

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234	1		1		1				
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	1	5	1	5	1	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	5	0	5	0	5	0	0	
	Grand Total	1082	6468	1	10	1	10	1	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.09.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR S	Nanakramguda	Gowlidoddi	33KV	Gachibowli	06.32	07.34	01.02		11kv Insulator failed and Line phase-to-phase occurred at Gowlidoddi	Gowlidoddi	-

TSSPDCL - LMRC / Corporate office

Date: 15.09.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Polkampally	11KV	Jadcherla	01.10	06.30	05.20		11KV Jumper cut near Polkampally	-
2		Balanagar	Mothiganapur	11KV	Jadcherla	01.30	09.00	07.30		11KV Jumper cut near Nandaram	-
1	NLG	Marriguda	y.g.Pally	11KV	Devarakonda	12.25	15.40	03.15	EL	Jumper Cutt	-
2		Shivanagyudam	S.R.Guda	11KV	Devarakonda	12.05	14.45	02.40	EL	11 KV Insulator Failed	-
3		Penpahad	Singireddy palem	11KV	Suryapet	06.30	09.30	03.00	EL	Conductor snapped	-
1	RR N	DPPally	Gandimaisamma Colony	11KV	Jeedimetla	16.50	18.33	01.43	EL/OL	11kv line Jumper Cut, at Opp: Gandimaisamm X Road	-
1	RR E	Pocharam	Jodimetla	11KV	Keesara	11.38	12.08	00.30		Pin Insulaotr Fail at Jodimetala	-
2		RGK	RGK	11KV	Keesara	11.07	12.07	01.00		11KV line cut at SS yard	-
1	HYD S	Karwan	Jiyaguda OH	11KV	IX	14.55	17.45	02.50	EL	UG Cable fault at Golconda Apartment	-----
1	HYD C	Industrial Area	Vidya Nagar	11KV	II	15.50	16.50	01.00	EL,OL-R&Bph	Cable punctured near SS	Arranged B/F on 11KV Ram Nagar fdr