

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234	1	1	1	1	1	1			
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	1	3	1	3	1	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3		3		3				
2	NLG	144	988	1		1		1				
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	2	4	2	4	2	0	0	
	Grand Total	1082	6468	5	5	5	5	5	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 16.09.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	SDPT	KOHEDA	VENKATESHWARAPALLY	11kv	SDPT	15.45	18.00	02.15		11KV Conductor Snapped	
2		Rebarthy	Gagillapur Agl	11kv	SDPT	14.20	16.20	02.00		Insulator Failure	
1	RR S	Kattedan-II	New citizenkanta	11kv	RJNR	17.30	19.20	01.50	B/D	No visible fault	-
1	HYD N	Jubilee Hills	Jubilee Hills	11kv	Jubilee Hills	07.50	09.00	01.10	Relay Problem	Relay Problem at SS & Bird fault at Rd.No.44	Arranged B/F on 11KV Jubilee Hills PS feeder
1	HYD S	Exhibition	Seetharampet	11kv	Begumbazar	17.52	19.50	01.58	EL	Breaker problem at SS	Arranged B/F on 11KV Hindi Nagar feeder

TSSPDCL - LMRC / Corporate office

Date: 16.09.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	SLC Mills	33KV	Mahabubnagar	13.10	15.50	02.40	O/L	Jumper cut at Picnic Hotel M.Nagar	SLC Mills	-
2		Kodangal	Dudyal	33KV	Vikarabad	16.30	17.10	00.40	O/L	Due to Rain	Dudyal	-
3		Maddur	Kothapally	33KV	Narayanapet	17.30	18.45	01.15	O/L	Pin Insulater Damaged at Devargattu Thanda	Kothapally	-
1	NLG	K.M.Pally	Neredugomma	33KV	Devarakonda	16.50	19.40	02.50	E/L	33Kv Jumper cut	Neredugomma	-
1	RR S	Nanakramguda	Gowlidoddi	33KV	Gachibowli	06.32	07.34	01.02		11kv Insulator failed and Line phase-to-phase occured at Gowlidoddi	Gowlidoddi	-