

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		4		4		4			
6	RR(N)	54	550		6		6		6			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		5		5		5			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>18</b>	<b>0</b>	<b>18</b>	<b>0</b>	<b>18</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	5	3	5	3	5	3			
2	NLG	144	988	3	16	3	16	3	16			
3	MDK	107	933	1		1		1				
4	SDPT			3	20	3	20	1	20	2		1 No.s 33kv still
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>12</b>	<b>39</b>	<b>12</b>	<b>39</b>	<b>10</b>	<b>39</b>	<b>2</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>12</b>	<b>57</b>	<b>12</b>	<b>57</b>	<b>10</b>	<b>57</b>	<b>2</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 17.09.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Gangapur	Gangapur	11kv	Jadcherla	05.30	08.50	03.20		11KV Insulator Failed Near Gangapur	-
2		Peddarevally	Ind	11kv	Jadcherla	14.30	16.35	02.05		11KV Wire Cut Near BSEPL Company	-
3		Udithyal	Udithyal	11kv	Jadcherla	14.38	16.10	01.32		11KV Insulator Failed Near Veerannapally	-
1	NLG	Penpahad	Macharam	11kv	Suryapet	13.00	16.00	03.00	E/L	Insulator flashover	-
2		Ravulapally	Ravulapally	11kv	Suryapet	14.50	16.00	01.10	E/L	Jumper cut	-
3		Urulugonda	Sarvaram	11kv	Huzarnagar	13.20	16.20	03.00	EL	Due to 11kv line snapped	
4		Palem	Bopparam	11kv	Nalgodna	05.10	11.20	06.10	E/L	11 KV Jumper Cut	
5		B.Banda	N.G.Kothapally	11kv	Nalgodna	06.30	09.10	02.40	E/L	11 KV Insulator Failed	
6		D.b.pally	Nerlapally	11kv	Devarakonda	13.00	15.00	02.00	E/L	Jumper Cut	
7		Nampally	Peddapuram	11kv	Devarakonda	14.00	16.00	02.00	E/L	11 KV Insulator Failed	
8		Nampally	Nampally Town	11kv	Devarakonda	14.00	18.10	04.10	E/L	100 KV DTR Failed SS	
9		Nampally	Mandhapuram	11kv	Devarakonda	14.00	19.30	05.30	E/L	11 KV Insulator Failed	
10		Nampally	M.R.Pally	11kv	Devarakonda	14.00	16.30	02.30	E/L	Tree Follen	
11		Cherkupally	Nijamnagar	11kv	Devarakonda	08.00	12.30	04.30	E/L	11 KV Conductor sanpped	
12		Ghanapuram	G.b.pally	11kv	Devarakonda	04.30	12.30	08.00	E/L	11KV Conductor Sanpped	
13		Ghanapuram	Polkampally	11kv	Devarakonda	06.45	07.15	00.30	E/L	11KV Conductor Sanpped	
14		Azmapuram	Mallapuram	11kv	Devarakonda	00.00	08.40	08.40	E/L	Male & Female	
15		Pendlipakala	Pendlipakala	11kv	Devarakonda	16.00	18.45	02.45	E/L	Jumper cut	
16		Pendlipakala	Chinthakuntla	11kv	Devarakonda	16.00	18.00	02.00	E/L	11KV Conductor Sanpped	
1	SDPT	Husnabad	Husnabad Town-2	11kv	Husnabad	20:50	21:30	00.40		BD DUE TO Jumper cut	-
2		Husnabad	Madatha	11kv	Husnabad	21:15	23:50	02.35		BD DUE TO RAIN	
3		Akkannapet	Pakilnayak Thanda	11kv	Husnabad	20:20	23:45	03.25		1PH OK,3PH BD DUE TO RAIN	
4		Akkannapet	Akkannapet Rural	11kv	Husnabad	20:20	23:30	03.10		1PH OK,3PH BD DUE TO RAIN	
5		Akkannapet	Gollakunta	11kv	Husnabad	20:20	23:15	02.55		1PH OK,3PH BD DUE TO RAIN	
6		Dharmaram	Dharmaram(R.)	11kv	Husnabad	19:20	23:02	03.42		1PH OK,3PH BD DUE TO RAIN	
7		Dharmaram	Nandaram	11kv	Husnabad	20:50	23:48	02.58		1PH OK,3PH BD DUE TO RAIN	
8		Regulapally	Cheelapur	11kv	Husnabad	9:50	15:50	06.00		INSULATOR FAILURE	
9		Koheda	Kurella	11kv	Husnabad	20:00	23:05	03.05		1PH OK,3PH BD DUE TO RAIN	
10		Koheda	Theegalakuntapally	11kv	Husnabad	20:00	23:42	03.42		1PH OK,3PH BD DUE TO RAIN	
11		Koheda	Sriramulapally	11kv	Husnabad	20:00	23:35	03.35		1PH OK,3PH BD DUE TO RAIN	
12		Shanigaram	Shanigaram Rural	11kv	Husnabad	20:10	23:55	03.45		1PH OK,3PH BD DUE TO RAIN	
13		Shanigaram	Gundareddypally	11kv	Husnabad	20:10	23:40	03.30		1PH OK,3PH BD DUE TO RAIN	
14		Shanigaram	Thangallapally	11kv	Husnabad	20:10	23:25	03.15		1PH OK,3PH BD DUE TO RAIN	
15		Cherial Town	Rollabanda Agl	11kv	Husnabad	10:00	10:30	00.30		BD HT/LT	
16		Cherial Town	Sundarayyanagar Agl	11kv	Husnabad	18:30	23:15	04.45		BD DUE TO RAIN	
17		Gurjakunta	Dommata	11kv	Husnabad	10:20	13:10	02.50		BD HT LINE TOUCHES DTR & SNAKE DIED ON LINE	
18		Komuravelly	Komuravell 24 Hrs	11kv	Husnabad	19:15	19:50	00.35		BD TREE BRANCHES FALLEN ON HT LINE	
19		Nagapuri	Nagapuri	11kv	Husnabad	14:25	15:15	00.50		BD HT/LT	
20		Gagillapur	Vallampatla	11kv	Husnabad	21:10	23:52	02.42		1PH OK,3PH BD DUE TO RAIN	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR S	Chanda Nagar	Huda Colony	11kv	GCB	13.50	15.00	01.10		11kv Pin-insulator failed at ICICI-Bank, Huda colony	-
2		Gachibowli	Gopanpally	11kv	GCB	13.50	15.15	01.25		1) 11kv 2 No. Disk failed at laxmi Infratech 2)11kv Pin-insulator failed at Uma Sai Apartment	-
3		Gachibowli	Nallagandla	11kv	GCB	14.00	15.00	01.00		Tree branches fallen on the 11kv line at Gulmarg park	-
4		Mathrusri Nagar	Srila	11kv	GCB	19.15	20.30	01.15		11kv Pin-insulator failed at SMR Apartments, Srila Apartments	-
1	RR N	Athiwelly	Ravalkole thanda	11kv	Medchal	12.05	13.30	01.25	BD	Tree fallen on the 11kv Line	-
2		Kistapur	IDA Hanuman	11kv	Medchal	12.25	13.05	00.40	BD	11KV pin insulator failed	-
3		Medcha	Checkpost	11kv	Medchal	18.10	19.20	01.10	BD	11KV conductor snapped at Checkpost	-
4		Kompally	Dolaridhani	11kv	Medchal	18.22	19.36	01.14	BD	11kv Coper patti cut at dolaridhani	-
5		Chandanagar	Shankar Nagar	11kv	Kukatpally	15.20	16.30	01.10	BD	11KV Line snapped at Shankarnagar	-
6		Athiwelly	Spic	11kv	Medchal	19.55	21.55	02.00	BD	11KV Pin Insulator failed at Rekulabavi	-
1	RR E	Yapral	Tulasi Garden	11kv	Sainikpuri	19.20	20.50	01.30		11Kv Pin Insuletor failure at Shaily Garden (AE/OP)	-
2		Narapally	Narapally	11kv	Keesara	11.28	12.48	01.20		Pin Insulator fail at Vijaypuri colony	-
3		Chengicherla	Chengicherla	11kv	Keesara	10.55	11.55	01.00		Pin Insulator fail at Maha ganapathi nagar	-
1	HYD S	Salarjung	Alija Kotla	11kv	III	09.20	13.50	04.30	EL,OL-Bph	Fatal accident & DTR fault at Darul-UI-Loom	-
2		Ch' Baradari	Ch' Baradari	11kv	III	16.45	18.35	01.50	OL-R&Bph	O/G R&Bph Jumpers cut & Pin Insulator falsh over at SS	-
3		E.N.T	C.B.I	11kv	IX	21.15	23.15	02.00	EL,OL-Rph	Cable Punctured at 94 Bus Stop (1No. DTR Kept Off)	Partial fdr arranged B/F at 22:55 Hrs on Koti fdr (10 amps)
1	HYD N	Bhudevi Nagar	Yadamma Nagar	11kv	C-VI	19.30	20.50	01.20	EL	No Visible Fault	----
2		Chinna Thokatta	Hasmathpet	11kv	D-6	22.55	01.20	02.25	EL,OL-Yph	l/C Cable fault at Hasmathpet Chowrasta	Arranged B/F on 11KV Old Bowenpally & 11KV M.D.F fdrs

## TSSPDCL - LMRC / Corporate office

Date: 17.09.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Pebbair	33kv	Wanaparthi	17.37	19.40	02.03	E/L	Due to Rain	Pebbair	-
2		Nagarkurnool	Manthathi	33kv	Nagarkurnool	07.25	15.40	08.15	E/L	Conductor Snapped at Chandubatla Gate	Manthathi	-
3		Balanagar	G.R Cable	33kv	Jadcherla	14.58	17.05	02.07	E/L	33KV Jumper cut at Hari Om Industry	G.R Cable	
4		Achampet	Veltoor	33kv	Nagarkurnool	15.20	17.35	02.15	E/L	Pin Insulator Failed at Koratikal (V)	Veltoor	-
5		Amangal	Polepally	33kv	Shadnagar	14.05	16.50	02.45	O/L	No Visible Fault Due to Rain	Polepally	-
1	NLG	K.M.Pally	Gurrampodu	33kv	Devarakonda	14.30	18.10	03.40		Jumper cut	Gurrampodu	-
2		K.M.Pally	Neredukomu	33kv	Devarakonda	14.30	17.30	03.00		Jumper cut	Neredukomu	-
3		Guntipally	Padamatpally	33kv	Devarakonda	14.00	18.05	04.05		33KV Insuletor Failed	Padamatpally	-
1	MDK	Sadashivapet	Koheer	33kv	Sangareddy	16.30	17.00	00.30		B/D due to Jumper cut	Koheer	-
1	SDPT	Siddipet	Chandlapur	33kv	Siddipet	19.55	21.40	01.45		Tree Branches fall in line	Chandlapur	-
2		Husnabad	Water Grid	33kv	Husnabad	20.00	00.00	04.00		B/D due to Heavy Rain & Gal	HUSNABAD	-
3		Husnabad	Katkur	33kv	Husnabad	20.15	00.00	03.45		B/D due to Heavy Rain & Gal	HUSNABAD	-