

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------|------------------------------|------|------------------------------------|------|-------------------------|------|-------------------------------------|------|--------------------------------|------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | 7 | | 7 | | 7 | | | |
| 7 | RR(E) | 168 | 403 | | 1 | | 1 | | 1 | | | |
| 8 | Hyd | 194 | 1044 | 1 | 2 | 1 | 2 | 1 | 2 | | | |
| | Total | 606 | 3055 | 1 | 10 | 1 | 10 | 1 | 10 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|-------------|-------------------------------|------|------------------------------------|------|-------------------------|------|-------------------------------------|------|--------------------------------|------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | | 3 | | 3 | | 3 | | | |
| 2 | NLG | 144 | 988 | 1 | 5 | 1 | 5 | 1 | 5 | | | |
| 3 | MDK | 107 | 933 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 1 | 8 | 1 | 8 | 1 | 8 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 2 | 18 | 2 | 18 | 2 | 18 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 18.09.2018

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------------|------|----------------------|-------|-------|----------|------------------|--------------------------------------|----------------------------|---------------------------|
| 1 | NLG | Suryapeta | Yerkaram | 33KV | Suryapeta | 07.00 | 10.30 | 03.30 | E/L | Insulator failure | Yerkaram | - |
| 1 | HYD N | 132KV J' Hills | Hitech City (HT Service) | 33KV | Kalyan Ngr | 17.00 | 18.20 | 01.20 | EL,OL-Rph | Cable damaged at Kotak Mahindra Bank | Hitech City (HT Service) | - |

TSSPDCL - LMRC / Corporate office

Date: 18.09.2018

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1 | MBNR | Narva | Lankal | 11KV | Mahabubnagar | 09.30 | 11.30 | 02.00 | | 11KV Disk failure at Lankal (vi) | - |
| 2 | | Lokirew | Lingampally | 11KV | Jadcherla | 05.00 | 10.00 | 05.00 | | 11KV Disk fail near Kishan Guda | - |
| 3 | | Polepally | Vallur | 11KV | Jadcherla | 08.00 | 10.30 | 02.30 | | 25 KVA DTR Fail near Chinnapally | - |
| 1 | NLG | Jammigadda | Estate | 11KV | Suryapeta | 02.50 | 05.30 | 02.40 | E/L | Insulator flashover | - |
| 2 | | Gundepuri | Gundepuri | 11KV | Suryapeta | 06.00 | 09.45 | 03.45 | E/L | Jumper cut | - |
| 3 | | Chada | Nancharipeta | 11KV | Bhongiri | 06.00 | 08.00 | 02.00 | E/L | 11KV Pin Insulator failure | - |
| 4 | | Azeempeta | Repaka | 11KV | Bhongiri | 06.00 | 08.20 | 02.20 | E/L | Insultor failure | - |
| 5 | | Peddathanda | Peddathanda | 11KV | Bhongiri | 08.00 | 10.25 | 02.25 | E/L | 11KV Jumper cut | - |
| 1 | RR N | Jeedimetla-II | Uttam Biscuti | 11KV | Jeedimetla | 02.55 | 03.55 | 01.00 | EL | 11kv Pole broken At gati Transport company phase-III | - |
| 2 | | Jeedimetla-I | SU-Drugs | 11KV | Jeedimetla | 05.30 | 07.50 | 02.20 | EL/OL | 11kv AB Cable failure At phase_I | - |
| 3 | | Jeedimetla-I | phase-I | 11KV | Jeedimetla | 13.55 | 15.15 | 01.20 | EL/OL | LV-I Out Going Jumper Cut IN SuB- station | - |
| 4 | | Dulapally | KK Society | 11KV | Medchal | 14.17 | 15.30 | 01.13 | BD | 11KV Cable failed at Bharath Petroleum Opp backfeeding arranged from IDA-II feeder | - |
| 5 | | Athiwelly | SPIC | 11KV | Medchal | 19.55 | 21.55 | 02.00 | BD | 11KV Pin Insulator failed at Rekulabavi | - |
| 6 | | Laxmapur | Narayanapur | 11KV | Medchal | 07.48 | 09.36 | 01.48 | BD | 11KV Jumper cut and replaced at Lawyer Bhavi | - |
| 7 | | Gowdawelly | IDA | 11KV | Medchal | 15.10 | 16.55 | 01.45 | BD | Tree Branch fallen on the 11KV Line at Basaragadi | - |
| 1 | RR E | VK Nagar | Old Safilguda | 11KV | Sainikpuri | 15.15 | 15.35 | 00.20 | | Felexy failen on 11Kv line at Old Safilguda (AE/VK Nagar) | - |
| 1 | HYD S | Petlaburz | Shah Gunj | 11KV | III | 05.10 | 07.10 | 02.00 | EL,OL | Bird fault on lines & HT Jumper cut at Moosa Bowli & Jalal Kunta | - |
| 1 | HYD C | Amberpet | Golnaka | 11KV | II | 15.00 | 16.30 | 01.30 | EL | 2No. DTR's fault at Golnaka | - |