

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		3		3		3			
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>13</b>	<b>0</b>	<b>13</b>	<b>0</b>	<b>13</b>	<b>0</b>	<b>0</b>	



## TSSPDCL - LMRC / Corporate office

Date: 20.09.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Jadcherla	Badepally	11KV	Jadcherla	08.10	15.14	07.04		11 KV Jumper Cut near Allor (v)	-
2		Rajapur	Rajapur	11KV	Jadcherla	08.05	14.30	06.25		11 KV Disk fail near mallepally	-
3		Nawabpet	Nawabpet	11KV	Jadcherla	14.10	16.10	02.00		11 KV Wire cut near Dayapunthala pally.	-
1	NLG	Ravulapally	Ravulapally	11KV	Suryapet	13.40	16.20	02.40	E/L	11Kv Jumper cut	-
2		Mukundapuram	Dacharam	11KV	Huzurnagar	09.30	12.15	02.45	E/L	11Kv jumper cut	-
3		Mukundapuram	Kalluru	11KV	Huzurnagar	07.00	09.30	02.30	E/L	11Kv jumper cut	-
4		Repala	Narsimhulagudem	11KV	Huzurnagar	08.10	10.30	02.20	E/L	Tree Branch fall on 11Kv line	-
1	RR N	Shemshiguda	Thulasivanam	11KV	Kukatpally	04.15	10.30	06.15	EL/OL	11kv line AB Cable Endkit failed at opp good will Hotal Yellammabanda	-
2		UMCC	Crusher	11KV	Medchal	00.53	02.30	01.37	BD	11KV Line Cut & Replaced at Pinakini Crusher	-
3		Thurkapally	Thurkapally	11KV	Medchal	11.00	13.25	02.25	BD	Bird fallen on the 11KV Line & Bunch Cable failed at Telangana Pipes Company Backside & Jyothirmai College	-
4		ICICI	Bharath Biotech	11KV	Medchal	20.30	21.30	01.00	BD	Bird fallen on the 11KV Line at Unicorn Company	-
1	RR E	Vinayak Nagar	Devi Nagar	11KV	SKP	06.20	07.20	01.00		11Kv Jumper snapped at Old Neredmet near Darga (AE)	-
1	HYD C	Industrial Area	Azamabad I.E	11KV	Azamabad	10.35	12.05	01.30	EL	Bird fallen on lines at Biological	-