

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		7		7		7			
3	MDK	107	933									
4	SDPT			1	10	1	10	1	10			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	18	1	18	1	18	0	0	
	Grand Total	1082	6468	1	26	1	26	1	26	0	0	

TSSPDCL - LMRC / Corporate office

Date: 21.09.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	SDPT	Duddeda	Medhinipur	33KV	Gajwel	02.00	07.00	05.00		Polimer disk failed	Duddeda	No

## TSSPDCL - LMRC / Corporate office

Date: 21.09.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Ediganipally	Nandigama	11KV	Jadcherla	12.00	13.30	01.30		11KV Disc Fail near Ediganipally	-
1	NLG	Nereducherla	Dirsincherla	11KV	Huzurnagar	09.10	11.10	02.00	EL	Due to 11kv line cutted	-
2		Gaddipally	Ponugodu	11KV	Huzurnagar	06.20	09.06	02.46	EL	Due to 11kv line cutted	-
3		Mattampally	Allipuram	11KV	Huzurnagar	03.00	06.00	03.00	EL	Due to 11kv Disk failure	-
4		Ragnathpur	Challur	11KV	Bhongir	13.30	17.30	04.00	EL	11kv pin insulter Filed near Sadhuvelly Villge	-
5		Motakondur	Motakondur	11KV	Bhongir	07.15	09.00	01.45	EL	11kv pin insulter Filed near Motakondur Villge	-
6		Thurkapally	Hajalapur	11KV	Nalgonda	06.30	11.20	04.50	E/L	11 KV Line Insulator Failed	-
7		Narketpally	Yellareddygudem	11KV	Nalgonda	09.30	13.50	04.20	E/L	11 KV Jumper Cut	-
1	SDPT	Thotapally	Anthakapet	11KV	Gajwel	13.00	23.10	10.10		Break down (3Ph)	-
2		Dharmaram	Dharmaram rural	11KV	Gajwel	01.30	14.50	12.20		Jumper cutting	-
3		Shanigaram	Shanigaram town	11KV	Gajwel	10.20	13.00	02.40		Heavy gale and wind	-
4		Ramchandrapur	Varikolu	11KV	Gajwel	08.00	10.40	02.40		Heavy gale and wind	-
5		Regulapally	Regulapally	11KV	Gajwel	08.00	23.50	15.50		Heavy gale and wind(3Ph)	-
6		Regulapally	Mallamchervu	11KV	Gajwel	08.00	22.50	14.50		Heavy gale and wind(3Ph)	-
7		Komuravelli	komuravelli 7 hrs	11KV	Siddipet	15.30	18.00	02.30		Heavy gale and wind(3Ph)	-
8		Dhoolmitta	Lingapur	11KV	Siddipet	14.20	15.10	00.50		Jumper cutting	-
9		Dhoolmitta	Dhoolmitta 7hrs	11KV	Siddipet	11.30	12.10	00.40		Jumper cutting	-
10		Gagillapur	Vallampatla	11KV	Siddipet	16.00	23.15	07.15		Heavy gale and wind(3Ph)	-
1	RR S	Gaganpahad	Gaganpahad	11KV	RJNR	07.45	08.59	01.14	B/D	11KV Cable Failed at Green india venture	-
2		Kokapet	Ocean park	11KV	RJNR	08.35	12.10	03.35	B/D	11kv Line Snapped at villagreen venture	-
1	RR N	Bahadurpally	Laxmi Nagar	11KV	Jeedimetla	11.00	12.00	01.00	EL	Bird Fallen on the 11KV Line at Laxmi Nagar	-
2		Devarayamjal	DMC	11KV	Medchal	13.40	17.10	03.30	BD	11KV Pin Insulator failed at Devarayamjal Villge	-
3		Shameerpet	Devarayamjal	11KV	Medchal	14.20	15.10	00.50	BD	Bird fallon on the 11KV Line at Thumkunta Village	-
1	RR E	Sainikpuri	Ramalayam	11KV	Sainikpuri	14.40	17.40	03.00		11Kv 2 Disk failure at Defence Colony (AE/OP)	-
2		Nagaram	P.S rao nagar	11KV	Keesara	13.16	14.21	01.05		Bird fallen on 11kv line at Kushi garden	-
1	HYD N	Clock Tower	Station Road	11KV	Sec-Bad	15.20	17.08	01.48	EL,OL-Bph	O/G AB Switch Bph Jumper cut at SS	Remaining fdr B/F on 11KV Gurudwara fdr