

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044		9		9		9			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>12</b>	<b>0</b>	<b>12</b>	<b>0</b>	<b>12</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>14</b>	<b>0</b>	<b>14</b>	<b>0</b>	<b>14</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 23.09.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mushampally	Muthyalamma	11KV	Nalgonda	07.40	09.00	01.20	E/L	Jumper cut	-
1	SDPT	HUSNABAD	Madatha	11KV	HUSNABAD	13.25	13.40	00.15		Insulator fail	-
1	RR N	GP Pally	Malla Reddy College	11KV	Medchal	10.40	12.20	01.40	BD	Tree fallen on the 11KV Line and 11KV Line replaced at Mallareddy College	-
2		Medicity	Munirabad	11KV	Medchal	16.20	17.00	00.40	BD	11KV Line cut and replaced at Shameerpet Cheruvu	-
3		Town Medchal	Country club	11KV	Medchal	21.30	23.00	01.30	BD	11KV Pin Insulator Failed at Saibaba Nagar	-
1	HYD C	S.D.Hospital	Humayun Nagar	11KV	VII	20.20	21.55	01.35	EL,OL-Bph	HT Line snapped at Humayun Nagar	
2		Golconda	Darga OH	11KV	VII	21.07	00.55	03.48	EL	No Visible Fault (Feeder not charged due to Ganesh Idols procession)	
1	HYD N	I.D.P.L.	Shivalayam	11KV	VI	20.00	21.45	01.45	EL	No Visible Fault due to heavy Rain	
2		I.D.P.L.	I.E.	11KV	VI	20.00	21.45	01.45	EL	No Visible Fault due to heavy Rain	
3		Prashanth Nagar	Sony Complex	11KV	VI	20.05	22.00	01.55	EL	No Visible Fault due to heavy Rain	
4		Prashanth Nagar	Time Tek	11KV	VI	20.15	00.00	03.45	OL-R&Bph	HT Line snapped at Prashanth Nagar	
5		I.D.P.L.	Bala Nagar	11KV	VI	20.30	21.45	01.15	OL-Bph	No Visible Fault due to heavy Rain	
6		I.D.P.L.	Wonder Plast	11KV	VI	21.45	23.10	01.25	EL	Pin Insulator flash over at HMS Steel	
7		H.M.T.	Sri Sai Colony	11KV	VI	21.30	22.42	01.12	EL	No Visible Fault due to heavy Rain	

TSSPDCL - LMRC / Corporate office

Date: 23.09.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR				NIL					NIL		-
2	NLG				NIL					NIL		-
3	MDK				NIL					NIL		-
4	SDPT				NIL					NIL		-
5	RR S				NIL					NIL		-
6	RR N				NIL					NIL		-
7	RR E				NIL					NIL		-
8	HYD C				NIL					NIL		-
9	HYD N				NIL					NIL		-
10	HYD S				NIL					NIL		-