

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3		3		3				
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	5	3	5	3	5	0	0	
	Grand Total	1082	6468	3	13	3	13	3	13	0	0	

TSSPDCL - LMRC / Corporate office

Date: 24.09.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Midjil	Madaram	33kv	Jadcherla	13.50	15.10	01.20	O/L	Due to Phase to Phase	Madaram	-
2		Puttapad	Nancherla	33kv	Narayanapet	12.00	12.35	00.35	E/L	Due to 33KV Line Snapped	Nancherla	-
3		Mahabubnagar	Jadcherla	33kv	Mahabubnagar	22.40	23.05	00.25	E/L&O/L	Supply Stood OK After Opening the Isolator at Thimmajipet. Avancha,Nerellapally line was Dark	Jadcherla	-

TSSPDCL - LMRC / Corporate office

Date: 24.09.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Narkatpally	Mandra	11kv	Nalgonda	12.30	15.32	03.02	E/L	11KV jumper cut	-
1	Siddipet	Husnabad	Husnabad Town-2	11kv	Husnabad	17.15	17.30	00.15		BD INSULATOR FAILURE	-
2		Husnabad	Madatha	11kv	Husnabad	16.30	17.10	00.40		BD,JUMPER CUT	-
3		Bejjanki	Kallepally	11kv	Husnabad	15.00	18.30	03.30		BD,INSULATOR FAILURE	-
4		Cherial Town	Sundarayyanagar Agl	11kv	Husnabad	18.00	23.50	05.50		BD INSULATOR FAILURE	-
1	RR S	IIIT	APHB Colony	11kv	Gaachibowli	12.30	14.20	01.50		Tree branches fallen on the 11kv Line at APHB Colony	-
1	RR N	GP Pally	Malla Reddy College	11kv	Medchal	10.40	12.20	01.40	BD	Tree fallen on the 11KV Line and 11KV Line replaced at Mallareddy College	-
2		Medicity	Munirabad	11kv	Medchal	16.20	17.00	00.40	BD	11KV Line cut and replaced at Shameerpet Cheruvu	-
3		Town Medchal	Country club	11kv	Medchal	21.30	23.00	01.30	BD	11KV Pin Insulator Failed at Saibaba Nagar	-
1	RR E	Moula-Ali	Spectra	11kv	Sainikpuri	16.53	17.15	00.22		Bird fallen on 11Kv lne at Suoer gas company (FOC Raju)	-
2		Vinayak Nagar	Tank Bund	11kv	Sainikpuri	16.34	16.56	00.22		100kva DTR failed at Venkateshwar Nagar near Bal Ram Nagar (AE)	-
1	HYD S	Moosarambagh	Shalivahana Nagar	11kv	VIII	17.55	19.25	01.30	OL-Bph	Line AB Switch Insulator flash over at Mayuri Ramaiah	-----
2		Vittalwadi	Ramkoti	11kv	IX	21.10	22.15	01.05	EL,OL-Rph	Cable fault at Ramkoti	Arranged B/F on 11KV Gayatri Hotel fdr