

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		5		5		5			
8	Hyd	194	1044		9		9		9			
	Total	606	3055	0	17	0	17	0	17	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	6		3		3		3		3 Nos. 33KV Still
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	6	3	3	3	3	3	3	0	
	Grand Total	1082	6468	6	20	3	20	3	20	3	0	

TSSPDCL - LMRC / Corporate office

Date: 25.09.18

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Mogalmadka	33KV	Narayanpet	18.00	18.30	00.30	E/L&O/L	Due to Rain	Mogalmadka	Alternate Supply Arranged from 33KV Kankurthy SS at 18:30Hrs
2		Marikal	Kondapur	33KV	Narayanpet	18.55	21.35	02.40		Pin Insulator failed near Sanganonipally (V)	Kondapur	No
3		Marikal	Water Gridd	33KV	Narayanpet	18.20	22.05	03.45		Due to Rain	Water Gridd	Alternate Supply Arranged from 33KV Kondapur At 22:05Hrs
4		Marikal	Koukuntla	33KV	Narayanpet	17:10	18:05	0:55		Due to Rain, Nagaram Jumpers Opened Supply Stood OK	Koukuntla	No
5		Thirumalaipally	Veltoor	33KV	Wanaparthy	19:10	19:35	0:25	E/L	Due to Rain	Veltoor	Alternate Supply Arranged from 33KV Peddamandadi SS at 19:35Hrs
6		Nagarkurnool	Tadoor	33KV	Nagarkurnool	16.19	20.10	03.51	E/L	Pin Insulators failed & tree branches fallen on the line near Gunta Kodoor	Tadoor	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Cheedella	G.M Puram	11KV	Suryapet	11:25	12:55	1:30	E/L	Insulator failed	No
2		Chada	Katepally	11KV	Bhongir	16.00	17.20	01.20	EL	11KV Line snapped at near Katepally	No
3		Champur	Champur	11KV	Bhongir	16.00	17.40	01.40	EL	11KV Insulator failed near Rekula kunta	No
1	RR N	Bommarajpet	Ponnal	11KV	Medchal	14:05	16:30	2:25		11KV Pole damaged at Yerra Kunta, Ponnal Village	No
2		Laxmapur	Laxmapur	11KV	Medchal	15.10	17.42	02.32		Tree Branch fallen on the 11KV Line at Forest Area	No
3		Laxmapur	IDA	11KV	Medchal	15.10	17.40	02.30		11KV Pin insulator failed at Potharam Road	No
1	RR E	Moula Ali	Gayatri Nagar	11KV	Sainikpuri	15:08	16:02	0:54		No visible fault	No
2		Vinayak Nagar	Tank Bund	11KV	Sainikpuri	14.18	16.10	01.52		Insulator failed	No
3		Kushaiguda	Kamala Nagar	11KV	Sainikpuri	14.30	15.18	00.48		Tree branches fallen on 11KV line	No
4		Kushaiguda	Kushaiguda	11KV	Sainikpuri	14.26	15.20	00.54		Tree branches fallen on 11KV line	No
5		Singapur	IT park	11KV	Habsiguda	17:00	19:35	2:35		Pin insulator faied	No
1	HYD S	E.N.T.	Gurudwara	11KV	Begumbazar	14.10	15.35	01.25	EL	DTR fault at Golden Press	No
2		Devi Bagh	Rama Talkies	11KV	Charminar	14:12	15:40	1:28	EL	HT Line snapped at Kamatipura	No
3		Devi Bagh	Kamela	11KV	Charminar	14:12	15:49	1:37	EL	No Visible Fault due to heavy rain	No
4		Attapur	N.M.Guda OH	11KV	Charminar	14:12	15:40	1:28	EL	Tree fallen on lines at Mallaiah Towers	No
5		Jiyaguda	Dolphine Hotel	11KV	Begumbazar	14.20	15.30	01.10	EL	Foreign material fallen on lines at Dolphin Hotel	No
6		Attapur	Hasad Baba Nagar	11KV	Charminar	14.25	16.12	01.47	EL,OL-R&Bph	HT Line snapped at Govt. School & Pin Insulator flash over at Shakeel PT	No
7		Attapur	Bahadurpura OH	11KV	Charminar	15.05	17.30	02.25	EL	Tree branches fallen on lines at Bahadurpura	No
8		Attapur	Puranapool	11KV	Charminar	15.05	17.55	02.50	EL,OL-R&Bph	Tree fallen on DTR at Golden Press	No
9		Yakuthpura	Sravani Hospital	11KV	Asmangadh	23.24	00.26	01.02	EL	Cable fault at Mohammad Nagar Nala	Arranged B/F on 11KV Kummarwadi feeder