

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	1	2	1	2	1			
2	NLG	144	988		1		1		1			
3	MDK	107	933	2	3	2	3	2	3			
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	8	4	8	4	8	0	0	
	Grand Total	1082	6468	4	10	4	10	4	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 29.09.2018

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Koilkonda Water Grid	33KV	Narayanapet	16.40	19.50	03.10	E/L	Insulator Replacement at Gotoor Tower	Koilkonda Water Grid	-
2		Wanaparthi	Chinnamaroor	33KV	Wanaparthi	13.25	13.40	00.15	E/L	33KV Jumper Cut near at Thirmalai gutta & Badda Bai Thanda	Chinnamaroor	Supply Arranged From 33KV Velgonda SS at 13:40Hrs.
1	MDK	Pashamailaram	EPIP	33KV	Sangareddy	08.45	09.45	01.00		B/D Due to Jumper Cut	EPIP	-
2		Singoor	Mudhimanik	33KV	Jogipet	15.40	16.40	01.00		B/D due to Insulator failure	Mudhimanik	-

TSSPDCL - LMRC / Corporate office

Date: 29.09.2018

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Peddarevelly	Peddarevelly	11KV	Jadcherla	08.00	11.30	03.30		Phase to Phase and 11 KV Insulater Fail near Devunigutta thanda	-
1	NLG	Reddygudem	Reddygudem	11KV	Suryapet	03.30	06.20	02.50	EL	Bird fallen on the line	-
1	MDK	Sangareddy	Filterbed	11KV	Sangareddy	16.20	19.15	02.55		B/D due to Tree branches fallen on the line.	-
2		Collectorate	Kothlapur	11KV	Sangareddy	13.30	16.30	03.00		B/D due to Tree branches fallen on the line near Aloor (V).	-
3		Collectorate	Balaji	11KV	Sangareddy	18.28	19.28	01.00		B/D due to Insulator failure near Balaji Hospital.	-
1	SDP	Gurjakunta	Gurjakunta Town	11KV	Husnabad	17.05	18.10	01.05		Insulator failure and same rectified.	-
2		Nagapuri	Gandikunta	11KV	Husnabad	14.50	16.30	01.40		Tree brach fallen same rectified	-
3		Husnabad	Malapally	11KV	Husnabad	07.35	08.45	01.10		11KV jumper cut same rectified	-
1	RR E	Kushaiguda	AS Rao Nagar	11KV	Sainikpuri	01.45	02.35	00.50		Ground Petrolling done but no Visible fault found	-
1	HYD S	Falaknuma	Falaknuma UG	11KV	III	21.20	22.30	01.10	EL,OL-Rph	Cable Fault	Arranged B/F on 11KV Vatte Pally fdr