

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988	1	6	1	6	1	6			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>7</b>	<b>2</b>	<b>7</b>	<b>2</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>11</b>	<b>2</b>	<b>11</b>	<b>2</b>	<b>11</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 02.04.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Achampet	Amrabad	33KV	Nagarkurnool	20.10	20.45	00.35	O/L	Due to AB Switch Damaged and Replacment at Amrabad	Achampet	No
1	NLG	132/33KV Ramannapet	33KV Chityala	33KV	Nalgonda	09.30	11.45	02.15	E/L	33KV Line Insulator Failur	Nereda SS, Urumadla SS, Goplaipally SS	No

## TSSPDCL - LMRC / Corporate office

Date: 02.04.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Aipoor	Isthalapuram	11KV	Suryapeta	05.55	08.30	02.35	EL	Insulator failed	-
2		Mamidala	G.V.Gudem	11KV	Nalgonda	13.10	15.30	02.20	EL	11KV Line Insuator Failur	-
3		Wangamarthy	Chittaior	11KV	Nalgonda	08.00	10.40	02.40	EL	11KV AB Switch Fimail Cut	-
4		Pazzur	Pedda Suraram	11KV	Nalgonda	12.25	14.30	02.05	EL	HT/LT Line Melting	-
5		Gondriyala	Gondiryala 01	11KV	Huzurnagar	16.05	17.20	01.15	EL	Due to jumper cutted	-
6		Repala	Narsimhulagudem	11KV	Huzurnagar	11.13	13.15	02.02	EL	Due to jumper cutted	-
1	SDPT	Nangunoor	Akkanapally	11KV	Husnabad	02.10	06.10	04.00		BD Jumper Cut.	
1	RR N	Dp pally	A G L gagillapur	11KV	Jeedimetla	07.40	08.40	01.00	EL	Tree fallon the 11kv line At pochaampally	-
1	HYD N	Road No.13	Road No.1	11KV	Banjarahills	10.36	11.48	01.12	EL,OL	3Way RMU Cable fault at Road No.1	-
1	HYD S	Falaknuma	Chatrinaka	11KV	Charminar	05.15	06.47	01.32	EL	Cable fault at Chatrinaka	Arranged B/F on 11KV G.M.Chowni & 11KV Gowlipura fdrs
1	HYD C	Fever Hospital	Tourist Hotel	11KV	Azamabad	09.05	11.05	02.00	EL,OL-Bph	5Way RMU Cable fault at Tourist Hotel	-