

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		1		1		1			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 03.04.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Sadashivapet	Koheer	33KV	Sangareddy	17.50	19.00	01.10		B/d due to Jumper cut		-

## TSSPDCL - LMRC / Corporate office

Date: 03.04.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Polkampally	11KV	Jadcherla	11.00	14.30	03.30		11KV Wire cut near Polkampally	-
1	NLG	Alair	Alair Town	11KV	Bhongir	05.10	06.30	01.20	EL	Tree Branches Fallen at Line Near Alair Town Post Office	-
1	MDK	Gaddapotharam-II	Kajipally Indl.	11KV	Patancheru	12.55	13.45	00.50		B/d due to Jumper cut	-
2	SDPT	MUSTHYAL	CHERIAL TOWN	11KV	Husnabad	15.20	17.25	02.05		HT/LT BD	-
3		GAGILLAPUR	GAGILLAPUR	11KV	Husnabad	01.00	10.40	09.40		HT/LT BD	-
4		THOTAPALLY	MALLAMPALLY	11KV	Husnabad	11.00	12.00	01.00		BDINSULATOR FAILED	-
5		BASWAPUR	POREDDYPALLY	11KV	Husnabad	04.40	08.20	03.40		JUMPPER CUT FALLEN ON DTR BD	-
1		RR N	Jeedimetla-I	Nitco	11KV	Jeedimetla	16.15	19.10	02.55	EL/OL	Tripped On EL/OL,AB Cable Endkit failure Near Sai kantta
1	RR E	Moula ali	Malkajgiri	11KV	Sainikpuri	14.20	15.07	00.47		Tree fallen on 11KV line near Berral Ground at Hanuman Nagar (L.Insp Venkateshwarulu)	-