

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		3		3		3			
3	MDK	107	933	2		2		2				
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	4	3	4	3	4	0	0	
	Grand Total	1082	6468	3	4	3	4	3	4	0	0	

TSSPDCL - LMRC / Corporate office

Date: 04.04.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Bijinapally	33KV	Nagarkurnool	13.24	14.35	01.11	E/L	No Visible Fault	Bijinapally	-
1	MDK	Narayankhed	Kalher	33KV	Jogipet	17.50	20.45	02.55		B/D Due to Conductor Snapped	Kalher	-
2		Sadasivpet	Koheer	33KV	Sangareddy	22.05	23.05	01.00		B/D Due to Jumper Cut	Koheer	-

TSSPDCL - LMRC / Corporate office

Date: 04.04.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Gaddipally	Ponugodu	11KV	Huzurnagar	08.30	11.15	02.45	EL	11 KV INSULATOR FAILED	-
2		Kalmalchervu	Ganugabanda	11KV	Huzurnagar	05.00	06.30	01.30	EL	11 KV JUMPER CUT	-
3		Y.Gutta	Saidapur	11KV	Bhongiri	09.30	11.05	01.35	OL	11 KV Line Snapped Near Yadagirigutta Town	-
1	SDPT	Marmamula	Dharmaram	11KV	Husnabad	06.45	09.22	02.37		Break Down due to line problem	-