

## Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle       | No. of Feeders Existing Urban |             | Breakdowns occurred during the day |          | Attended during the day |          | Time taken for restoring the supply |          |                                |          | Remarks (Pending) |
|------|--------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
|      |              | 33KV                          | 11KV        | 33KV                               | 11KV     | 33KV                    | 11KV     | Rectified (Within 24 Hours)         |          | Not Rectified (Above 24 Hours) |          |                   |
|      |              |                               |             |                                    |          |                         |          | 33KV                                | 11KV     | 33KV                           | 11KV     |                   |
| 1    | MBN          | 18                            | 107         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 2    | NLG          | 22                            | 358         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 3    | MDK          | 97                            | 359         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 4    | SDPT         |                               |             |                                    |          |                         |          |                                     |          |                                |          |                   |
| 5    | RR(S)        | 53                            | 234         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 6    | RR(N)        | 54                            | 550         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 7    | RR(E)        | 168                           | 403         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 8    | Hyd          | 194                           | 1044        |                                    | 1        |                         | 1        |                                     | 1        |                                |          |                   |
|      | <b>Total</b> | <b>606</b>                    | <b>3055</b> | <b>0</b>                           | <b>1</b> | <b>0</b>                | <b>1</b> | <b>0</b>                            | <b>1</b> | <b>0</b>                       | <b>0</b> |                   |

Rural

| S.No | Circle             | No. of Feeders Existing Rurals |             | Breakdowns occurred during the day |           | Attended during the day |           | Time taken for restoring the supply |           |                                |          | Remarks (Pending) |
|------|--------------------|--------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
|      |                    | 33KV                           | 11KV        | 33KV                               | 11KV      | 33KV                    | 11KV      | Rectified (Within 24 Hours)         |           | Not Rectified (Above 24 Hours) |          |                   |
|      |                    |                                |             |                                    |           |                         |           | 33KV                                | 11KV      | 33KV                           | 11KV     |                   |
| 1    | MBN                | 107                            | 849         | 5                                  | 2         | 5                       | 2         | 5                                   | 2         |                                |          |                   |
| 2    | NLG                | 144                            | 988         |                                    | 26        |                         | 26        |                                     | 26        |                                |          |                   |
| 3    | MDK                | 107                            | 933         | 1                                  | 1         | 1                       | 1         | 1                                   | 1         |                                |          |                   |
| 4    | SDPT               |                                |             | 1                                  | 12        | 1                       | 12        | 1                                   | 12        |                                |          |                   |
| 5    | RR(S)              | 58                             | 396         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 6    | RR(N)              | 38                             | 114         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 7    | RR(E)              | 22                             | 133         |                                    |           |                         |           |                                     |           |                                |          |                   |
|      | <b>Total</b>       | <b>476</b>                     | <b>3413</b> | <b>7</b>                           | <b>41</b> | <b>7</b>                | <b>41</b> | <b>7</b>                            | <b>41</b> | <b>0</b>                       | <b>0</b> |                   |
|      | <b>Grand Total</b> | <b>1082</b>                    | <b>6468</b> | <b>7</b>                           | <b>42</b> | <b>7</b>                | <b>42</b> | <b>7</b>                            | <b>42</b> | <b>0</b>                       | <b>0</b> |                   |

TSSPDCL - LMRC / Corporate office

Date: 09.04.2019

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown  | Sub Stations Effected | Alternate Supply Arranged  |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|--|
| 1    | MBNR   | Mahabubnagar        | Jadcherla            | 33KV | Mahabubnagar         | 16.30 | 19.15 | 02.45    | E/L&O/L          | Due to Heavy Gale & Wind  | Mahabubnagar          | Alternate Supply arrange from 132KV SS Polepally at 19:15Hrs                 |
| 2    |        | Palkonda            | Kothamolgera         | 33KV | Mahabubnagar         | 19.10 | 20.30 | 01.20    | E/L              | Insulator Failed at Karvena Village   | Palkonda              | No   |
| 3    |        | Palkonda            | Kodur                | 33KV | Mahabubnagar         | 19.53 | 23.55 | 04.02    | E/L              | for Loads Change Over 33KV Kodur Feeder Loads Tag on to 33KV Machanpally Feeder | Palkonda              | Alternate Supply Arranged From 33KV Machanpally at 23:55Hrs in 132KV SS MBNR |
| 4    |        | Wanaparthy          | Chinnamaroor         | 33KV | Wanaparthy           | 22.20 | 23.20 | 01.00    | E/L              | Due to Heavy Gale & Wind and Jumpers Open at Pabbair                            | Wanaparthy            | No   |
| 5    |        | Gadwal              | Oil Seeds            | 33KV | Gadwal               | 21.30 | 23.55 | 02.25    | E/L              | Insulator Replacment at Veerapur SS   | Gadwal                |  |
| 1    | MDK    | Kandi               | Alkabeer             | 33KV | Sangareddy           | 15.20 | 16.10 | 00.50    |                  | BD DUE TO TREE FALLEN ON LINE AT KOWALAMPET ( V )                               |                       | -  |
| 1    | SDPT   | Shanigaram          | Chelmeda             | 33KV | Husnabad             | 15.58 | 19.30 | 03.32    |                  | Tree branches touched the line, same rectified                                  |                       |  |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown  | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---------------------------|
| 1    | MBNR   | Janampet           | Polkampally          | 11KV | Jadcherla            | 12.00 | 12.55 | 00.55    |                  | 11KV Wire cut near Polkampally  | -                         |
| 2    |        | Balanagar          | Nerallapally         | 11KV | Jadcherla            | 14.05 | 18.45 | 04.40    |                  | 3 Poles Damaged near Nandaram   | -                         |
| 1    | NLG    | Cherkupally        | Cherkupally          | 11KV | Nalgonda             | 13.45 | 15.00 | 01.15    | E/L              | 11KV Line Jumper Cut  | -                         |
| 2    |        | Pamangundia        | Yerrasanigudem       | 11KV | Nalgonda             | 04.00 | 07.00 | 03.00    | E/L              | 11KV Line Insulator failure   | -                         |
| 3    |        | Velmagudem         | Basireddypally       | 11KV | Miryalguda           | 15.00 | 16.45 | 01.45    | E/L              | 11Kv line snapped   | -                         |
| 4    |        | Velmagudem         | Peddagudem           | 11KV | Miryalguda           | 15.10 | 16.45 | 01.35    | E/L              | 11Kv line snapped   | -                         |
| 5    |        | Avanthipuram       | Alagadapa            | 11KV | Miryalguda           | 05.10 | 08.00 | 02.50    | E/L              | 11KV jumper cut   | -                         |
| 6    |        | Buggabaigudem      | Thimmareddygudem     | 11KV | Miryalguda           | 12.29 | 14.10 | 01.41    | E/L              | 11KV jumper cut   | -                         |
| 7    |        | Agamothkur         | Chirumarthi          | 11KV | Miryalguda           | 07.00 | 09.45 | 02.45    | E/L              | 11Kv line snapped   | -                         |
| 8    |        | Pulicherla         | Shankarnaik(T)       | 11KV | Miryalguda           | 16.41 | 17.50 | 01.09    | E/L              | 11Kv line snapped   | -                         |
| 9    |        | Pottichelma        | Ramannagudem         | 11KV | Miryalguda           | 08.00 | 10.00 | 02.00    | E/L              | 11Kv line snapped   | -                         |
| 10   |        | Mukundapuram       | Somaram              | 11KV | Huzurnagar           | 05.00 | 07.30 | 02.30    | E/L              | 11 kv line Snapped  | -                         |
| 11   |        | Mukundapuram       | Mukundapuram         | 11KV | Huzurnagar           | 11.36 | 13.55 | 02.19    | E/L              | 11 KV Jumper cut  | -                         |
| 12   |        | Nandanam           | Anajipur             | 11KV | Bhongir              | 12.20 | 14.30 | 02.10    | EL/OL            | 11kv Line Sanpped & 11kv Pole Damaged near Anajipur Village   | -                         |
| 13   |        | Ramlingampally     | Jalalpur             | 11KV | Bhongir              | 13.15 | 13.50 | 00.35    | EL               | 11Kv Insulator Fail In Jalal Pur Village  | -                         |
| 14   |        | Alair 2            | Alair Agl            | 11KV | Bhongir              | 03.00 | 08.12 | 05.12    | EL               | 11 kv Insulator Fail at SS- 14 & Tree Branchess Fallen at Line Near Alair   | -                         |
| 15   |        | Kolanpaka          | Somaram              | 11KV | Bhongir              | 04.30 | 10.05 | 05.35    | EL/OL            | Phase to phase near Somaram Village Due to Heavy Gale   | -                         |
| 16   |        | Rajapeta           | Narsapuram           | 11KV | Bhongir              | 02.00 | 07.30 | 05.30    | EL               | 11 kv Jumper Open Near Narsapuram Out Side Single Phase ok 3 Phase B/d Due to Heavy Gale                                  | -                         |
| 17   |        | Rajapeta           | Namela               | 11KV | Bhongir              | 05.00 | 11.50 | 06.50    | EL               | Tree Branches Fallen at line near Namela Village Parupally near Jumper Open 3 Phase B/d Single Phase OK.Due to Heavy Gale | -                         |
| 18   |        | Rajapeta           | Renikunta Indl       | 11KV | Bhongir              | 18.50 | 20.35 | 01.45    | EL               | Tree Branches Fallen at Line near BSNL Tower  | -                         |
| 19   |        | Bondugula          | Godumakunta          | 11KV | Bhongir              | 06.00 | 10.45 | 04.45    | EL               | HT/LT & 11KV Pin Insulator Fail near Somaram Village 3 Phase B/d Single Phase OK.Due to Heavy Gale                        | -                         |
| 20   |        | Addagudur          | CH.Ramaram           | 11KV | Bhongir              | 04.30 | 09.10 | 04.40    | EL               | 11 kv Insulator Fail.& SS-6 Jumper Melt. 3 Phase B/d Single Phase OK. Heavy Gale  | -                         |
| 21   |        | Chada              | Chada                | 11KV | Bhongir              | 05.00 | 10.40 | 05.40    | EL/OL            | 11kv Insulator Fail In Chada Village 3 Phase B/d Single Phase OK.   | -                         |
| 22   |        | Choutuppal         | Thangada pally       | 11KV | Choutuppal           | 10.40 | 13.55 | 03.15    | EL/OL            | Tree Branches Fallen at Line near Chinthala Gudem   | -                         |
| 23   |        | Malkapur           | Thuprampet Agl       | 11KV | Choutuppal           | 06.00 | 12.45 | 06.45    | EL               | Due to Heavy Gale 1DTR off Mailaram Road near   | -                         |
| 24   |        | S.Lingotam         | Lingojigudem         | 11KV | Choutuppal           | 07.40 | 10.20 | 02.40    | EL               | No Fault Due to Gale  | -                         |
| 25   |        | Jublakpally        | Jublakpally          | 11KV | Choutuppal           | 05.30 | 07.50 | 02.20    | EL               | Lothugudem Village Out Side AB Switch Open. 3 Phase B/d Single Phase OK.  | -                         |
| 26   |        | Varkatpally        | Varkatpally          | 11KV | Choutuppal           | 05.00 | 10.30 | 05.30    | EL/OL            | 11kv Disc Fail In near Ramalayam Temple Varkatpally Village   | -                         |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown   | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1    | MDK    | EPIP-I             | Chitrakoot           | 11KV | Sangareddy           | 07.30 | 09.40 | 01.20    |                  | B/D Due to Conductor Snapped at Manikanta Mess Pashamailaram | -                         |
| 1    | SDPT   | Husnabad           | Pandilla & Malapally | 11KV | Husnabad             | 00.00 | 16.05 | 16.05    |                  | Pole damage and disc failure, same rectified                 |                           |
| 2    |        | Gandipally         | Ramavaram            | 11KV | Husnabad             | 00.00 | 04.00 | 04.00    |                  | Due to gale and wind   |                           |
| 3    |        | Gouravelly         | Gudatipally          | 11KV | Husnabad             | 18.20 | 18.30 | 00.10    |                  | Due to gale and wind   |                           |
| 4    |        | Bejjanki           | Kallepally           | 11KV | Husnabad             | 17.30 | 19.30 | 02.00    |                  | Insulator failure same rectified                             |                           |
| 5    |        | Bejjanki           | Muthannapet          | 11KV | Husnabad             | 17.45 | 19.25 | 01.40    |                  | 11KV line cutout same rectified                              |                           |
| 6    |        | Thotapally         | Thotapally (R)       | 11KV | Husnabad             | 16.40 | 17.15 | 00.35    |                  | Insulator failure same rectified                             |                           |
| 7    |        | Begumpet           | Begumpet Rural       | 11KV | Husnabad             | 16.15 | 16.45 | 00.30    |                  | Due to gale and wind   |                           |
| 8    |        | Shanigaram         | Shanigaram Rural     | 11KV | Husnabad             | 08.00 | 15.00 | 07.00    |                  | Due to gale and wind   |                           |
| 9    |        | Shanigaram         | Gundareddypally      | 11KV | Husnabad             | 08.20 | 10.10 | 01.50    |                  | Due to gale and wind   |                           |
| 10   |        | Shanigaram         | Thangallapally       | 11KV | Husnabad             | 08.20 | 09.05 | 00.45    |                  | Due to gale and wind   |                           |
| 11   |        | Akunoor            | Rampoor              | 11KV | Husnabad             | 00.00 | 13.15 | 13.15    |                  | Tree branches touched the line same rectified                |                           |
| 12   |        | Gagillapur         | Narsaipally          | 11KV | Husnabad             | 12.00 | 13.20 | 01.20    |                  | Tree branches touched the line same rectified                |                           |
| 1    | HYD N  | Prashasan Nagar    | Andhra Bank          | 11KV | Banjarahills         | 11.21 | 12.53 | 01.32    | EL,OL            | Cable End Kit fault at Road No.3                             | -                         |