

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		9		9		9			
3	MDK	107	933	2		2		2				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	9	2	9	2	9	0	0	
	Grand Total	1082	6468	2	9	2	9	2	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 11.04.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Sadasivapet	Koheer	33KV	Sangareddy	07.40	09.00	01.20		B/D Due to Jumper Cut	Koheer	-
2		Sadasivapet	Vikarabad	33KV	Sangareddy	08.00	09.10	01.10		B/D Due to Jumper Cut	Vikarabad	-

TSSPDCL - LMRC / Corporate office

Date: 11.04.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Addagudur	Kotamarthy	11KV	Bhongir	00.04	07.20	07.16	OL	SS-2 HT/LT Near Chirragudur Village	-
2		Narayanapur	Gudimalkapur	11KV	Choutuppal	13.50	17.45	03.55	OL	HT/LT Gandiraju Poultry Farm, Near Gudimalkapur Village 3 Phase B/d Single Phase Ok	-
3		Juloor	Peddagudem	11KV	Choutuppal	14.30	16.40	02.10	OL	11 kv Line Snapped Near Jangavarigudem Village. 3 Phase B/d Single Phase Ok	-
4		Chilukur	Kondapuram	11KV	Huzurnagar	12.48	13.32	00.44	EL	Due to bird fall on 11kv line	-
5		Garidepally	L B Nagar	11KV	Huzurnagar	04.00	06.00	02.00	EL	Due to tree branch fall on 11kv line	-
6		Reddygudem	Kothagudem	11KV	Suryapet	14.00	15.15	01.15	EL	Insulator failed	-
7		Thurkapally	M.Gouraram	11KV	Nalgonda	14.20	16.00	01.40	EL	HT/LT Line Melting	-
8		Kattangur	Mallaram	11KV	Nalgonda	12.00	16.00	04.00	EL	11KV Line Jumper Cut	-
9		Thoragal	Madaram	11KV	Nalgonda	12.00	11.20	01.20	EL	11KV Line Jumper Cut	-