

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	4	1	4	1	4			
7	RR(E)	168	403		10		10		10			
8	Hyd	194	1044		21		21		21			
	Total	606	3055	1	35	1	35	1	35	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	1	2	1	2	1			
2	NLG	144	988	1	9	1	9	1	9			
3	MDK	107	933	1		1		1				
4	SDPT			1	6	1	6	1	6			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	5	16	5	16	5	16	0	0	
	Grand Total	1082	6468	6	51	6	51	6	51	0	0	

TSSPDCL - LMRC / Corporate office

Date: 12.04.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Raikal	33KV	Shadnagar	21.40	22.05	00.25	E/L&O/L	Due to Heavy Wind AB Switch Opened at Raikal(V)	Raikal	-
2		Shadnagar	Kishannagar	33KV	Shadnagar	21.00	22.00	01.00	E/L&O/L	Due to Heavy Gale & Wind	Kishannagar	-
1	NLG	Dirsincherla	Garidepally	33KV	Huzurnagar	02.00	07.00	05.00	EL	Due to 33KV Jumper Cut	Garidepally	33KV Keethavarigudem from 2:30 132KV Dirsincherla
1	MDK	Bollaram	Agarwal Globle Steel	33KV	Sangareddy	18.30	23.00	04.30		BD Due to Insulator Fail At Near AGL SS	Agarwal Globle Steel	-
2	SDPT	Angadi kistapur	Jagadevpur	33KV	Gajwel	19.09	19.40	00.31		Isolator Blast	Jagadevpur	-
1	RR N	132KV LGM Pet	33KV Aliabad	33KV	Medchal	17.48	19.22	01.34		Spare Cable Fallen on the 33KV Line at Kashavada	33KV Aliabad	-

TSSPDCL - LMRC / Corporate office

Date: 12.04.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Pedda Revally	Thirumalagiri	11KV	Jadcherla	07.40	11.10	03.30		Phase to Phase near Madampally	-
1	NLG	Arlagaddagudem	Suraram	11KV	Nalgonda	03.00	06.50	03.50	EL	11KV Line Insulator Failur	-
2		Kanagal	Lachugudem	11KV	Nalgonda	08.00	12.10	04.10	EL	11KV Line Jumper Cut And AB Switche femail cut.	-
3		Ravulapally	Ravulapally	11KV	Suryapet	05.00	07.20	02.20	EL	HT/LT Line melt	-
4		Kandibanda	N.B.Gudem	11KV	Huzurnagar	07.15	09.55	02.40	EL	Due to 11Kv line snapped	-
5		Karivirala	Karvirala	11KV	Huzurnagar	07.00	10.00	03.00	EL	Due to 11Kv line snapped	-
6		Dirsincherla	Nereducherla T-I	11KV	Huzurnagar	03.00	05.00	02.00	EL	Due to Bird fall on 11Kv line	-
7		Ch.Laxmapur	Madhapur Agl	11KV	Bhongiri	05.00	08.30	03.30	EL	11kv Pin Insulator Failde In Madhapur Village near By crusher machine	-
8		Motakondur	Motakondur	11KV	Bhongiri	04.45	05.15	00.30	EL	Line AB Swich Open near Sikinder Nagar	-
9		Bollepally	Lift Irrigation	11KV	Bhongiri	12.00	12.40	00.40	EL/OL	11kv Line Snapped near Bollepally Village	-
1	SDPT	MUSTHYAL	CHUNCHANAKOTA	11KV	SDPT	12.20	13.20	01.00		BD due to Duck fall	-
2		GURJAKUNTA	GURJAKUNTA AGL	11KV	SDPT	09.00	10.15	01.15		BD due to line fault	-
3		BEKKAL	BEKKAL	11KV	SDPT	19.30	00.00	04.30		Due To Heavy Rain	-
4		REBARTHY	GAGILLAPUR	11KV	SDPT	18.40	00.00	05.20		Due To Heavy Rain	-
5		REBARTHY	REBARTHY AGL	11KV	SDPT	20.10	00.00	03.50		Due To Heavy Rain	-
6		GANDIPALLY	RAMARAM EXP	11KV	SDPT	20.35	00.00	03.25		Due To Heavy Rain	-
1	RR N	Nizampet	Journalist colony	11KV	Kukatpally	12.55	14.18	01.23	EL/OL	11kv Line Cut Near Double Bed Room Construction Nizampet	-
2		Madinaguda	H M T	11KV	Kukatpally	20.02	21.05	01.03	EL	Due To Heavy Rain	-
3		Jeedimetla-I	Thirumala	11KV	Jeedimetla	20.18	21.18	01.00	EL/OL	Due To heavy Rain	-
4		Kandlakoya	KV Reddy Nagar	11KV	Medchal	19.12	20.18	01.06		Tree fallen on the 11KV Line at KV Reddy nagar	-
1	RR E	Sai Nagar	Maruthi Nagar	11KV	Habsiguda	20.05	21.15	01.10		Line patrolling but no visible fault	-
2		Sai Nagar	Devender Nagar	11KV	Habsiguda	20.05	21.15	01.10		Water pipe touched & fallen on 11kv line at Devender Nagar	-
3		Mallapur	Standard Tiles	11KV	Habsiguda	20.05	21.20	01.15		11KV HG Fuse cut & Net Cable touched to HG fuse set shot at Appolo Pharmacy Company Opposite	-
4		Moula-Ali	Meerpet	11KV	Sainikpuri	06.10	06.55	00.45		Coconut Tree branches fallen on 11Kv line at Meerpet Thirumala Nagar (AE/OP)	-
5		Cherlapally-I	Phase-I	11KV	Sainikpuri	19.20	20.15	00.55		Ground petrolling done but no visible fault found due to Heavy Rain & Air	-
6		RGK	Kowkooor	11KV	Sainikpuri	19.50	20.40	00.50		11Kv Polimer Disk failed at Chaithnya School (AE/Yapral)	-
7		Kushaiguda	Sriram Nagar	11KV	Sainikpuri	19.45	22.25	02.40		90% arranged back feeding only 5 No.DTR taken under removed on cable failed (AE/SKP)	-
8		Moula-Ali	Meerpet	11KV	Sainikpuri	20.01	22.45	02.44		Tree fallen on 11Kv line & 11Kv Pin Insulator failed at Thirumal Nagar (AE/Moula-Ali)	-
9		NN Colony	Jammigadda	11KV	Sainikpuri	22.10	23.00	00.50		11Kv Disk failed at Barath Nagar (L.Insp Nageshwar Rao)	-
10		Singapur	RGK	11KV	Keesara	19.15	21.50	02.35		Line patrolling but no visible fault & 11KV Line AB Switch opened at Garam Masala Company	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Zamistanpur	S.P.College	11KV	V	20.30	22.39	02.09	EL,OL-Rph	No Visible Fault (due to rain)	-----
2		Osm. University	RTC Hospital	11KV	V	20.50	22.10	01.20	EL	Cable End Kit failed at RTC Hospital	-----
3		Patigadda	Zeera	11KV	V	20.30	21.40	01.10	EL,OL-Rph	2No. Pin Insulators flash over at Rani Gunj Depot	-----
4		Road No.22	Road No.5	11KV	X	20.18	21.20	01.02	EL,OL-Bph	AB Cable Jumper cut at Road No.10	-----
5		Road No.12	C.R.P.F	11KV	X	20.20	21.35	01.15	EL,OL-Rph	Tree branches fallen on lines at CRPF	Arranged B/F on 11KV Sai Enclave fdr
6		James Street	Chikoti Complex	11KV	V	20.30	22.05	01.35	EL	Disc Insulator flash over at Chikoti Nala	-----
7		Clock Tower	Minerva	11KV	V	20.28	22.15	01.47	EL,OL-Rph	Ad Board fallen on Lines at Palika Bazar	-----
8		K.I.M.S.	Bapu Bagh	11KV	V	21.14	22.49	01.35	EL,OL-Rph	Disc Insulator flash over near Minister Road Nala	-----
9		Seethaphal Mandi	Srinivasa Nagar Colony	11KV	V	20.30	23.35	03.05	EL,OL-Rph	Tree branches fallen on lines at Srinivasa Nagar Colony Nala	Arranged B/F on 11KV S.P.College feeder
10		R.P.Nilayam	Naga Devatha	11KV	C-VI	19.55	21.30	01.35	OL-Rph	No Visible Fault (due to rain)	Arranged B/F on 11KV Officers Coloy fdr
11		Hakimpet	Allenby Lines	11KV	C-VI	20.45	23.10	02.25	OL	Pin Insulator flash over at Military Area	-----
1	HYD S	Malakpet	Chaderghat	11KV	VIII	20.40	00.15	03.35	EL	2No. Pin Insulators flash over at Kamala Nagar & Govt. School	-----
2		C.R.P.F	C-Block	11KV	III	16.48	18.45	01.57	EL,OL	Cable End Kit failed at C-Block, Baba Nagar	-----
1	HYD C	Fever Hospital	Nalla Kunta	11KV	II	20.30	22.00	01.30	EL	Tree branches fallen on lines at Street No.5	-----
2		Fever Hospital	Tourist Hotel	11KV	II	20.30	21.40	01.10	EL	Faulty 2No. DTR's at Tourist Hotel	-----
3		Narayanguda	Preventive Medicine	11KV	II	20.30	22.30	02.00	EL	-----	Arranged B/F on 11KV YMCA & 11KV ROM feeders
4		Bathkammakunta	D.D.Colony	11KV	II	21.45	00.00	02.15	EL	Disc Insulator flash over at D.D.Colony	-----
5		Chilkaiguda	Parsigutta	11KV	II	21.50	00.55	03.05	EL,OL-Bph	Tree branches fallen line at Bapuji Nagar	-----
6		Karwan	Langerhouse OH	11KV	VII	20.45	23.55	03.10	EL	Cable End Kit faile at Mehadi Colony	Partial fdr charged (3Amps) & remaining loads added on 11KV Defence Colony fdr
7		Vittalwadi	Y.M.C.A.	11KV	II	20.12	21.40	01.28	All Indication	No Visible Fault (due to rain)	-----
8		Industrial Area	Azamabad Key SS Cable	11KV	II	23.50	01.00	01.10	EL,OL-Rph	O/G Rph Jumper cut at SS	-----