

## Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle       | No. of Feeders Existing Urban |             | Breakdowns occurred during the day |          | Attended during the day |          | Time taken for restoring the supply |          |                                |          | Remarks (Pending) |
|------|--------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
|      |              | 33KV                          | 11KV        | 33KV                               | 11KV     | 33KV                    | 11KV     | Rectified (Within 24 Hours)         |          | Not Rectified (Above 24 Hours) |          |                   |
|      |              |                               |             |                                    |          |                         |          | 33KV                                | 11KV     | 33KV                           | 11KV     |                   |
| 1    | MBN          | 18                            | 107         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 2    | NLG          | 22                            | 358         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 3    | MDK          | 97                            | 359         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 4    | SDPT         |                               |             |                                    |          |                         |          |                                     |          |                                |          |                   |
| 5    | RR(S)        | 53                            | 234         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 6    | RR(N)        | 54                            | 550         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 7    | RR(E)        | 168                           | 403         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 8    | Hyd          | 194                           | 1044        |                                    | 1        |                         | 1        |                                     | 1        |                                |          |                   |
|      | <b>Total</b> | <b>606</b>                    | <b>3055</b> | <b>0</b>                           | <b>1</b> | <b>0</b>                | <b>1</b> | <b>0</b>                            | <b>1</b> | <b>0</b>                       | <b>0</b> |                   |

Rural

| S.No | Circle             | No. of Feeders Existing Rurals |             | Breakdowns occurred during the day |           | Attended during the day |           | Time taken for restoring the supply |           |                                |          | Remarks (Pending) |
|------|--------------------|--------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
|      |                    | 33KV                           | 11KV        | 33KV                               | 11KV      | 33KV                    | 11KV      | Rectified (Within 24 Hours)         |           | Not Rectified (Above 24 Hours) |          |                   |
|      |                    |                                |             |                                    |           |                         |           | 33KV                                | 11KV      | 33KV                           | 11KV     |                   |
| 1    | MBN                | 107                            | 849         | 5                                  | 3         | 5                       | 3         | 5                                   | 3         |                                |          |                   |
| 2    | NLG                | 144                            | 988         | 1                                  | 22        | 1                       | 22        | 1                                   | 22        |                                |          |                   |
| 3    | MDK                | 107                            | 933         | 1                                  | 2         | 1                       | 2         | 1                                   | 2         |                                |          |                   |
| 4    | SDPT               |                                |             |                                    |           |                         |           |                                     |           |                                |          |                   |
| 5    | RR(S)              | 58                             | 396         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 6    | RR(N)              | 38                             | 114         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 7    | RR(E)              | 22                             | 133         |                                    |           |                         |           |                                     |           |                                |          |                   |
|      | <b>Total</b>       | <b>476</b>                     | <b>3413</b> | <b>7</b>                           | <b>27</b> | <b>7</b>                | <b>27</b> | <b>7</b>                            | <b>27</b> | <b>0</b>                       | <b>0</b> |                   |
|      | <b>Grand Total</b> | <b>1082</b>                    | <b>6468</b> | <b>7</b>                           | <b>28</b> | <b>7</b>                | <b>28</b> | <b>7</b>                            | <b>28</b> | <b>0</b>                       | <b>0</b> |                   |

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown                                 | Sub Stations Effected | Alternate Supply Arranged                                |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|-----------------------|--|
| 1    | MBNR   | Makthal             | Gudeballore          | 33KV | Narayanpet           | 06.25 | 08.25 | 02.00    | O/L              | Tree fallen on the line near Tangadi (V)           | Gudeballore           | No   |
| 2    |        | Marikal             | Gunmukla             | 33KV | Narayanpet           | 07.30 | 07.50 | 00.20    | O/L              | AB Switch Open at Jaklair                          | Gunmukla              | No   |
| 3    |        | Wanaparthy          | Kodair               | 33KV | Wanaparthy           | 07.13 | 07.30 | 00.17    | E/L              | AB Switch open at Teegalapally                     | Kodair                | No   |
| 4    |        | Sri Rangapur        | Scan Energy          | 33KV | Shadnagar            | 11:55 | 13:50 | 1:55     | E/L              | Conductor snapped near Sri Rangapur SS             | Scan Energy           | No   |
| 5    |        | Kothur              | Sangem               | 33KV | Shadnagar            | 19.00 | 03.00 | 08.00    | E/L&O/L          |  | Sangem                | At 03:00 hrs. Alternate supply arranged from 132KV Alwal |
| 1    | NLG    | Mothkur             | Mothkur              | 33KV | Bhongir              | 9:50  | 10:50 | 1:00     | EL               | Tree branchess fallen at line near Mothkur Village | Mothkur               | No   |
| 1    | MDK    | Zaheerabad          | Mannapur             | 33KV | Zaheerabad           | 4:00  | 8:00  | 4:00     |                  | B/D due to Insulator failed                        | Mannapur              | Arranged B/F on 11KV Gowrah & Kummer Basti fdr           |

| S.No | Circle   | Name of 33/11KV SS  | Name of 11 KV Feeder | Vol        | Name of the Division | From  | To    | Duration | Relay Indication  | Cause of Breakdown  | Alternate Supply Arranged |
|------|----------|---------------------|----------------------|------------|----------------------|-------|-------|----------|---|---|---------------------------|
| 1    | MBNR     | Udithyal            | Udithyal             | 11KV       | Jadcherla            | 10.55 | 12.10 | 01.15    |   | HT/LT Near Adavibhavulu Side.                               | No                        |
| 2    |          | Kothamolgara        | Maddigatla           | 11KV       | Jadcherla            | 10.25 | 13.30 | 03.05    |   | 11KV Wire cut & touched by the Crossarm near Maddigatla (V) | No                        |
| 3    |          | Karkonda            | Khanapur             | 11KV       | Jadcherla            | 05.20 | 10.08 | 04.48    |   | 11KV Wire cut near Khanapur (V)                             | No                        |
| 1    | NLG      | Ananthagiri         | Mogalaikota          | 11KV       | Huzurnagar           | 1:00  | 4:05  | 3:05     | E/L   | Tree branch fall on 11Kv line                               | No                        |
| 2    |          | Bheelya Naik thanda | Vardapuram           | 11KV       | Huzurnagar           | 02.30 | 05.30 | 03.00    | E/L   | 11Kv line cut   | No                        |
| 3    |          | Bheelya Naik thanda | Pathathanda          | 11KV       | Huzurnagar           | 04.10 | 07.00 | 02.50    | E/L   | 11Kv line cut   | No                        |
| 4    |          | Thogarrai           | Ganapavaram          | 11KV       | Huzurnagar           | 03.10 | 06.00 | 02.50    | E/L   | Tree branch fall on 11Kv line                               | No                        |
| 5    |          | Kodur               | Loyapally            | 11KV       | Suryapet             | 08.00 | 10.20 | 02.20    | EL/OL   | 11Kv Insulator failed                                       | No                        |
| 6    |          | Narketpally         | M.Yadavally          | 11KV       | Nalgonda             | 06.00 | 11.00 | 05.00    | E/L   | 11KV Line Cut   | No                        |
| 7    |          | Akkenapally         | Akkenapally          | 11KV       | Nalgonda             | 05.00 | 08.00 | 03.00    | E/L   | 11KV Line Cut .   | No                        |
| 8    |          | Koppole(K)          | Koppole              | 11KV       | Nalgonda             | 04.00 | 06.00 | 02.00    | E/L   | Movment Fault   | No                        |
| 9    |          | Eduloor             | Munukuntla           | 11KV       | Nalgonda             | 04.30 | 06.30 | 02.00    | E/L   | SS-2, Jumper Cut  | No                        |
| 10   |          | Chityala            | Chityala Town        | 11KV       | Nalgonda             | 01.10 | 03.00 | 01.50    | E/L   | 11KV Line Cut   | No                        |
| 11   |          | Gudapur             | Singaram             | 11KV       | Nalgonda             | 07.00 | 11.20 | 04.20    | E/L   | 11KV Line Ab Switch Fimail Cut And Lt Line Melting          | No                        |
| 12   |          | Chandur             | Gundrapally          | 11KV       | Nalgonda             | 05.20 | 07.00 | 01.40    | E/L   | Tree Span On The Line                                       | No                        |
| 13   |          | Pamangundla         | yarrasanigudem       | 11KV       | Nalgonda             | 06.00 | 10.00 | 04.00    | E/L   | Big Tree Fallen On The Line                                 | No                        |
| 14   |          | Akaram              | Vaddipamula          | 11KV       | Nalgonda             | 11.00 | 12.40 | 01.40    | E/L   | 11KV Line Cut   | No                        |
| 15   |          | IDA                 | Bommaipally          | 11KV       | Bhongir              | 10.35 | 11.04 | 00.29    | OL  | 11kv Line Snapped Near Thukkapur Road                       | No                        |
| 16   | MT.Pally | MT.Pally Agl        | 11KV                 | Bhongir    | 06.30                | 10.30 | 04.00 | OL       | 11kv Insulator Failed Near Manthrollammamla Village,3 Phase B/d Single Phase OK, Heavy Gale | No  |                           |
| 17   | Rajapeta | Rajapeta Agl        | 11KV                 | Bhongir    | 06.45                | 08.15 | 01.30 | OL       | 11 kv Line Snapped Near Rajapet Village   | No  |                           |
| 18   | Paladugu | Datthappagudem      | 11KV                 | Bhongir    | 04.40                | 10.30 | 05.50 | OL       | 11 kv Insulator Failed Near Kammagudem Village  | No  |                           |
| 19   | Paladugu | Paladugu Indl       | 11KV                 | Bhongir    | 09.45                | 12.50 | 03.05 | OL       | 11 kv Insulator Failed at Rice mill Near Raghavapur Village                                 | No  |                           |
| 20   | Pallerla | Siddapurm           | 11KV                 | Bhongir    | 05.50                | 07.00 | 01.10 | EL       | Bird Fallen at Line Near Siddapuram Village   | No  |                           |
| 21   | Panhangi | Panhangi Agl        | 11KV                 | Choutuppal | 04.20                | 09.16 | 04.54 | OL       | 11 kv Jumper Snapped Near Areygudem Village.Due to Heavy Gale                               | No  |                           |
| 22   | Juloor   | Pilaipally          | 11KV                 | Choutuppal | 22:25                | 1:55  | 3:20  | OL       | 2 DTR's Copper Patti Cut at Pakkir Prabhaker reddy Well Near Pilaipally Village             | No  |                           |
| 1    | MDK      | Gummadidala         | Bell Remedies        | 11KV       | Patancheru           | 10:08 | 10:40 | 0:32     |   | B/D due to Insulator fail                                   | No                        |
| 2    |          | Anrich Bollaram     | Town- II             | 11KV       | Patancheru           | 13.03 | 13.36 | 00.33    |   | B/D due to Jumper cut                                       | No                        |
| 1    | HYD N    | Madhapur            | Vaishnavi Residence  | 11KV       | Jublee Hills         | 20.10 | 21.15 | 01.05    | EL,OL   | HG fuse burnt out at Awasa Hotel                            | No                        |