

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988	1	8	1	8	1	8			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	8	3	8	3	8	0	0	
	Grand Total	1082	6468	3	8	3	8	3	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.04.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kothur	Sangem	33KV	Shadnagar	19.00 (13.04.19)	11.05 (14.04.19)	16.05	E/L&O/L	Company Problem	Sangem	Alternate Supply Arranged Nactco chemical from 11:05HRs
2		Amarchintha	Amarchintha	33KV	Wanaparthi	08.40	09.43	01.03	E/L&O./L	No Visible Fault	Amarchintha	-
1	NLG	Suryapet	Nemmikal	33KV	Suryapet	05.00	07.30	02.30	EL	Insulator failed		-

TSSPDCL - LMRC / Corporate office

Date: 14.04.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Madugulapally	Kukkadam	11KV	Nalgonda	12.50	15.50	05.00	E/L	11KV Line Disc Failure	-
2		Mamidala	Mamidala	11KV	Nalgonda	12.40	16.30	03.00	E/L	11KV Line Cut .	-
3		Eduloor	Parada	11KV	Nalgonda	06.00	10.30	02.00	E/L	SS-47 Jumper Cutting	-
4		Kasarabadha	Kesaram	11KV	Suryapet	11.30	13.30	02.20	EL	Disk failed	-
5		MR.Gudem	Gangasanipally	11KV	Bhongir	04.35	09.30	04.55	EL	11Kv Gangasanpally Breker B phase Problem Tag On to LV1	-
6		Golankonda	Golankonda	11KV	Bhongir	09.35	11.30	01.55	EL/OL	11kv Line Snapped near Golankonda Village	-
7		Golankonda	Vanchagudem	11KV	Bhongir	09.50	10.35	01.40	EL	11kv Line Snapped near Ammanabolu village	-
8		Jublakpally	Jublakpally	11KV	Choutuppal	06.20	10.35	04.15	EL	25kva DTR Failed Near Ananthamma Gudem Village	-