

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	2	8	2	8	2	8			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>3</b>	<b>9</b>	<b>3</b>	<b>9</b>	<b>3</b>	<b>9</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>3</b>	<b>11</b>	<b>3</b>	<b>11</b>	<b>3</b>	<b>11</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 16.04.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Kodad	Siripuram	33KV	Huzarnagar	05.00	09.00	04.00	EL/OL	Due to 33kv line snapped	Kodad	No
2		Dirsincherla	Mukundhapuram	33KV	Huzarnagar	07.30	10.30	03.00	EL	Due to Tree branch fall on 33kv line	Dirsincherla	No
1	MDK	Gummadidala	AFA	33KV	Patancheru	15.32	16.50	01.18		BD due to Conductor snapped		-

TSSPDCL - LMRC / Corporate office

Date: 16.04.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Akupamula	Lift	11KV	Huzurnagar	04.40	06.30	01.50	EL/OL	Due tree branch fall on 11kv line	-
2		Chilukur	Kondapuram	11KV	Huzurnagar	05.15	08.00	02.45	EL	Due 11kv jumper cutted	-
3		Chanupally	Chanupally	11KV	Huzurnagar	03.00	06.00	03.00	EL	Due 11kv line snapped	-
4		Munagala	Kokkireni-II	11KV	Huzurnagar	07.00	10.00	03.00	EL	Due 11kv line snapped	-
5		Tekumatla	Raingudem	11KV	Suryapet	09.50	11.45	01.55	E/L	Conductor snapped	-
6		Paladugu	Duppelly	11KV	Bhongir	09.10	11.10	02.00	EL	11kv Jumper Cut In Duppelly Village Single Phase B/d	-
7		Pamkunta	Jala	11KV	Bhongir	13.30	15.30	02.00	EL/OL	HT/LT near Ram reddy Well Jala Village	-
8		S.Lingotam	S.Lingotam Agl	11KV	Choutuppal	06.00	09.00	03.00	EL	11kv Line Snapped near Lingoigudem Village Single Phase B/d	-
1	MDK	Gaddapotharam - I	Astrix	11KV	Patancheru	02.50	06.15	03.25		BD due to Jumper cut	-
1	RR N	Bowrampet	Junnrum	11KV	Jeedimetla	13.23	14.26	01.03	EL	11kv HT Cable Failre at Bachupally Road	-
1	HYD S	Falaknuma	Falaknuma OH	11KV	Charminar	05.05	06.20	01.15	EL	I/C Cable fault at SS	Arranged B/F on 11KV Jangammet AB Cable fdr