

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988	3	13	3	13	3	13			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT				14		14		14			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	6	28	6	28	6	28	0	0	
	Grand Total	1082	6468	6	31	6	31	6	31	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.04.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Gadwal	Nandinne	33KV	Gadwal	13.03	15.10	02.07	O/L	33KV Line Phase to Phase near 132KV SS Gadwal	Gadwal	No
2		Alampur	Undavelly	33KV	Gadwal	15.40	17.40	02.00	E/L&O/L	line Petroling No visible fault supply stude ok	Alampur	No
1	NLG	Haliya	Peddavoorra	33KV	Miryalguda	01.52	02.33	00.41	E/L	Lorry hitting the 9.1MTr PSCC poles near Peddavoorra	Haliya	No
2		Kanagal	G.Yedavelly	33KV	Nalgonda	06.10	12.45	06.35	E/L	33KV Line Melting	Kanagal	No
3		Kanagal	Pagidimarry	33KV	Nalgonda	08.07	14.00	05.53	E/L	33KV Line Melting	Kanagal	No
1	MDK	Zaheerabad	Machanoor	33KV	Zaheerabad	15.55	17.05	01.10		BD due to Jumper snapped	Zaheerabad	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	B Chandupatla	Thimmapuram	11KV	Suryapet	05.30	07.40	02.10	E/L	11Kv Insulator failed	-
2		Dirincherla	Dirincherla	11KV	Huzurnagar	10.30	12.00	01.30	E/L	11Kv Jumper Cut	-
3		Dirincherla	Somaram	11KV	Huzurnagar	05.30	08.30	03.00	E/L	11Kv Line Snapped	-
4		Dirincherla	Chellapally	11KV	Huzurnagar	05.30	08.00	02.30	E/L	11Kv Line Snapped	-
5		Keethavarigudem	Velidanda	11KV	Huzurnagar	05.00	07.30	02.30	E/L	Control AB Switch open	-
6		Huzurnagar	Singaram	11KV	Huzurnagar	07.20	10.00	02.40	E/L	11Kv Line Snapped	-
7		Cherkupally	Bandapalem	11KV	Nalgonda	14.30	17.30	05.00	E/L	11KV Line Cut .	-
8		Narketpally	M.Yedavelly	11KV	Nalgonda	17.00	18.00	03.00	E/L	HT/LT Melting	-
9		Arlagaddagudem	Thatikal	11KV	Nalgonda	08.00	10.20	02.00	E/L	11KV Line Jumper Cut	-
10		SLBC	Dorepally	11KV	Nalgonda	16.40	17.50	02.00	E/L	11KV Line Jumper Cut	-
11		Pamkunta	Jala	11KV	Bhongir	15.00	19.00	04.00	E/L	11kv Jumper Cut In Jala Village Single Phase ok 3phase B/d Due to Heavy Gale & Wind	-
12		Datherpally	Mallapur	11KV	Bhongir	15.15	17.45	02.30	EL/OL	11kv Pin Insulator Failed Near Mallapur Village	-
13		BP.Pally	Narayanagiri	11KV	Choutuppal	07.30	09.50	02.20	E/L	11kv Line Snapped at Narayangiri Village Due to Heavy Gale & Wind	-
1	MDK	Kistareddypet	Industrial	11KV	Patancheru	06.10	06.50	00.40		BD due to Jumper cut	-
1	SDPT	Baswapur	Poredupally	11KV	Husnabad	14.25	17.30	03.05		BD,Poles broken	-
2		Bejjanki	Cotton Mill	11KV	Husnabad	15.30	19.00	03.30		BD(3Ph),1 Ph ok,Insulator failure	-
3		Bejjanki	Muthannapet	11KV	Husnabad	15.30	19.00	03.30		BD(3Ph),1 Ph ok,Insulator failure	-
4		Guruvannapet	Posanpally	11KV	Husnabad	14.00	14.20	00.20		BD,Due to rain	-
5		Aknoor	Aknoor Agl	11KV	Husnabad	13.40	15.20	01.40		BD,Tree fallen on line	-
6		Cherial Town	Cherial-Town	11KV	Husnabad	15.50	16.05	00.15		BD,Jumper cut	-
7		Cherial Town	Rollabanda Agl	11KV	Husnabad	14.35	19.50	05.15		BD,Conductor snapped	-
8		Gouravelly	Gubbadi Jangam	11KV	Husnabad	14.45	16.05	01.20		BD,Jumper cut	-
9		Katkur	Mallaram	11KV	Husnabad	16.00	17.00	01.00		BD,Jumper cut	-
10		Pandilla	Kunchanpally	11KV	Husnabad	15.18	18.40	03.22		BD,Conductor snapped&Insulator failed	-
11		Pandilla	Pandilla Rural	11KV	Husnabad	16.20	23.50	07.30		BD,Conductor snapped	-
12		Koheda	Venkateshwarapally	11KV	Husnabad	15.13	19.07	03.54		BD,Poles broken&Tree fallen on line	-
13		Gagillapur	Narsaipally	11KV	Husnabad	18.45	20.10	01.25		BD,Conductor snapped	-
14		Guggilla	Gagillapur	11KV	Husnabad	15.00	23.30	08.30		1 Ph ok,3 Ph BD	-
1	HYD S	Ch' Baradari	I.T.I.Colony	11KV	Charminar	06.28	08.54	02.26	OL-Bph	HT Line snapped at Opp. Fire Station, Flash over Pin Insulator & twisted lines at Old Office	-
2		Khilwath	Charminar	11KV	Charminar	17.50	19.20	01.30	EL,OL	Cable fault at Khilwath to Shalibanda new Road	Arranged B/F on (18:39 Hrs partal loads on 11KV Chowk & 11KV Pancha Mohalla feeder (no supply to 2no DTR)
1	HYD C	Toli Chowki	Paramount Hills	11KV	Mehdipatanam	13.10	14.18	01.08	EL,OL-Rph	Cable fault at Paramount Hills Gate No.1	Arranged B/F on 11KV Hakimsha & BSNL fdrs