

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		16		16		16			
7	RR(E)	168	403		20		20		20			
8	Hyd	194	1044		122		122		122			
	Total	606	3055	0	158	0	158	0	158	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	3							
2	NLG	144	988	4	78							
3	MDK	107	933	1	14							
4	SDPT			4	30	4	30	0	16	4	14	4 No.s 33kv & 14 No.s 11kv still
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	10	125	4	30	0	16	4	14	
	Grand Total	1082	6468	10	283	4	188	0	174	4	14	

TSSPDCL - LMRC / Corporate office

Date: 19.04.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Alwal	Ippalapally	33kv	SDNR	20.40	22.48	02.08	EL	2no insulator failed and replaced	Ippalapally	-
1	NLG	Dirincherla	Mukundapuram	33kv	Huzurnagar	17.00	20.20	03.30	EL/OL	Tree Branch fallen 33 kv line snapped	Mukundapuram	-
2		Munagala	Bethavolu	33kv	Huzurnagar	18.50	19.50	01.00	EL/OL	Tree Branch fallen 33 kv line snapped	Bethavolu	-
3		Mutyalanagar	Burugadda	33kv	Huzurnagar	17.30	20.30	03.00	EL/OL	Tree Branch fallen 33 kv line snapped	Burugadda	-
4		Gudapur	Chikatimamidi	33kv	Nalgonda	19.50	07.50	12.00	EL/OL	33 KV Insulator failure	Chikatimamidi	-
1	MDK	Kandhi	HFC II	33kv	Sangareddy	01.50	04.00	02.10		BD due to Tree fallen on line	HFC II	-
1	SDPT	GAJWEL	Gowraram	33kv	GAJWEL	17.30	00.00	06.30		Break down due to metal sheets fallen on line	Gowraram	Tunki Bollaram - Markook 18.00 Hrs.
2		Shanigaram	Koheda	33kv	SDPT	06.30	00.00	17.30		BD,LC(Not returned)	Koheda	-
3		Husnabad	Thotapally	33kv	SDPT	06.30	00.00	17.30		BD,LC(Not returned)	Thotapally	-
4		Husnabad	Koheda	33kv	SDPT	18.20	00.00	05.40		BD(Poles broken)	Koheda	-

TSSPDCL - LMRC / Corporate office

Date: 19.04.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Annasagar	Town	11kv	Jadcherla	08.50	11.00	02.10		Ab Switch Problem At Annasagar(V)	-
2		Badepally	Burgupally	11kv	Jadcherla	10.32	14.35	04.03		11Kv Jumper Cut Touched By The Cross Arm Near Aloor (V)	-
3		Peddarevelly	Chinnarevelly	11kv	Jadcherla	10.52	12.10	01.18		11Kv jumper Cut Touched By The Cross Arm Near Pochammagadda Tanda	-
1		Dirincherla	Somaram	11kv	Huzurnagar	05.00	08.30	03.30	E/L	Pole Damages	-
2		Dirincherla	Dirincherla	11kv	Huzurnagar	06.00	09.00	03.00	E/L	Pole Damages	
3		Janpahad	Janpahad	11kv	Huzurnagar	05.00	08.30	03.30	E/L	11Kv Conductor snapped	
4		Kalmalcheruvu	Kalmalcheruvu	11kv	Huzurnagar	03.00	06.30	03.30	E/L	11Kv Conductor snapped	
5		Akupamula	Akupamula indl	11kv	Huzurnagar	07.00	09.30	02.30	E/L	11 KV Jumper cut	
6		B.Chandupatla	Vatti kam pahad	11kv	Suryapet	06.00	08.30	02.30	E/L	11Kv Conductor snapped	
7		Bopparam	Bopparam	11kv	Suryapet	05.30	07.40	02.10	E/L	11Kv Insulator flashover	
8		Dirsenapally	Alugunuru	11kv	Suryapet	05.00	08.00	03.00	E/L	11Kv Disk flashover	
9		Biravunibanda	M.G.Kothapally	11kv	Nalgonda	22.00	10.50	12.50	E/L	11 KV Line Jumper Cut and Insulator failed	
10		Chityala	Yelikatte	11kv	Nalgonda	21.00	07.30	10.30	E/L	HT/LT Line Cut	
11		Edulur	Parada	11kv	Nalgonda	23.00	09.30	10.30	E/L	SS.3 Jumper cutting	
12		Gudapoor	Sanabanda	11kv	Nalgonda	01.50	12.30	10.40	E/L	Tree fallen on the line	
13		Gudapoor	Singaram	11kv	Nalgonda	02.00	10.00	08.00	E/L	11 KV Disc Failure	
14		Anneparthy	Anneparthi AGL	11kv	Nalgonda	07.00	09.30	02.30	E/L	Jumper cut	
15		Kanagal	parvathagiri	11kv	Nalgonda	17.00	11.00	18.00	E/L	11 KV Line Jumper Cut and Insulator failed	
16		Kanagal	Kanagal AGL	11kv	Nalgonda	17.00	08.30	15.30	E/L	Tree fallen on the line	
17		Koppole(K)	Beemavaram	11kv	Nalgonda	21.00	07.30	10.30	E/L	HT/LT Line Cut	
18		Marror	Mangalapally	11kv	Nalgonda	06.00	09.40	03.40	E/L	Jumper cut	
19		Marror	Marror	11kv	Nalgonda	05.30	10.20	04.50	E/L	11 KV Insulator Failed	
20		Narkatpally IE	Goplaipally	11kv	Nalgonda	06.00	08.00	02.00	E/L	Insulator failed	
21		Narsingbatla	Gadibaigudam	11kv	Nalgonda	17.20	07.30	14.10	E/L	HT/LT Line Cut	
22		Narsingbatla	Chennugudem	11kv	Nalgonda	17.20	08.00	14.40	E/L	HT/LT Line Milting	
23		Narsingbatla	Kuturgudem	11kv	Nalgonda	17.20	11.05	17.45	E/L	Insulator failed	
24		Palem	Palem	11kv	Nalgonda	23.50	11.10	11.20	E/L	Insulator failed	
25		Palem	Bopparam	11kv	Nalgonda	12.30	10.30	22.00	E/L	Tree fallen on the line	
26		Palem	Ogodu	11kv	Nalgonda	06.15	14.30	08.15	E/L	Tree fallen on the line	
27		Pamangundla	Yerrasanigudem	11kv	Nalgonda	06.00	09.00	03.00	E/L	HT/LT Line Milting	
28		Pamangundla	Ismailpally	11kv	Nalgonda	06.00	10.45	04.45	E/L	Insulator failed	
29		Pullemla	Pullemla (AGL)	11kv	Nalgonda	02.30	07.30	05.00	E/L	HT/LT Line Milting	
30		Rayaniguda	A.D.Pally	11kv	Nalgonda	22.55	09.40	10.45	E/L	Tree fallen on the line	
31		Rayaniguda	Korriganigudem	11kv	Nalgonda	07.00	09.45	02.45	E/L	HT/LT Line Milting	
32		Sh.Gowraram	Sh.Gowraram (AGL)	11kv	Nalgonda	06.00	09.40	03.40	E/L	Jumper cut	
33		Sh.Gowraram	Ambaripeta	11kv	Nalgonda	07.00	10.40	03.40	E/L	11 KV line disck fail	
34		Sh.Gowraram	Gurajala	11kv	Nalgonda	07.00	15.00	08.00	E/L	HT/LT Line Milting tree branches on the line	
35		Thimmannagudem	Chenaram	11kv	Nalgonda	17.30	09.00	15.30	E/L	Heavy gail and wind tree branches on the lines	
36		Thipparthi	Sarvaram	11kv	Nalgonda	04.55	10.30	05.35	E/L	HT/LT line cut	
37		Thoragal	Thangalavari gudam	11kv	Nalgonda	12.30	08.00	19.30	E/L	Jumper cut	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
38	NLG	Thoragal	Gajanai gudam	11kv	Nalgonda	12.40	07.50	19.10	E/L	Tree branches on the line	
39		Urumadla	Yelikatte 2	11kv	Nalgonda	04.50	07.00	02.10	E/L	11 KV line cut	
40		Gundrampally	Gundrampally	11kv	Nalgonda	05.30	08.50	03.20	E/L	Disk failure	
41		Velugupally	A.R.Guda	11kv	Nalgonda	18.40	11.25	16.45	E/L	HT/LT line cutting	
42		Velugupally	Rasoolpuram	11kv	Nalgonda	18.00	09.00	15.00	E/L	Insulator failed	
43		Wangamarthy	Madharam	11kv	Nalgonda	06.00	10.50	04.50	E/L	HT/LT line milting	
44		Kethepally	Kasanagode	11kv	Nalgonda	06.00	07.30	01.30	E/L	Jumper cut	
45		Aitipamula	R.C.puram	11kv	Nalgonda	07.30	12.30	05.00	E/L	11 KV line disck fail	
46		Aitipamula	Gangadevigudem	11kv	Nalgonda	07.30	09.30	02.00	E/L	HT LT line milting	
47		Avanthipuram	Alagadapa	11kv	Miryalguda	07.20	08.42	01.22	E/L	11KV jumper cut	
48		Avanthipuram	Industrial	11kv	Miryalguda	07.00	09.00	02.00	E/L	Conductor snapped	
49		B. Annaram	Annaram	11kv	Miryalguda	02.00	09.00	07.00	E/L	11KV jumper cut	
50		Damarcherla	Narsapuram	11kv	Miryalguda	09.10	11.05	01.55	E/L	Conductor snapped	
51		Damarcherla	Wadapally	11kv	Miryalguda	11.10	14.00	02.50	E/L	11KV jumper cut	
52		Rajavaram	Tirumalagiri	11kv	Miryalguda	10.00	12.05	02.05	E/L	11KV jumper cut	
53		Muppam	Guntkagudem	11kv	Miryalguda	10.00	11.00	01.00	E/L	11KV jumper cut	
54		Neelaigudem	Neelaigudem	11kv	Miryalguda	07.30	09.00	01.30	E/L	Conductor snapped	
55		Nunavath (T)	Keshavapuram	11kv	Miryalguda	09.00	12.00	03.00	E/L	11KV jumper cut	
56		A.D.Pally	Ulsaipalem	11kv	Miryalguda	08.30	11.40	03.10	E/L	11KV jumper cut	
57		MR.Gudem	MR.Gudem Indl	11kv	Bhongir	00.00	09.12	09.12	EL/OL	11kv Line Snapped Near MR.Gudem Village	
58		MR.Gudem	Baswapur	11kv	Bhongir	05.00	08.30	03.30	EL/OL	SS-1 Jumper Open Baswapur Village	
59		Nandanam	Teliphone Exchange	11kv	Bhongir	18.50	20.10	01.20	EL/OL	11kv Line Snapped near BSNL Tower Nagireddy Pally Village	
60		Bollepally	Jampally	11kv	Bhongir	06.00	10.00	04.00	EL/OL	1kv Line Snapped & solid Core Failed near Bhuchamma Well near Jampally Village	
61		MT.Pally	Dharmaram	11kv	Bhongir	17.00	20.20	03.20	EL/OL	3no's 11kv Poles Damaged In Dharmaram Village 15DTR's off near Dharmaram Village	
62		MT.Pally	Vaslamarri	11kv	Bhongir	17.00	19.00	02.00	EL/OL	11kv Line Snapped near Srinivasapuarm Village	
63		Venkiryala	Venkiryala Indl	11kv	Bhongir	18.20	18.44	00.24	EL/OL	11kv Insulator Failed near Rudravelly Village	
64		Maryala	Wadaparthi	11kv	Bhongir	23.00	10.45	11.45	EL/OL	11kv Line Snapped Dayanandam Well Maryala Village 3 Phaase B/d Single Phase ok	
65		Sharajipet	Kolluru	11kv	Bhongir	05.00	07.00	02.00	EL/OL	11kv Disc Failed Kolluru Village 3 Phaase B/d Single Phase ok	
66		Azeempet	Azeempet	11kv	Bhongir	21.15	13.14	15.59	EL/OL	11kv 2no's poles Dammages near Azempet Village	
67		Addagudur	Addagudur AGL	11kv	Bhongir	21.20	11.40	14.20	EL/OL	11kv Insulator Failed In AddaGudur Village	
68		Addagudur	Addagudur Indl	11kv	Bhongir	21.20	11.40	14.20	EL/OL	11kv Insulator Failed In AddaGudur Village	
69		Manaikunta	Manaikunta	11kv	Bhongir	17.45	17.20	23.35	EL/OL	1 No's 11kv Pole Damedged & Rectified singile Phase Ok 3Phase B/d	
70		Manaikunta	Veldevi	11kv	Bhongir	17.45	17.20	23.35	EL/OL	2 No's 11kv Pole Damedged & Rectified singile Phase Ok 3Phase B/d	
71		Manaikunta	Gattusingaram	11kv	Bhongir	17.45	17.20	23.35	EL/OL	2 No's 11kv Pole Damedged & Rectified singile Phase Ok 3Phase B/d	
72	Athmakur	Thukkapur	11kv	Bhongir	20.20	10.40	14.20	EL/OL	11kv Insulator Failed In Thukkapur Village		
73	Chada	Chada Indl	11kv	Bhongir	19.20	07.00	11.40	EL/OL	1 pole Dammaged Rice mill jumper open		

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
74		Juloor	Kapraipally	11kv	Choutuppal	15.10	17.40	02.30	EL/OL	11 kv Insulators 2 no's Failed & 11 kv Line Snapped near Kapraipally Village. Heavy Gale & Rain	
75		Juloor	Peddagudem	11kv	Choutuppal	04.10	09.40	05.30	EL/OL	11kv Insulator Failed near Peddagudem Village	
76		Juloor	Pilaipally	11kv	Choutuppal	06.20	08.08	01.48	EL/OL	11kv Insulator Failed near Pilaipally Village	
77		Panthangi	Panthangi agl	11kv	Choutuppal	02.45	12.05	09.20	EL/OL	2 no's 11kv Disc Failed 3 Phaase B/d Single Phase ok	
78		Laxmapuram	Thummalagudem	11kv	Choutuppal	17.30	09.45	16.15	EL/OL	11kv Insulator Failed 3 Phaase B/d Single Phase ok	
1	MDK	Isnapur	Patodia	11kv	Sangareddy	01.32	02.25	00.53		BD due to Insulator failed	-
2		Sangareddy Rural	Pothireddypally	11kv	Sangareddy	01.40	04.25	02.45		BD due to After petroling no fault at found	-
3		Anrich Bollaram	Mallampet	11kv	Patancheru	02.33	03.41	01.08		BD due to After petroling no fault at found	
4		Ismaikhhanpet	Ismaikhhanpet	11kv	Sangareddy	04.22	05.21	00.59		BD due to Insulator failed	
5		Kistareddypet	Bheeramguda	11kv	Patancheru	03.15	04.30	01.15		BD due to Phase to Phase	
6		Kistareddypet	Industrial	11kv	Patancheru	17.30	18.30	01.00		BD due to Conductor snapped	
7		SOL	Markwell	11kv	Patancheru	17.50	19.40	01.50		BD due to Conductor snapped	
8		Bollaram - I	Sulaxshana-I	11kv	Patancheru	17.15	18.15	01.00		BD due to Dish cable fallen on line	
9		Bollaram - II	Shalini	11kv	Patancheru	02.20	04.10	01.50		BD due to Conductor snapped	
10		Bollaram - II	Rupa	11kv	Patancheru	02.20	04.40	02.20		BD due to Jumper cut	
11		Bonthapally	Veerabadra	11kv	Patancheru	18.46	19.52	01.06		BD due to Conductor snapped	
12		Patancheru Town	MIA I	11kv	Patancheru	01.50	05.40	03.50		BD due to Conductor snapped	
13		Patancheru Town	Town	11kv	Patancheru	02.40	05.10	02.30		BD due to Tree braches fallen on line	
14		Pati	My Home	11kv	Patancheru	03.06	05.40	02.34		BD due to Tree braches fallen on line	
1	SDPT	Bejjanki	Kallepally	11kv	Husnabad	17.35	20.30	02.55		BD, Due to heavy gale & wind	-
2		Bejjanki	Muthannapet	11kv	Husnabad	00.00	07.45	07.45		BD, Conductor snapped	
3		Bejjanki	Regulapally	11kv	Husnabad	19.20	00.00	04.40		3 Ph BD, 1 Ph ok	
4		Guruvannapet	Posanpally	11kv	Husnabad	09.30	11.15	01.45		3 Ph BD, 1 Ph ok	
5		Guruvannapet	Tapaspally	11kv	Husnabad	09.00	14.35	05.35		3 Ph BD, 1 Ph ok	
6		Nagapuri	Nagapuri	11kv	Husnabad	08.40	09.05	00.25		BD, Jumper cut	
7		Nagapuri	Pothireddypalli	11kv	Husnabad	08.10	10.04	01.54		BD, Conductor snapped	
8		Akkannapet	Akkannapet Rural	11kv	Husnabad	22.00	00.00	02.00		BD, Conductor snapped	
9		Akkannapet	Akkannapet Town	11kv	Husnabad	21.45	22.10	00.25		BD, Conductor snapped	
10		Akkannapet	Pakilnayak Thanda	11kv	Husnabad	22.00	00.00	02.00		3 Ph BD, 1 Ph ok, Poles broken	
11		Gouravelly	Gubbadi Jangam	11kv	Husnabad	00.00	06.30	06.30		BD, Due to heavy gale & wind	
12		Katkur	Katkur Rural	11kv	Husnabad	18.00	00.00	06.00		BD, Conductor snapped	
13		Katkur	Mallaram	11kv	Husnabad	18.00	00.00	06.00		BD, Conductor snapped	
14		Thotapally	Anthakkapet	11kv	Husnabad	17.30	18.30	01.00		BD, Conductor snapped	
15		Thotapally	Mallampally	11kv	Husnabad	18.30	00.00	05.30		3 Ph BD, 1 Ph ok	
16		Thotapally	Thotapally	11kv	Husnabad	17.30	18.30	01.00		BD, Conductor snapped	
17		Dharmaram	All feeders	11kv	Husnabad	00.00	18.34	18.34		ISF, Due to 33KV break down	
18		Dharmaram	Nandaram	11kv	Husnabad	18.34	00.00	05.26		3 Ph BD, 1 Ph ok	
19		Gandipally	Gandipally	11kv	Husnabad	15.30	15.45	00.15		BD, Pin Insulator failure	
20		Gouravelly	Gouravelly Rural	11kv	Husnabad	21.35	00.00	02.25		3 Ph BD, 1 Ph ok	
21		Gouravelly	Gudatipally	11kv	Husnabad	21.40	00.00	02.20		BD, Due to heavy gale & wind	
22		Pandilla	All feeders	11kv	Husnabad	00.00	00.00	00.00		ISF, Due to 33KV break down	
23		Husnabad	Malapally	11kv	Husnabad	00.00	09.30	09.30		BD, Poles broken	
24		Husnabad	Pandilla	11kv	Husnabad	00.00	00.00	00.00		BD, Poles broken	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
25		Ramchandrapur	Ramchandrapur Rural	11kv	Husnabad	17.50	00.00	06.10		3 Ph BD, 1 Ph ok	
26		Ramchandrapur	Varikolu	11kv	Husnabad	17.50	00.00	06.10		3 Ph BD, 1 Ph ok	
27		Ramchandrapur	Vinjalpally	11kv	Husnabad	18.55	19.22	00.27		BD	
28		Bekkal	Bairanpally	11kv	Husnabad	07.00	09.55	02.55		BD, Due to heavy gale & wind	-
29		Begumpet	Begumpet Rural	11kv	Husnabad	18.25	00.00	05.35		3 Ph BD, 1 Ph ok	-
30		Thotapally	Devakkapally	11kv	Husnabad	00.00	08.05	08.05		BD, Pin Insulator failure	-
1	RR N	UMCC	Gajularamaram	11KV	Medchal	02.10	03.15	01.05		11KV 2Nos Pin Insulator failed at Sriveni Enclave	-
2		UMCC	Mahadevpuram	11KV	Medchal	02.40	03.45	01.05		100KVA DTR Brass patti cut & replacement at Mahadevpuram	
3		Jagathgiringutta	IDA Jagathgiringutta	11KV	Medchal	02.30	03.15	00.45		11KV Pin Insulator failed at Swathi School Devamma Basti	
4		HMT	Manikya Nagar	11KV	Medchal	03.35	05.20	01.45		No Fault	
5		HMT	Quthbullapur	11KV	Medchal	02.40	05.10	02.30		11KV Cable touched the 11KV Line at Rayal Wines	
6		Petbasheerabad	Satyam Enclave	11KV	Medchal	03.35	05.20	01.45		11KV Pin Insulator failed & Tree Fallen on the 11KV Line at Dandamudi Enclave	
7		Mayurinagar	Prashanth Nagar	11KV	Kukatpally	02.03	03.50	01.47		Tarbal bag Fallon the 11kv line at prashanth nagar	
8		Jeedimetla-III	USP Oraganic	11KV	Jeedimetla	02.05	04.05	02.00		11kv line End kit failure at Near Sub Station	
9		Jeedimetla-IV	Venkatadri	11KV	Jeedimetla	17.15	19.40	02.25		11kv line Cut at Last Bus stop, Subhash nagar	
10		Jeedimetla-I	HMT Socity	11KV	Jeedimetla	02.05	05.05	03.00		Jumper Cut & Incoming Jumper Cut & LV-IV Bus Jumper Cut Sub Station	-
11		Jeedimetla-I	Phase-I	11KV	Jeedimetla	03.30	04.45	01.15		Jumper cut & Touched the Chanal at Phase-I	-
12		Ravalkole	IDA Ganapathi	11KV	Medchal	16.56	19.10	02.14		11KV Line melted at Rajabollram Village	-
13		Ravalkole	Cheruvukatta	11KV	Medchal	16.42	19.10	02.28		11KV Pin Insulator failed at Jaya Darishini Temple	-
14		Aliabad	LGM Pet	11KV	Medchal	17.40	19.45	02.05		2 Nos 11KV Poles damaged at Mulla Cheruvu	-
15		Yellampet	IDA Yellampet	11KV	Medchal	17.55	19.55	02.00		Tree Branches fallen on the 11KV Line near PHI Company	-
16		Kolthur	Kolthur	11KV	Medchal	19.15	22.20	03.05		11KV Pin Insulator failed at Kol Village	-
1		Cherlapally-I	EC Computers	11KV	Sainikpuri	10.40	11.10	00.30		11Kv line Jumper cuit at Metal Forgin Compony (AE/OP)	-
2		RGK	Nissa	11KV	Sainikpuri	05.30	06.10	00.40		Ground petrolling done but no visible fault found	
3		Moula-Ali	Mirzalguda	11KV	Sainikpuri	04.45	06.14	01.29		Tree branches fallen on 11Kv line at Opposite HMT Company (Foc Bal Narsihma)	
4		Anandbagh	BS Nagar	11KV	Sainikpuri	04.32	06.00	01.28		11Kv Pin Insulator failed Vishnupuri Colony (LM Babu) due to Heavy Rain	
5		Sainikpuri	Kalyan Garden	11KV	Sainikpuri	17.15	18.10	00.55		Ground petrolling done but no visible fault found	
6		NGRI	Habsiguda	11KV	Habsiguda	02.09	03.44	01.35		Tree branches fallen on 11kv line at St.No.05 Habsiguda	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
7	RR E	St.No.08	Green Hills	11KV	Habsiguda	02.19	04.25	02.06		Line patrolling but no visible fault & 11KV line AB switch opened at Gayathri Tiffins		
8		Mallapur	Standard Tiles	11KV	Habsiguda	02.50	04.10	01.20		11KV Disc failed near Pennar Chemical Company at IDA Mallapur		
9		IDA Uppal	Kamakshipuram	11KV	Habsiguda	03.31	04.46	01.15		Line patrolling but no visible fault & 11KV line AB switch opened at Babu Rao Hotel		
10		IDA Uppal	Srikrishna	11KV	Habsiguda	03.31	05.24	01.53		11KV Disc failed near Airtel Building at IDA Uppal		
11		Nacharam Indore	Mallikarjuna Nagar	11KV	Habsiguda	03.56	05.03	01.07		Tree branches fallen on 11kv line at Mallikarjuna Nagar		
12		NGRI	Scientist Colony	11KV	Habsiguda	02.48	05.35	02.47		Line patrolling but no visible fault & Back feeding supply taken from 11KV Snehapuri feeder		
13		Uppal	Nava Bharath	11KV	Habsiguda	03.00	06.00	03.00		Tree branches fallen on 11kv line at IDA Uppal		
14		Sinagapur	Annojiguda	11KV	Keesara	04.00	05.50	01.50		11KV pin insulaotr fail at Market road annojiguda		
15		Sinagapur	Annojiguda	11KV	Keesara	08.40	10.50	02.10		11KV jumper cut at SS yard back side		
16		Sinagapur	RGK	11KV	Keesara	08.40	10.50	02.10		11KV jumper cut at SS yard back side		
17		Pravathapur	Balaji anjandri	11KV	Keesara	04.00	05.50	01.50		11KV Disk fail at Mandeep colony		
18		Peerzathiguda	RTC	11KV	Keesara	02.40	05.50	03.10		Coconut tree branches fallen on 11kv line at Sriram nagar		
19		Nagaram	SN colony	11KV	Keesara	07.05	07.43	00.38		Copper patti cut at East gandhi nagar		
20		GKSR	DANO	11KV	Keesara	18.00	19.30	01.30		Tree fallen on 11kv line at Kidee steel		
1			Public Garden	Nampally Railway Station	11KV	I	01.39	06.51	05.12	EL	Tree branches fallen on lines at Chapal Road	----
2			Lumbini Park	Lokayuktha	11KV	I	01.40	06.15	04.35	EL	Banner fallen on lines at Ohri's Hotel	----
3			Lumbini Park	Avanthi Nagar	11KV	I	01.40	05.00	03.20	EL	Tree branches fallen on lines at Sky Line Theatre	----
4			Lumbini Park	A.I.R	11KV	I	01.40	04.35	02.55	EL	Tree branches fallen on lines at A.I.R	----
5			Lumbini Park	A.P.Tourism	11KV	I	01.42	04.30	02.48	OL	No Visible Fault (due to rain)	----
6			Erramanzill	Padmavathi Nagar	11KV	I	01.42	03.16	01.34	EL	No Visible Fault (due to rain)	----
7		Lake View	Satyam Computers	11KV	I	01.43	04.35	02.52	EL	No Visible Fault (due to rain)	----	
8		Lumbini Park	T.T.D	11KV	I	01.45	03.10	01.25	EL	No Visible Fault (due to rain)	----	
9		Nizam College	Brand Factory	11KV	I	01.48	06.30	04.42	EL,OL	No Visible Fault (due to rain)	----	
10		Indira Park	Secreteriate	11KV	I	01.50	03.35	01.45	EL	No Visible Fault (due to rain)	----	
11		Indira Park	Gulshan Nagar	11KV	I	01.50	03.25	01.35	EL	No Visible Fault (due to rain)	----	
12		Indira Park	Kuchipudi	11KV	I	01.50	08.20	06.30	EL,OL	Tree branches fallen on lines	----	
13		Indira Park	R.K.Mutt	11KV	I	01.50	03.35	01.45	EL	No Visible Fault (due to rain)	----	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
14	HYD C	Jawahar Nagar	Balaji Indra Prastha	11KV	I	01.50	03.50	02.00	EL	No Visible Fault (due to rain)	----
15		Indira Park	Gandhi Nagar	11KV	I	01.50	03.55	02.05	EL,OL-Rph	No Visible Fault (due to rain)	----
16		Indira Park	Talla Basti	11KV	I	01.50	06.00	04.10	EL,OL-Rph	No Visible Fault (due to rain)	----
17		Indira Park	Ambedkar Nagar	11KV	I	01.50	03.20	01.30	EL,OL-Rph	No Visible Fault (due to rain)	----
18		Indira Park	Himayath Nagar	11KV	I	01.50	05.20	03.30	EL,OL-Rph	Tree branches fallen on lines at Street No.5	----
19		Vittalwadi	Commissioner Office	11KV	I	01.50	03.30	01.40	EL,OL-Rph	No Visible Fault (due to rain)	----
20		Narayanguda	City Central Library	11KV	I	01.50	03.00	01.10	EL,OL-Rph	No Visible Fault (due to rain)	----
21		Nizam College	Shantha Bai Nursing Home	11KV	I	01.55	04.52	02.57	OL	No Visible Fault (due to rain)	----
22		Z.P.Office	Nirankari Bhavan	11KV	I	01.59	05.00	03.01	EL,OL	No Visible Fault (due to rain)	----
23		N.I.M.S	Naveen Nagar	11KV	I	02.30	04.15	01.45	EL	Cable fault	----
24		Nizam College	Little Flower School	11KV	I	02.55	04.50	01.55	EL	No Visible Fault (due to rain)	----
25		Vittalwadi	I.C.I.C.I Bank	11KV	I	03.10	05.15	02.05	EL	No Visible Fault (due to rain)	----
26		Narayanguda	City Central Library	11KV	I	04.35	07.15	02.40	EL,OL-Bph	Tree branches fallen on lines	----
27		Jawahar Nagar	J.N Home	11KV	I	09.45	11.35	01.50	EL,OL-Rph	Tree branches fallen on lines at SRT Quarters	----
28		Public Garden	Nampally Railway Station	11KV	I	09.57	11.30	01.33	EL,OL-Yph	Tree branches fallen on lines at Uday Omini Hospital	----
29		Fever Hospital	Tourist Hotel	11KV	II	01.45	06.30	04.45	EL	No Visible Fault (due to rain)	----
30		Narayanguda	Chikkadpally	11KV	II	01.45	03.15	01.30	EL	No Visible Fault (due to rain)	----
31		Industrial Area	RTC X Road	11KV	II	01.45	04.45	03.00	EL	No Visible Fault (due to rain)	----
32		Industrial Area	Azamabad Key SS	11KV	II	01.49	07.40	05.51	EL	No Visible Fault (due to rain)	----
33		Industrial Area	Barkathpura	11KV	II	01.50	03.49	01.59	EL	Tree branches fallen on lines at Barkathpura	----
34		Bathkammakunta	D.D.Colony	11KV	II	01.50	04.20	02.30	EL	No Visible Fault (due to rain)	----
35		Vittalwadi	Y.M.C.A	11KV	II	01.55	03.35	01.40	EL,OL-Rph	No Visible Fault (due to rain)	----
36		Vittalwadi	APCO	11KV	II	01.55	06.30	04.35	EL	Tree branches fallen on lines at Bata Show Room	----
37		Durga Nagar	Bapu Nagar	11KV	II	02.00	04.40	02.40	EL	Flexi fallen on lines at Bapu Nagar	----
38		Industrial Area	R.O.M	11KV	II	02.20	03.25	01.05	EL	No Visible Fault (due to rain)	----
39		Amberpet	Amberpet	11KV	II	02.25	03.50	01.25	All Indication	No Visible Fault (due to rain)	----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
40		Bathkammakunta	Saibaba Temple	11KV	II	02.34	04.30	01.56	EL	No Visible Fault (due to rain)	----
41		Bathkammakunta	Ahobil Mutt	11KV	II	02.36	04.06	01.30	EL	No Visible Fault (due to rain)	----
42		Amberpet	C.P.L	11KV	II	02.37	03.55	01.18	EL	No Visible Fault (due to rain)	----
43		Golnaka	Tulasi Nagar	11KV	II	03.18	04.29	01.11	EL	Tree branches fallen on lines at MLA House	----
44		Chilkaiguda	44 Bus Stop	11KV	II	03.20	08.50	05.30	EL,OL-Rph	Tree branches fallen on lines at Parsigutta	----
45		Fever Hospital	C.C.Shroff Hospital	11KV	II	03.55	05.05	01.10	All Indication	No Visible Fault (due to rain)	----
46		Narayanguda	Narayanguda	11KV	II	04.22	05.50	01.28	EL	Jumper cut at Sundaraiah Park	----
47		Fever Hospital	C.C.Shroff Hospital	11KV	II	11.56	13.26	01.30	EL,OL	Twisted Lines & Tree branches fallen on lines at Ambika Res.	----
48		Asif Nagar	Toli Chowki	11KV	VII	01.25	03.40	02.15	EL	No Visible Fault (due to rain)	----
49		Nampally	Red Hills	11KV	VII	01.32	03.12	01.40	EL,OL	No Visible Fault (due to rain)	----
50		Asif Nagar	Mehdipatnam OH	11KV	VII	01.33	03.12	01.39	EL	No Visible Fault (due to rain)	----
51		Asif Nagar	Kakatiya Nagar	11KV	VII	01.35	03.12	01.37	OL	No Visible Fault (due to rain)	----
52		Nampally	FAPCCI	11KV	VII	01.38	03.13	01.35	EL	No Visible Fault (due to rain)	----
53		S.D.Hospital	Crescent Hospital	11KV	VII	01.38	04.05	02.27	EL,OL-Yph	No Visible Fault (due to rain)	----
54		A.C.Guards	Bazarghat	11KV	VII	01.40	06.10	04.30	EL	Tree branches fallen on lines at Bazarghat	----
55		Nampally	Pearl Regency	11KV	VII	01.43	03.14	01.31	EL,OL	No Visible Fault (due to rain)	----
56		S.D.Hospital	Khadi Bandar	11KV	VII	01.50	05.59	04.09	EL,OL	Pin Insulator flash over at Khadi Bandar	----
57		Nampally	Nampally Hospital	11KV	VII	01.55	03.20	01.25	EL,OL	No Visible Fault (due to rain)	----
58		A.C.Guards	Nilofer Hospital	11KV	VII	02.05	05.00	02.55	OL-Rph	No Visible Fault (due to rain)	Arranged B/F on 11KV Pearl Regency fdr
59		S.D.Hospital	Police Mess	11KV	VII	02.14	03.47	01.33	EL	No Visible Fault (due to rain)	----
60		Nampally	Amba Hospital	11KV	VII	02.15	03.18	01.03	EL	No Visible Fault (due to rain)	----
61		S.D.Hospital	Ahmed Nagar OH	11KV	VII	02.17	03.26	01.09	EL	No Visible Fault (due to rain)	----
62		I.T.I Mallepally	Anjuman	11KV	VII	02.30	07.32	05.02	EL	Faulty loads of 11KV Zebabagh feeder	----
63		Asif Nagar	Military	11KV	VII	02.30	09.22	06.52	OL-Rph	Big Tree fallen on lines at Military Area	----
64		I.T.I Mallepally	P.S Nagar	11KV	VII	02.35	06.54	04.19	EL	Tree branches fallen on lines at St.Ann's School	----
65		Langer House	Fathe Darwaja	11KV	VII	02.35	07.35	05.00	EL,OL-Bph	No Visible Fault (due to rain)	Arranged B/F on 11KV Balancer feeder

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
66	HYD N	A.C.Guards	Shanthi Nagar	11KV	VII	02.35	06.00	03.25	EL	Tree branches fallen on lines at Annapurna Printers	-----
67		A.S.R.Raju Colony	Jeevan Kalyan Nagar	11KV	VII	02.35	06.15	03.40	EL,OL	Tree branches fallen on lines at J.K.Nagar	-----
68		A.S.R.Raju Colony	L.I.C Office	11KV	VII	02.40	05.30	02.50	EL,OL	Tree branches fallen on lines at Gudimalkapur	-----
69		Gudi Malkapur	Amba Garden	11KV	VII	02.44	04.03	01.19	OL-Bph	UG Cable fault at Santosh Nagar	-----
70		Langer House	Netaji Nagar	11KV	VII	02.45	04.45	02.00	EL	Foreign material fallen on lines at Netaji Nagar	-----
1		Jana Priya	Mothi Nagar	11KV	IV	02.20	04.15	01.55	EL	Insulator flash over at Mothi Nagar	-----
2		Jana Priya	Bharath Nagar	11KV	IV	02.22	04.20	01.58	EL,OL	No Visible Fault (due to rain)	-----
3		E.S.I	I.A.S Quarters	11KV	IV	02.26	03.50	01.24	EL	No Visible Fault (due to rain)	-----
4		Nehru Nagar	Teachers Colony	11KV	V	02.03	03.12	01.09	EL,OL-Rph	Faulty loads of 11KV Ramser Café fdr	-----
5		Marredpally	Nehru Nagar	11KV	V	02.15	03.45	01.30	EL,OL	No Visible Fault (due to rain)	-----
6		Osm. University	Ladies Hostel	11KV	V	02.15	03.30	01.15	EL	O/G AB Switch Jumper cut at SS	-----
7		Marredpally	Tagore Home	11KV	V	02.35	03.55	01.20	EL,OL	No Visible Fault (due to rain)	Arranged B/F on 11KV Nehru Ngr feeder
8		Osm. University	Keshava Nagar	11KV	V	02.50	04.40	01.50	EL	HT Jumper cut at Mallikarjuna House	-----
9		K.I.M.S	My Fair Complex	11KV	V	03.32	04.45	01.13	EL,OL	Cable fault	Arranged B/F on 11KV Babu Bagh feeder
10		Clock Tower	St.Mary's	11KV	V	19.05	20.48	01.43	EL	Disc Insulator flash over at D-Mart	-----
11		Vasanthapuri	Sheshapahad	11KV	V	19.14	20.49	01.35	EL	Disc Insulator flash over at Shivalyam	-----
12		Road No.2	E-Seva	11KV	X	01.33	03.35	02.02	All Indication	Jumper cut at Road No.3	-----
13		Jubilee Hills	Film Nagar	11KV	X	01.35	03.30	01.55	EL	Tree branches fallen on lines at Plot No.55	-----
14		Mytrivanam	Sarathi Studio	11KV	X	01.45	03.35	01.50	EL,OL	No Visible Fault (due to rain)	-----
15		Road No.2	Shabdalya	11KV	X	01.53	04.23	02.30	OL-Yph	No Visible Fault (due to rain)	-----
16		Road No.22	Jublee Hills P. S.	11KV	X	01.53	02.55	01.02	EL	No Visible Fault (due to rain)	-----
17		Yellareddyguda	Engineers Colony	11KV	X	02.30	05.15	02.45	EL	End Kit failed at K.K.Tower	-----
18		Yellareddyguda	Maruthi Nagar	11KV	X	02.30	03.47	01.17	EL	No Visible Fault (due to rain)	Arranged B/F on 11KV Pragathi Nagar feeder
19	Yellareddyguda	Savera	11KV	X	02.30	04.15	01.45	EL	No Visible Fault (due to rain)	-----	
20	Yousufguda	Police Lines	11KV	X	02.35	05.30	02.55	EL	No Visible Fault (due to rain)	-----	
21	Toli Chowki	Hanuman Temple	11KV	X	02.40	05.30	02.50	EL	Tree branches fallen on lines at Vijaya Shanthi House	-----	
22	MLA Colony	Cine Ghar	11KV	X	03.10	05.06	01.56	EL	Disc flash over & Banner fallen on lines at Omega Hospital	-----	
23	Mytrivanam	Sarathi Studio	11KV	X	05.35	06.50	01.15	All Indication	Post type Insulator flash over at L&T Office	-----	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
24		Road No.2	Arora Colony	11KV	X	09.38	10.55	01.17	EL	Tree branches fallen on lines at Arora Colony	-----	
25		Tirumalgiri	Khanajiguda	11KV	VI	02.15	04.00	01.45	EL,OL	Faulty loads of 11KV Yadamma Nagar fdr	-----	
26		I.D.P.L	V.E	11KV	VI	02.25	06.30	04.05	EL,OL-Bph	No Visible Fault (due to rain)	-----	
27		I.D.P.L	Wonder Plast	11KV	VI	02.25	05.25	03.00	EL,OL-Bph	Tree branches fallen on lines at Bala Nagar	-----	
28		Prashanth Nagar	Sony Complex	11KV	VI	02.30	06.05	03.35	EL	Conductor snapped at Water Tank Lane	-----	
29		H.A.L	I.A.L	11KV	VI	02.30	04.50	02.20	EL	Jungil bit problem	Arranged B/F on 11KV IAF feeder	
30		Bowenpally	Sancharpuri Colony	11KV	VI	02.30	03.50	01.20	EL	No Visible Fault (due to rain)	-----	
31		I.D.P.L	Bala Nagar	11KV	VI	02.35	05.05	02.30	EL	No Visible Fault (due to rain)	-----	
32		Prashanth Nagar	Ganesh Kanta	11KV	VI	03.10	05.10	02.00	EL	Tree branches fallen on lines at Ayyanna Building	-----	
33		Bhudevi Nagar	Ram Raj Nagar	11KV	VI	03.15	04.30	01.15	OL	Tree branches fallen on lines at Ram Raj Nagar	-----	
34		Prashanth Nagar	Shakthipuram	11KV	VI	03.25	05.20	01.55	EL	AB Cable Jumper Cut	Arranged B/F on 11KV Ganesh Kanta feeder	
35		Gunrock	Tirumalgiri	11KV	C-VI	02.55	04.40	01.45	EL	No Visible Fault (due to rain)	-----	
36		Gunrock	Surya Enclave	11KV	C-VI	02.58	04.35	01.37	EL	No Visible Fault (due to rain)	-----	
37		Gunrock	Lal Bazar	11KV	C-VI	03.00	04.20	01.20	EL	No Visible Fault (due to rain)	-----	
38		R.P.Nilayam	Naga Devatha Temple	11KV	C-VI	03.30	05.14	01.44	EL	Military HT Service fault	-----	
39		Hakimpet	Allenby Lines	11KV	C-VI	04.15	07.45	03.30	All Indication	Tree branches fallen on lines at BSNL Office	-----	
1		HYD S	Salarjung	Pathergatti	11KV	III	01.45	02.55	01.10	EL	No Visible Fault (due to rain)	-----
2			Ch' Baradari	Dood Bowli	11KV	III	11.44	13.00	01.16	EL,OL	Common Hall DTR UG Cable fault	-----
3			C.R.P.F	C-Block	11KV	III	15.40	17.25	01.45	EL	HT Line snapped at Meridian Hotel	-----
4	Miralam		Hasan Nagar	11KV	III	17.40	19.00	01.20	EL	-----	Arranged B/F on 11KV Madina Masjid feeder	
5	Santosh Nagar		Jahangir Nagar	11KV	VIII	01.35	02.40	01.05	EL	No Visible Fault (due to rain)	-----	
6	Gunj		Gunj	11KV	VIII	01.45	05.00	03.15	OL	AB Switch problem & Brass Patti cut at Gate No.1	-----	
7	Teegalaguda		Teegalaguda	11KV	VIII	03.05	04.30	01.25	All Indication	Jumper cut Opp.SS	-----	
8	Osm. Hospital		Gowliguda	11KV	IX	01.30	02.50	01.20	EL	Tree branches fallen on lines at Red Building	-----	
9	Osm. Hospital		Puranapool OH	11KV	IX	01.34	03.20	01.46	EL	Jumper touching to Channel at Nagarkhana	-----	
10	E.N.T		Gurudwara	11KV	IX	01.45	03.10	01.25	EL	No Visible Fault (due to rain)	-----	
11	E.N.T		Rang Mahal Road	11KV	IX	01.50	03.25	01.35	EL	No Visible Fault (due to rain)	-----	
12	Karwan		Karwan	11KV	IX	01.55	03.00	01.05	EL,OL-Rph	Tree branches fallen on lines at Govt.School	-----	
13	Osm. Hospital		Osmangunj	11KV	IX	02.41	04.20	01.39	EL	AB Switch fault at Phool Market	-----	