

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		3		3		3			
6	RR(N)	54	550	2	10	2	10	2	10			
7	RR(E)	168	403		17		17		17			
8	Hyd	194	1044		73		73		73			
	Total	606	3055	2	103	2	103	2	103	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988	1	43	1	43	1	43			
3	MDK	107	933	1	5	1	5	1	5			
4	SDPT			7	19	5	6	5	6	2	13	2 Nos 33KV & 13 Nos 11KV Feeder still
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	9	68	7	55	7	55	2	13	
	Grand Total	1082	6468	11	171	9	158	9	158	2	13	

TSSPDCL - LMRC / Corporate office

Date: 20.04.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Suryapeta	Nemmikal	33KV	Suryapeta	04.00	07.25	03.25	E/L	Insulator Flashover	Suryapeta	No
1	MDK	Gummadidala	Bonthapally	33KV	Patancheru	15.13	17.55	02.42		B/D Due to Conductor Snapped		-
1	SDPT	Chandlapur	Kammarlapally	33KV	Siddipet	17.02	19.05	02.03		Break Down (due to bad wind)		
2		Gajwel	Ahmedapur	33KV	Gajwel	15.50	19.10	03.10		Break down (Jumper cut)		
3		Doultabad	Mubaraspur	33KV	Gajwel	16.17	18.12	01.55		Break down		
4		Shanigaram	Ramchandrapur	33KV	Husnabad	16.15	17.15	01.00		BD		
5		Shanigaram	Koheda	33KV	Husnabad	00.00	16.55	16.55		BD		
6		Husnabad	Thotapally	33KV	Husnabad	00.00	Still now			BD(Poles broken)		
7		Husnabad	Koheda	33KV	Husnabad	00.00	Still now			BD(Poles broken)		
1	RR N	132KV LGM Pet	33KV LGM Pet	33KV	Medchal	15.57	17.28	01.31		Tree Fallen on the 33KV Line at Pokarna company		-
2		132KV LGM Pet	33KV Aliabad	33KV	Medchal	15.59	16.46	00.47		33KV Isolators Opened at Laxmapur SS(Tree Fallen on 33KV Line at Kolthur SS)		-

TSSPDCL - LMRC / Corporate office

Date: 20.04.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Badepally	Burgupally	11KV	Jadcherla	13.00	13.35	00.35		11 KV Jumpers Opend At Burgupally Tanda Side	-
1	NLG	Gudapoor	Jamastanpally	11KV	Nalgonda	02.00	08.10	06.10	E/L	11KV Jumper cut	-
2		Gundrampally	Aepoor	11KV	Nalgonda	06.00	11.10	05.10	E/L	11KV Disk failure	-
3		Kethepally	Industrial	11KV	Nalgonda	02.00	09.10	07.10	E/L	Tree fallen on line	-
4		Koppole(K)	Bheemaram	11KV	Nalgonda	03.25	07.00	03.35	E/L	HT/LT line melting	-
5		Mamidala	Godavarigudem	11KV	Nalgonda	07.30	10.40	03.10	E/L	11KV Insulator failed	-
6		Palivela	Palivela	11KV	Nalgonda	06.20	10.40	04.20	E/L	Tree fallen on line	-
7		Pullemla	Pullemla AGL	11KV	Nalgonda	07.00	08.30	01.30	E/L	Moment fault	-
8		Gudapoor	Koratikal	11KV	Nalgonda	02.00	11.30	09.30	E/L	Tree branches on line	-
9		Thungathurthy	B.Ramaram	11KV	Suryapet	03.30	07.15	03.45	E/L	Pole Damaged & Insulator flashover	-
10		Phanigiri	Phanigiri Agl	11KV	Suryapet	06.00	09.40	03.40	E/L	Pole Damaged	-
11		Nagaram	Wardamanu kota	11KV	Suryapet	06.00	09.40	03.40	E/L	Pole Damaged & Insulator flashover	-
12		T.Singaram	Somla thanda	11KV	Suryapet	03.30	06.40	03.10	E/L	Conductor snapped	-
13		Palakaveedu	Palakeedu	11KV	Huzurnagar	00.00	08.20	08.20	E/L	Due to 11Kv insulator failure	-
14		Mukundapuram	Kalluru	11KV	Huzurnagar	04.10	07.00	02.50	E/L	Due to 11Kv line cutted	-
15		Keethavarigudem	Kattakommu thanda	11KV	Huzurnagar	03.35	06.40	03.05	E/L	Due to 11Kv line snapped	-
16		Mamillagudem	Thummalapally	11KV	Huzurnagar	03.03	06.00	02.57	E/L	Due to 11Kv line snapped	-
17		Burugadda	Burugadda	11KV	Huzurnagar	08.30	11.00	02.30	E/L	Due to 11Kv line cutted	-
18		K.M.Pally	C.A.Pally	11KV	Devarakonda	04.00	08.25	04.25	E/L	HT/HT	-
19		Padampally	Thurupupally	11KV	Devarakonda	06.00	08.00	02.00	E/L & O/L	11 KV Line Cutt	-
20		Padampally	Iddampally	11KV	Devarakonda	06.00	08.30	02.30	E/L	Movement Fault	-
21		Angadipeta	Akkampally	11KV	Devarakonda	08.00	14.00	06.00	E/L	Jumper Cutt	-
22		Ghanapuram	G.B.Pally	11KV	Devarakonda	09.30	11.30	02.00	E/L	11KV Line Cutt	-
23		Nampally	M.R.Pally	11KV	Devarakonda	00.00	07.10	07.10	E/L	11KV Insulator Failed	-
24		Nampally	Peddapuram	11KV	Devarakonda	07.35	09.00	01.25	O/L	3-ph 25KVA DTR Failed (-
25		T.P.Gouraram	Thungapad	11KV	Devarakonda	09.15	10.58	01.43	E/L	3-ph 25KVA DTR Failed (Thungapad Village)	-
26		T.P.Gouraram	M.R.Pally	11KV	Devarakonda	06.00	08.30	02.30	E/L	LT line Cutt	-
27		Gurrampode	Chepuru	11KV	Devarakonda	08.00	12.00	04.00	E/L	11kv Jumper Cutt	-
28		Gurrampode	Thenepally	11KV	Devarakonda	06.00	10.00	04.00	E/L	11kv Jumper Cutt	-
29		Palvai	M.K.Gudam	11KV	Devarakonda	06.00	13.00	07.00	E/L	HT/HT	-
30		Chepuru	Chepuru	11KV	Devarakonda	06.00	12.50	06.50	E/L	1 No 11KV Disc Failed	-
31		Chepuru	Mosangi	11KV	Devarakonda	13.15	16.30	03.15	E/L	11 KV Jumper Cutt	-
32		Koppole	Bollaram	11KV	Devarakonda	06.30	13.30	07.00	E/L	Tree Fallon	-
33		Marrigudam	Y.G.Pally	11KV	Devarakonda	06.20	07.20	01.00	E/L	1No 11KV Disc Failed	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
34		MR.Gudem	Baswapur	11KV	Bhongir	07.30	09.00	01.30	EL	11kv Pin Insulator Failed near Baswapur Village	-	
35		MT.Pally	Mulkalapally	11KV	Bhongir	06.00	12.00	06.00	EL/OL	Mulkalapally Village near SS_4 100kva DTR short circuit to DTR Failed Single Phase OK 3phase B/d	-	
36		Mothkur	Anajipur	11KV	Bhongir	03.30	06.45	03.15	EL/OL	11kv Line Snapped at Anjipur Villge 3 Phaase B/d Single Phase ok	-	
37		Addagudur	Addagudur	11KV	Bhongir	02.30	08.00	05.30	EL	11kv Pin Insulator Failed near Addagudur Sub_station 5th no Pole	-	
38		Ambala	Ambala	11KV	Bhongir	11.45	13.50	02.05	EL	Kondapur Village near single Phase DTR Failed	-	
39		Choutuppal	Tangedipally	11KV	Choutuppal	06.15	09.20	03.05	EL	11kv Pin Insulator Failed near Tangedipally Village	-	
40		Juloor	Pilaipally	11KV	Choutuppal	16.30	18.30	02.00	EL/OL	11kv 2no's Poles Damaged In Deshimukhi Village	-	
41		Yacharam	Yacharam	11KV	Miryalaguda	11.58	13.30	01.32	EL	Line Snapped	-	
42		Shettipalem	Vemulapally	11KV	Miryalaguda	02.30	06.00	03.30	EL	Jumper Cut	-	
43		Pulimamidi	Srinadhapuram	11KV	Miryalaguda	09.30	11.35	02.05	EL	Line Snapped	-	
1		MDK	Bonthapally	Swamy	11KV	Patancheru	15.00	15.50	00.50		B/D Due to tree branches on the line	-
2			Bonthapally	Veerabadra	11KV	Patancheru	15.00	15.50	00.50		B/D Due to tree branches on the line	-
3			Kistareddypet	Industrial	11KV	Patancheru	17.30	19.17	01.47		B/D Due to Conductor Snapped	-
4			Patancheru Town	Town	11KV	Patancheru	14.45	16.50	02.05		B/D Due to Insulator Failure	-
5	SOL		Markwell	11KV	Sangareddy	14.35	16.55	02.20		B/D Due to tree branches on the line	-	
1	SDPT	Samudrala	Baswapur	11KV	Husnabad	18.00	Still now			BD		
2		Samudrala	Samudrala (R)	11KV	Husnabad	18.00	Still now			3Ph BD,1 Ph ok		
3		Bejjanki	Kallepally	11KV	Husnabad	16.00	Still now			3 Ph BD,1 Ph ok		
4		Bejjanki	Muthannapet	11KV	Husnabad	18.00	Still now			3 Ph BD,1 Ph ok		
5		Bejjanki	Regulapally	11KV	Husnabad	19.00	Still now			4 Ph BD,1 Ph ok		
6		Akkannapet	Akkannapet Rural	11KV	Husnabad	19.00	Still now			BD		
7		Akkannapet	Gollakunta	11KV	Husnabad	13.15	Still now			3 Ph BD,1 Ph ok		
8		Akkannapet	Pakilnayak Thanda	11KV	Husnabad	15.30	17.15	01.45		BD,Conductor snapped		
9		Gouravelly	Gudatipally	11KV	Husnabad	08.30	11.30	03.00		BD		
10		Husnabad	Malapally	11KV	Husnabad	00.02	08.15	08.13		BD		
11		Husnabad	Pandilla	11KV	Husnabad	00.02	07.15	07.13		BD		
12		Koheda	Kurella	11KV	Husnabad	17.25	Still now			BD		
13		Ramchandrapur	Ramchandrapur Rural	11KV	Husnabad	00.35	17.55	17.20		BD		
14		Bekkal	All feeders	11KV	Husnabad	00.00	Still now			BD		
15		Gagillapur	Vallampatla	11KV	Husnabad	19.00	Still now			BD		
16		Marmamula	Dharmaram	11KV	Husnabad	19.10	Still now			BD		
17		Rebarthy	Ladnoor	11KV	Husnabad	18.20	Still now			BD		

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
18		Rebarthy	Maddur	11KV	Husnabad	10.55	11.35	00.40		BD, Jumper cut	
19		Begumpet	Laxmipur	11KV	Husnabad	17.20	Still now			3 Ph BD, 1 Ph ok	
1	RR S	NPA	Shastripuram	11KV	RJNR	16.25	18.30	02.05	B/D	1Nos DTR Damaged at King colony and Tree Branches Fallen on 11kv Line at Shastripuram Due to Rain	-
2		NPA	Raghavendra Colony	11KV	RJNR	16.20	18.46	02.26	B/D	Tree Branches Fallen on 11kv Line at Shastripuram Busstop and Raghavendra colony	-
3		Nanakramguda	Gowlidoddi	11KV	Gachibowli	17.20	18.25	01.05		11KV Pin Insulator Failure near Journalist Colony at Gowlidoddi.	-
1	RR N	Subhash Nagar	Pragha Tools	11KV	Medchal	15.50	17.05	01.15		11KV Pole Damaged at Pipe Line Road	-
2		Kompally	Kompally	11KV	Medchal	16.20	16.50	00.30		Cloth Fallen on 11KV Line at Andra Bank, Jaibheri Park	
3		Subhash Nagar	Ramraj Nagar	11KV	Medchal	21.35	22.15	00.40		Tree Branches fallon on the 11KV Line at OM Books	-
4		Kolthur	Kolthur	11KV	Medchal	10.45	12.40	01.55		11KV Pin Insulator Failed at Grape Garden	-
5		Aliabad	Jaganguda	11KV	Medchal	17.00	20.00	03.00		11KV Jumper Opened at Bommarajpet Road(11KV Pole Damaged)	-
6		Shameerpet	Shameerpet	11KV	Medchal	16.40	18.40	02.00		10No LT Poles Damaged and Conductor Snapped at Aliabad Road	-
7		Uddamarry	Yellaguda	11KV	Medchal	18.15	20.20	02.05		11KV Conductor Snapped at Adraspally	-
8		Uddamarry	Usharpally	11KV	Medchal	18.15	19.20	01.05		11KV Pole Damaged at Cheruvu, Uddamarry(Jumper Opened)	-
9		Bommarajpet	Ponnal	11KV	Medchal	18.05	20.02	01.57		11KV 11KV Pole Damaged at Pochamma Temple, Ponnal	-
10		Bommarajpet	Bommarajpet	11KV	Medchal	18.05	20.15	02.10		11KV Pin Insulator failed marajpet Cheruvu	-
1		Cherlapally-I	Phase-I	11KV	Sainikpuri	03.45	04.20	00.35		HG fuse fail T/F Problem AB Switch Open at Pharma Engineering Compony (Artisan/Ravi)	-
2		Vinayak Nagar	RK Nagar	11KV	Sainikpuri	10.35	11.58	01.23		Binding Wire fallen on 11Kv line at Chankyapuri Colony Main Road (L Insp Venu)	-
3		Vinayak Nagar	Tankbund	11KV	Sainikpuri	16.11	16.50	00.39		Tree branches fallen on 11Kv line at Sheethal Apt (AE/OP)	-
4		Moula-Ali	Kailasagiri	11KV	Sainikpuri	16.05	17.07	01.02		HV Servece Cable Problem at Water House Kailasagiri (AE/OP)	-
5		Moula-Ali	Jawahar Nagar	11KV	Sainikpuri	16.05	17.05	01.00		Star Cable fallen on 11Kv at Jawahar Nagar (AE/OP)	-
6		Moula-Ali	Venkateshwara Nagar	11KV	Sainikpuri	16.05	17.15	01.10		Tree fallen on 11Kv line at Kakatiya School (AE/OP)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
7	RR E	Uppal	Uppal	11KV	Habsiguda	17.15	18.15	01.00		11KV line cut & Tree fallen on 11kv line at Laxma reddy colony	-	
8		Pocharam	Pocharam	11KV	Keesara	16.47	17.47	01.00		Tree fallen on 11kv line jodimetal	-	
9		Chekripuram	Shilpa nagar	11KV	Keesara	17.00	17.30	00.30		Tree fallen on 11kv line at shilpa nagar	-	
10		Rampally	Venneguda	11KV	Keesara	17.12	19.55	02.43		Tree fallen on 11kv line at annapurana fuction hall	-	
11		Keesara	Keesara Town	11KV	Keesara	17.04	17.50	00.46		Flex fallen on 11KV Line Keesara X-Road	-	
12		Keesara	Bogaram	11KV	Keesara	17.10	19.38	02.28		Pin Insulator Failed at Petrol Bunk Keesara	-	
13		Keesara	Vardhana	11KV	Keesara	17.10	21.50	04.40		11KV Pole Damage Mallanaguda Keesara	-	
14		Keesara	Cheeryal	11KV	Keesara	17.10	21.50	04.40		LT Pole Damage & Cable Fault	-	
15		Keesara	Ankireddy Pally	11KV	Keesara	17.10	21.55	04.45		Tree Fallen on 11KV Line Goshal Ankireddy Pally	-	
16		Ghatkesar	Yamnampet	11KV	Keesara	16.30	19.30	03.00		HT/LT Jumper Cut at Sathi Reddy Bhawi	-	
17		Ghatkesar	Shiva Reddy Guda	11KV	Keesara	16.20	18.00	01.40		11KV Jumper Cut at Ghanapur Road	-	
1		MIRALAM	Miralam	Ansari Road	11KV	Charminar	15.55	17.05	01.10	EL	No Visible Fault (due to Rain)	-
2			Miralam	Water Works	11KV	Charminar	15.57	17.25	01.28	EL	No Visible Fault (due to Rain)	-
3			Miralam	Teegala Kunta	11KV	Charminar	15.57	18.18	02.21	EL	No Visible Fault (due to Rain)	-
4			Miralam	Shaik Masjid	11KV	Charminar	15.57	17.06	01.09	EL	No Visible Fault (due to Rain)	-
5			Miralam	Mustafa Nagar	11KV	Charminar	15.57	18.40	02.43	EL	No Visible Fault (due to Rain)	-
6			Miralam	Madina Masjid	11KV	Charminar	15.57	18.55	02.58	EL	No Visible Fault (due to Rain)	-
7	Miralam		Amzadullah Bagh	11KV	Charminar	15.57	17.05	01.08	EL	No Visible Fault (due to Rain)	-	
8	Miralam		Ranjan Colony	11KV	Charminar	15.57	18.45	02.48	EL	No Visible Fault (due to Rain)	-	
9	Miralam		Tadbun	11KV	Charminar	15.57	19.05	03.08	EL	No Visible Fault (due to Rain)	-	
10	Miralam		Kala Pather	11KV	Charminar	15.57	20.05	04.08	EL	No Visible Fault (due to Rain)	-	
11	Khilwath		Khazipura	11KV	Charminar	15.57	21.32	05.35	OL-Y&Bph	Tree Branches fallen on lines at Khajipura	-	
12	Devi Bagh		Jahanuma	11KV	Charminar	15.57	21.20	05.23	EL	Tree Branches fallen on lines at Jahanuma	-	
13	Devi Bagh		MCH Colony	11KV	Charminar	15.57	21.30	05.33	EL	Tree Branches fallen on lines at Macca Colony	-	
14	Miralam		N.S.Kunta	11KV	Charminar	15.57	21.50	05.53	EL	Tree Branches fallen on lines at N.S.Kunta	-	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
15	HYD S	Aliyabad	Shamseer Gunj	11KV	Charminar	15.59	17.05	01.06	EL,OL	No Visible Fault (due to Rain)	-
16		Petlaburz	Petlaburz	11KV	Charminar	15.58	18.40	02.42	EL	Tree fallen on lines at MET Hospital	-
17		Khilwath	Khilwath	11KV	Charminar	15.58	19.38	03.40	OL-Yph	No Visible Fault (due to Rain) (2No. DTR's Kept Off)	-
18		Khilwath	Lal Darwaza	11KV	Charminar	15.58	19.54	03.56	All Indication	DTR & Poles fell down at Lal Darwaza Out Post P.S (1No. DTR Kept Off)	-
19		Aliyabad	Police Quarters	11KV	Charminar	15.59	18.08	02.09	EL	No Visible Fault (due to Rain)	-
20		Attapur	Kishanbagh OH	11KV	Charminar	16.00	17.10	01.10	EL	No Visible Fault (due to Rain)	-
21		Petlaburz	Ghansi Bazar	11KV	Charminar	16.08	17.40	01.32	EL	HT Jumper burntout at Bad Ka Jaad	-
22		Salarjung	Madina	11KV	Charminar	16.00	17.00	01.00	EL	Cable Jumper cut at Pushpa Medical Hall	-
23		Salarjung	Purani Haveli	11KV	Charminar	16.00	18.20	02.20	EL	Twisted HT Lines at Jahara Nagar	-
24		C.R.P.F	Balapur	11KV	Charminar	16.50	18.00	01.10	EL,OL	No Visible Fault (due to Rain)	-
25		C.R.P.F	C.R.P.F	11KV	Charminar	16.48	17.58	01.10	EL,OL	Tree branches fallen on lines at C.R.P.F	-
26		Ch' Baradari	Ch' Baradari	11KV	Charminar	16.00	18.10	02.10	EL,OL-Rph	Tree branches fallen on lines at Ch' Baradari	-
27		Ch' Baradari	Govt.Polytechnic	11KV	Charminar	16.00	18.20	02.20	EL	Tree branches fallen on lines at Ch' Baradari	-
28		Ch' Baradari	SRT Colony	11KV	Charminar	16.00	18.30	02.30	EL	Tree branches fallen on lines at SRT Colony	-
29		Ch' Baradari	Bilal Nagar	11KV	Charminar	16.00	18.50	02.50	EL	Tree branches fallen on lines at Bilal Nagar	-
30		Ch' Baradari	I.T.I Colony	11KV	Charminar	16.00	19.10	03.10	EL	Tree branches fallen on lines at I.T.I Colony	-
31		Ch' Baradari	Ramnaspura	11KV	Charminar	16.00	19.10	03.10	EL	Tree branches fallen on lines at Ramnaspura	-
32		Ch' Baradari	Dood Bowli	11KV	Charminar	16.00	19.20	03.20	EL	Tree branches fallen on lines at Dood Bowli	-
33		Ch' Baradari	Gazi Banda	11KV	Charminar	16.00	19.30	03.30	EL	Tree branches fallen on lines at Gazi Banda	-
34		Ch' Baradari	Fire Station	11KV	Charminar	16.00	20.10	04.10	EL	Tree branches fallen on lines at Fire Station	-
35		Khilwath	Charminar	11KV	Charminar	16.20	19.57	03.37	OL-Bph	HT Line snapped at Narayana College	-
36		Kandikalgate	Phool Bagh	11KV	Charminar	16.00	17.40	01.40	EL,OL	No Visible Fault (due to Rain)	-
37		Kandikalgate	Gazi Millath Colony	11KV	Charminar	16.00	17.45	01.45	EL,OL	No Visible Fault (due to Rain)	-
38		Kandikalgate	Naseeb Nagar	11KV	Charminar	16.00	17.48	01.48	EL,OL	No Visible Fault (due to Rain)	-
39		Kandikalgate	Hashamabad	11KV	Charminar	16.00	17.25	01.25	EL,OL	No Visible Fault (due to Rain)	-
40		Salarjung	Q.Q Stadium	11KV	Charminar	16.00	20.20	04.20	EL,OL-Yph	HT Jumper cut at Maternity Hospital	-
41		Attapur	Shareef Nagar	11KV	Charminar	16.15	18.10	01.55	EL	No Visible Fault (due to Rain)	-
42		Kanchan Bagh	Riyasath Nagar	11KV	Charminar	16.48	18.27	01.39	EL,OL-Rph	No Visible Fault (due to Rain)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
43		Devi Bagh	Shivalayam	11KV	Charminar	16.01	17.55	01.54	OL	Tree Branches fallen on station T/F	-
44		Devi Bagh	Kamela	11KV	Charminar	16.01	17.55	01.54	OL	Tree Branches fallen on station T/F	-
45		Devi Bagh	Rama Ralkies	11KV	Charminar	16.01	17.55	01.54	OL	Tree Branches fallen on station T/F	-
46		Kandikalgate	Patel Nagar	11KV	Charminar	17.25	18.40	01.15	EL,OL	Tree branches fallen on lines at Patel Nagar	-
47		Devi Bagh	Zoo Quarters	11KV	Charminar	17.55	19.11	01.16	OL	Tree Branches fallen on station T/F	-
48		Devi Bagh	Shalimar	11KV	Charminar	17.55	19.21	01.26	OL	Tree Branches fallen on station T/F	-
49		Devi Bagh	Edgah	11KV	Charminar	17.55	21.12	03.17	OL	Tree Branches fallen on station T/F	-
50		Devi Bagh	Siddiq Gulshan	11KV	Charminar	17.55	21.22	03.27	OL	Tree Branches fallen on station T/F	-
51		Devi Bagh	Bandalguda	11KV	Charminar	19.55	21.48	01.53	OL	Tree Branches fallen on lines at Bhahadurpura P.S	-
52		Panjasha	Bi Bi Bazar	11KV	Charminar	16.55	18.45	01.50	EL	Foreign Meterial fallen on lines at Swagath Hotel	-
53		Panjasha	Gulzar House	11KV	Charminar	16.55	19.50	02.55	EL	Cable Jumper cut at Char Kaman	-
54		Panjasha	Sulthan Shahi	11KV	Charminar	17.00	18.30	01.30	All Indication	Tree Branches fallen on lines at Maisamma Banda	-
55		Salarjung	Pather Gatti	11KV	Charminar	16.09	22.10	06.01	EL	Tree Branches fallen on lines at Divan Devdi	-
56		Falaknuma	Chatrinaka	11KV	Charminar	17.30	19.25	01.55	EL	HT Lines Twisted at Bala Gunj	-
57		Falaknuma	G.S.Darga	11KV	Charminar	17.30	18.55	01.25	EL	Tree Branches fallen on lines at Darga	-
58		Falaknuma	Vatte Pally	11KV	Charminar	17.30	23.35	06.05	EL	Tree Branches fallen on lines at Temple	-
59		Gunj	Gunj	11KV	Asmangadh	15.56	17.06	01.10	EL,OL-Rph	No Visible Fault (due to Rain)	-
60		Malakpet	Farath Nagar	11KV	Asmangadh	16.06	17.40	01.34	EL	No Visible Fault (due to Rain)	-
61		Madannapet	Waheed Colony	11KV	Asmangadh	16.05	17.50	01.45	OL-Rph	HT Line snapped & Tree branches fallen on lines at Waheed Colony	-
62		Gunj	Palton	11KV	Asmangadh	16.02	17.45	01.43	OL-R&Yph	Tree fallen on lines at Palton X-Roads	-
63		Salarjung	Sadath Nagar	11KV	Asmangadh	16.08	17.35	01.27	EL,OL-R&Bph	No Visible Fault (due to Rain)	-
64		Asmangadh	Saibaba Temple	11KV	Asmangadh	16.59	18.07	01.08	EL	No Visible Fault (due to Rain)	-
65		Malakpet	Dabeerpura	11KV	Asmangadh	17.10	18.55	01.45	All Indication	Tree fallen on lines at Hanuman Temple	-
66		Osm. Hospital	Begum Bazar	11KV	Begumbazar	16.00	17.20	01.20	EL,OL	No Visible Fault (due to Rain)	-
67		E.N.T	Gurudwara	11KV	Begumbazar	16.00	18.18	02.18	EL	Limb Flash over at SS	Arranged B/F on 11KV Gowliguda & Puthli Bowli fdrs
68		Womens College	Victoria Play Ground	11KV	Begumbazar	16.05	18.10	02.05	EL	Tree branches fallen on lines at Esamiya Bazar	-
69		Womens College	Esamiya Bazar	11KV	Begumbazar	16.05	17.50	01.45	EL	Tree branches fallen on lines at Esamiya Bazar	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD C	Golnaka	Thulasi Nagar	11KV	Azamabad	16.05	18.13	02.08	EL	PTR buch holz alaram operated	Arranged B/F on 11KV Che Number fdr
2		Bathkammakunta	Saibaba Temple	11KV	Azamabad	16.08	17.30	01.22	EL	Tree branches fallen on lines at Chaitanya College	-
3		Industrial Area	Azamabad I.E	11KV	Azamabad	16.25	18.00	01.35	EL,OL-R&Bph	Tree branches fallen on lines at Sai Aishwarya Apts	-
4		A.C Guards	Niloufer	11KV	Mehdipatanam	16.02	17.36	01.34	OL-Bph	Twisted Lines & Tree branches fallen on lines at Forenic Lab	-