

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234	2		2		2				
6	RR(N)	54	550	1	13	1	13	1	13			
7	RR(E)	168	403									
8	Hyd	194	1044		248		243		243			5 Nos.11 KV Still
	Total	606	3055	3	261	3	256	3	256	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	5	3	5	3	5			
2	NLG	144	988		18		18		18			
3	MDK	107	933	11	9	11	7	11	7			2 Nos.11 KV Still
4	SDPT				15		15		15			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	14	47	14	45	14	45	0	0	
	Grand Total	1082	6468	17	308	17	301	17	301	0	0	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	leeza	Venkatapuram	33KV	Gadwal	17.55	21.50	03.55	E/L & O/L	Pin Insulater Replacement at Uppal Camp	Venkatapuram	-
2		Ghanapur	Kamaludinnpur	33KV	Wanaparth	17.45	20.53	03.08	E/L	Jumper Cut at Thirumalaipally	Kamaludinnpur	-
3		Kalwakurthy	Veldanda	33KV	Nagarkurnool	00.40	03.45	03.05	E/L	for Pin Baining Replaced at Kutra Village	Veldanda	-
1	MDK	Kandi	SRD-I	33KV	Sangareddy	20.00	20.45	00.45		B/D due to Jumper cut	SRD-I	-
2		Kandi	BDL	33KV	Sangareddy	20.35	21.10	00.35		B/D due to Insulator fail	BDL	-
3		Kandi	Signode	33KV	Sangareddy	20.00	01.00	05.00		B/D due to Insulator fail	Signode	-
4		Kandi	SKOL	33KV	Sangareddy	20.35	03.30	06.55		B/D due to Jumper cut	SKOL	-
5		Sadashivapet	Manjeera	33KV	Sangareddy	18.50	18.55	00.05		B/D due to Jumper cut	Manjeera	-
6		Zaheerabad	Machnoor	33KV	Zaheerabad	15.55	17.45	01.50		B/D due to Insulator fail	Machnoor	-
7		Narayankhed	Narayankhed	33KV	Jogipet	17.40	18.40	01.00		B/D due to Jumper cut	Narayankhed	-
8		Borapatla	Feeder-2	33KV	Jogipet	18.48	21.07	02.19		B/D due to Tree branches fallen on the line	Feeder-2	-
9		Gummadidala	GPSS-II	33KV	Patancheru	20.05	21.10	01.05		B/D due to Jumper cut	GPSS-II	-
10		Gummadidala	Bonthapally	33KV	Patancheru	17.55	19.45	01.50		B/D due to Conductor snapped	Bonthapally	-
11		Gummadidala	Jinnaram	33KV	Patancheru	17.55	20.43	02.48		B/D due to Tree branches fallen on the line	Jinnaram	-
1	RR S	MD Pally	MD Pally (V)	33KV	RJNR	09.20	11.20	02.00	B/D	11KV Insulator failed and 11kv Line Snapped at MD Pally village Due to Heavy Rain	MD Pally (V)	-
2		MD Pally	Brundavan colony	33KV	RJNR	09.20	13.00	03.40	B/D	Md pally line cut fallen on Brundavan colony Feeder at MD Pally village Police Station Due to Heavy Rain	Brundavan colony	-
1	RR N	132KV Medchal	33KV Medchal-I	33KV	Medchal	18.55	20.28	01.33	BD	33KV Jumper cut and replaced at Kisapur Road	33KV Medchal-I	-

TSSPDCL - LMRC / Corporate office

Date: 22.04.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Hemajipur	Lingaram	11KV	Jadcherla	21.00	09.00	12.00		B.D. 11Kv Disc Failure Near Lingaram (Vi).	-
2		Kothamolgara	Kothamolgara	11KV	Jadcherla	10.20	13.30	03.10		B.D.Tree Follen on The 11kv Line Near Pathamolgara(Vi).	-
3		Bhoothpur	Amistapur	11KV	Jadcherla	06.00	07.40	01.40		B.D. 11Kv Phase To Phase Near Hasnapur(Vi).	-
4		Bhoothpur	Rural	11KV	Jadcherla	06.00	09.30	03.30		B.D.Ht/Lt Near Nakkalabanda Tanda(Vi).	-
5		Kodgal	Goplapur	11KV	Jadcherla	10.36	14.50	03.14		B.D.Dtr Failure And Lt Line Cut Near Goplpur(Vi)	-
1	NLG	Mukundapurma	Chandupatla	11KV	Suryapet	07.55	09.40	01.45	E/L	Insulator failed	-
2		Jalalpuram	Jalalpuam	11KV	Suryapet	09.50	11.20	01.30	E/L	Disk failed	-
3		PD Pally	PD Pally	11KV	Nalgonda	09.40	11.20	01.40	E/L	11KV Line Cut .	-
4		Arlagadda Gudem	N.R Gudem	11KV	Nalgonda	11.30	13.30	02.00	E/L	11KV Line Insulator Fail	-
5		Mandra	Mandra	11KV	Nalgonda	08.00	10.00	02.00	E/L	11KV Line Jumper Cut	-
6		Madugalapally	Kukkadam	11KV	Nalgonda	12.00	15.05	03.05	E/L	AB Switch Femail Cut	-
7		Padamtipally	Kandukur	11KV	Devarakonda	08.00	10.00	02.00	E/L	Tree Fallen on the line	-
8		Padamtipally	Yaraguntlapally	11KV	Devarakonda	07.00	08.00	01.00	E/L	Tree Fallen on the line	-
9		Mukundapuram	Mukundapuram	11KV	Huzurnagar	11.05	13.35	02.30	E/L	Due to 11Kv jumper cutted	-
10		Kandibanda	Gandi nagar thanda	11KV	Huzurnagar	08.05	10.08	02.03	E/L	Due to 11kv line snapped	-
11		Alingapuram	Gundlapahad	11KV	Huzurnagar	16.00	17.55	01.55	E/L	Due to 11Kv jumper cutted	-
12		Akupamula	Akupamula Agl	11KV	Huzurnagar	16.05	17.56	01.51	E/L	Due to 11kv line snapped	-
13		Gundala	Nunegudem	11KV	Bhongir	11.30	13.15	01.45	E/L	Jumper Open Near Bandakothapally , 3 DTR's OFF	-
14		Peddapadishala	Peddapadishala	11KV	Bhongir	15.00	17.30	02.30	E/L	HT/LT Near Peddapadishala Village.3 Phase B/d Single Phase ok	-
15		Choutuppal	Thangedipally	11KV	Choutuppal	05.30	10.20	04.50	E/L	11 KV Insulator Failed Near Chinthalagudem Village.3 phase B/d Single Phase OK	-
16		Panthnagi	Panthnagi	11KV	Choutuppal	06.00	09.10	03.10	E/L	Tree Branchess Fallen at Line Near Panthangi Village. 3 phase B/d Single Phase OK	-
17		Narayanapur	Kothagudem	11KV	Choutuppal	04.00	08.25	04.25	E/L	11 KV Line Snapped at SS - 5,Near Kothagudem Village	-
18		Botimedithanda	Dackthanda	11KV	Choutuppal	07.20	10.20	03.08	E/L	Tree Branchess Fallen at Line Near Lachhammagudem.3 phase B/d Single Phase OK	-
1		SRD-T-II	No.1	11KV	Sangareddy	21.00	22.30	01.30		B/D due to Tree branches fallen on the line	-
2		SRD-T-II	Kosla	11KV	Sangareddy	21.00	22.06	01.06		B/D due to Jumper cut	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
3	MDK	Collectorate	Kothlapur	11KV	Sangareddy	21.00	21.50	00.50		B/D due to Insulator fail	-	
4		Sadashivapet	TSM	11KV	Sangareddy	15.50	16.45	00.55		B/D due to Jumper cut	-	
5		Sadashivapet	Nandi Kandi	11KV	Sangareddy	15.50	00.00	08.10		B/D continue	-	
6		Isnapur	Widea	11KV	Sangareddy	19.30	00.00	04.30		B/D continue	-	
7		Inole	Indresham	11KV	Patancheru	19.30	21.30	02.00		B/D due to Conductor snapped	-	
8		Inole	Pedda Kanjarla	11KV	Patancheru	19.30	20.46	01.16		B/D due to Tree branches fallen on the line	-	
9		Kistareddypet	Industrial	11KV	Patancheru	19.35	20.35	01.00		B/D due to Jumper cut	-	
1		SDP	Husnabad	Husnabad Town-2	11KV	Husnabad	08.10	09.00	00.50		Break down (insulator fail)	-
2			Pandilla	Pandilla Rural	11KV	Husnabad	00.00	08.10	08.10		Break down	-
3	Pandilla		Pandilla Express	11KV	Husnabad	18.10	18.50	00.40		Break down	-	
4	Thotapally		Thotapally	11KV	Husnabad	18.15	19.30	01.15		Break down	-	
5	Thotapally		Anthakkapet	11KV	Husnabad	15.05	15.55	00.50		BD, Conductor snapped	-	
6	Thotapally		Anthakkapet	11KV	Husnabad	18.15	19.15	01.00		Break down	-	
7	Gouravelly		Gouravelly Rural	11KV	Husnabad	10.30	11.30	01.00		HT wire short	-	
8	Bejanki		Kallepally	11KV	Husnabad	00.00	00.07	00.07		Break down	-	
9	Akunoor		Rampoor	11KV	Husnabad	09.25	10.30	01.05		Breaak down	-	
10	Mustyal		Chuchanakota	11KV	Husnabad	11.55	14.20	02.25		Break down	-	
11	Mustyal		Chuchanakota	11KV	Husnabad	17.30	18.05	00.35		Break down	-	
12	Mustyal		Chuchanakota	11KV	Husnabad	08.45	15.25	06.40		Break down	-	
13	Komuravelly		Kistampet	11KV	Husnabad	12.35	18.00	05.25		Break down	-	
14	Rebarthy		Gagillapur Agl	11KV	Husnabad	18.13	18.30	00.17		Break down	-	
15	Rebarthy		Ladnoor	11KV	Husnabad	08.30	09.30	01.00		Break down	-	
1	RR N	Jeedimetla-III	U S P Organic	11KV	Jeedimetla	18.43	20.40	01.57	BD	Due to rain and wind	-	
2		Jeedimetla-III	Ramreddy nagar	11KV	Jeedimetla	18.58	20.40	01.42	BD	Due to rain and wind	-	
3		Jeedimetla-III	Pipe Line	11KV	Jeedimetla	19.04	20.20	01.16	BD	Due to rain and wind	-	
4		Subhash Nagar	Jeedimetla	11KV	Medchal	19.33	20.02	00.29	BD	Tree fallen on the 11KV Line at Jeedimetla	-	
5		Subhash Nagar	Suchitra	11KV	Medchal	19.33	20.19	00.46	BD	Tree fallen on the 11KV Line at Suchitra	-	
6		Subhash Nagar	Jairam Nagar	11KV	Medchal	19.33	20.24	00.51	BD	Line AB Switch opened at Chermas Company(Tree Fallen on 11KV Line)	-	
7		Subhash Nagar	Gayatri Nagar	11KV	Medchal	19.36	21.05	01.29	BD	Tree Fallen on 11KV Line at TNR Garden	-	
8		Subhash Nagar	Padma Nagar	11KV	Medchal	19.33	21.30	01.57	BD	Tree Fallen on 11KV Line at Ring Road	-	
9		Subhash Nagar	Ramaraj Nagar	11KV	Medchal	19.42	22.05	02.23	BD	11KV Conductor Snapped and Replaced at	-	
10		Petbasheerabad	Satyam Enclave	11KV	Medchal	18.55	21.05	02.10	BD	Tree Fallen on 11KV Line at Dandamudi Enclave	-	
11		Petbasheerabad	Balaji Hospital	11KV	Medchal	18.57	21.15	02.18	BD	Tree Fallen on 11KV Line at Balaji Hospital(100KVA DTR Off)	-	
12		Kandlakoya	Godrej	11KV	Medchal	18.50	20.00	01.10	BD	Tree fallen on the 11KV Line at Chaitanya Agro	-	
13		Kistapur	IDA Hanuman	11KV	Medchal	20.30	22.07	01.37	BD	11KV Conductor Snapped at Amulya company	-	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1		Begumpet	D.K.Road	11KV	IV	19.20	22.20	03.00	EL	Tree branches fallen on lines at Various locations	-----
2		Begumpet	Vidyuth Towers	11KV	IV	19.25	20.40	01.15	EL	No Visible Fault (Due to rain)	-----
3		Bansialpet	Botany School	11KV	V	19.15	20.21	01.06	EL	No Visible Fault (Due to rain)	-----
4		Bansialpet	Old Jail Khana	11KV	V	19.15	22.50	03.35	EL	No Visible Fault (Due to rain)	-----
5		Marredpally	Mahendra Hills	11KV	V	19.20	20.45	01.25	EL,OL-R&Yph	No Visible Fault (Due to rain)	-----
6		Marredpally	Lalitha Nagar	11KV	V	19.08	20.50	01.42	EL,OL-Rph	No Visible Fault (Due to rain)	-----
7		Marredpally	Tagore Home	11KV	V	19.10	20.30	01.20	EL	No Visible Fault (Due to rain)	-----
8		Marredpally	Railway Colony	11KV	V	19.20	21.15	01.55	EL,OL	No Visible Fault (Due to rain)	-----
9		Marredpally	Nehru Nagar	11KV	V	19.10	21.13	02.03	EL,OL	No Visible Fault (Due to rain)	-----
10		James Street	M.G.Road	11KV	V	19.05	20.50	01.45	EL,OL	Faulty DTR at Gandhi Statue	-----
11		James Street	C.T.C.	11KV	V	19.10	21.40	02.30	EL,OL	Faulty DTR at Park Lane Hotel	-----
12		James Street	Park Lane	11KV	V	19.05	22.00	02.55	EL	No Visible Fault (Due to rain)	-----
13		Addagutta	Ambedkar Nagar	11KV	V	20.20	21.55	01.35	EL,OL-Yph	No Visible Fault (Due to rain)	-----
14		K.I.M.S	D.V.Colony	11KV	V	19.12	21.58	02.46	EL	No Visible Fault (Due to rain)	-----
15		K.I.M.S	Krishna Nagar	11KV	V	19.13	23.42	04.29	EL	Cable Fault	Arranged B/F on 11KV Bapu Bagh feeder
16		K.I.M.S	Mani Anjaiah	11KV	V	19.14	21.52	02.38	EL,OL-Rph	No Visible Fault (Due to rain)	-----
17		K.I.M.S	H.D.F.C.	11KV	V	19.15	21.09	01.54	EL,OL-Rph	No Visible Fault (Due to rain)	-----
18		Vasanthapuri	Sheshapahad	11KV	V	19.06	00.01	04.55	EL	Tree branches fallen on lines at Various locations	-----
19		Nehru Nagar	Contonment	11KV	V	19.08	22.28	03.20	EL,OL-Bph	Tree branches fallen on lines at Various locations	-----
20		Nehru Nagar	West Marredpally	11KV	V	19.10	22.10	03.00	EL,OL	No Visible Fault (Due to rain)	-----
21		Nehru Nagar	Rezimental Bazar	11KV	V	19.12	22.12	03.00	EL,OL-Rph	No Visible Fault (Due to rain)	-----
22		Nehru Nagar	Hari Hara Kala Bhavan	11KV	V	19.12	22.42	03.30	EL,OL	No Visible Fault (Due to rain)	-----
23		Addagutta	Polytechnic	11KV	V	18.56	22.10	03.14	EL,OL-Rph	Tree branches fallen on lines at Various locations	-----
24		Addagutta	Addagutta	11KV	V	20.10	22.15	02.05	EL	Sparking on Pole at Saibaba Temple	-----
25		Addagutta	Tukaram Gate	11KV	V	20.05	22.10	02.05	EL,OL-Rph	No Visible Fault (Due to rain)	-----
26		Addagutta	Hanuman Temple	11KV	V	20.20	01.40	05.20	EL	Tree branches fallen on DTR at Water Works	-----
27		Marredpally	Jyothi Colony	11KV	V	19.05	01.40	06.35	EL,OL-R&Bph	Tree branches fallen on DTR at Jyothi Colony	-----
28		Zamistanpur	S.P.College	11KV	V	19.12	21.30	02.18	EL	Flexi fallen on lines at Garuda Apts	-----
29		Zamistanpur	Sanjeevapuram	11KV	V	19.15	20.45	01.30	OL	No Visible Fault (Due to rain)	-----
30		Gunrock	Gymkhana	11KV	V	19.10	01.30	06.20	EL	Tree branches fallen on lines at Various locations	-----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
31	HYD N	Clock Tower	St.Mary's	11KV	V	19.12	22.05	02.53	EL,OL-Bph	Tree branches fallen on lines at Various locations	-----
32		Clock Tower	R.P.Road	11KV	V	19.14	21.20	02.06	OL-R,Y&Bph	No Visible Fault (Due to rain)	-----
33		Clock Tower	Station Road	11KV	V	19.16	21.50	02.34	EL,OL-R,Y&Bph	Tree branches fallen on lines at Venu Gopala Swamy Temple	-----
34		Nehru Nagar	J.B.S.	11KV	V	19.07	00.00	04.53	EL	Still	-----
35		Gymkhana	Laxmi Nagar	11KV	V	19.14	21.10	01.56	EL,OL-Bph	No Visible Fault (Due to rain)	Arranged B/F on 11KV Picket fdr
36		Gymkhana	Vikrampuri	11KV	V	19.16	01.00	05.44	EL,OL-Rph	Tree branches fallen on lines at Various locations	Only partial fdr charged
37		Gymkhana	Mud Fort	11KV	V	19.20	21.25	02.05	EL,OL-Rph	Tree branches fallen on lines at Mud Fort	-----
38		Gymkhana		11KV	V	19.25	21.20	01.55	EL,OL-Rph	No Visible Fault (Due to rain)	-----
39		Gymkhana	Vasavi Nagar	11KV	V	19.25	22.10	02.45	EL,OL	No Visible Fault (Due to rain)	-----
40		Gymkhana	Pared Ground	11KV	V	19.10	23.50	04.40	All Indication	Tree branches fallen on lines at Tivoli Theatre	-----
41		Gymkhana	Balaji Enclave	11KV	V	19.07	00.00	04.53	EL,OL-R&Bph	Still	-----
42		Gymkhana	Apollo	11KV	V	19.07	00.25	05.18	EL	Pole damaged at Sec'bad Club	Arranged B/F on 11KV Lalitha Nagar feeder
43		Gymkhana	Balamrai	11KV	V	19.15	20.44	01.29	EL	No Visible Fault (Due to rain)	-----
44		Gymkhana	Tadbun Temple	11KV	V	19.14	20.35	01.21	EL,OL	No Visible Fault (Due to rain)	-----
45		Gymkhana	Picket	11KV	V	19.17	20.35	01.18	EL	No Visible Fault (Due to rain)	-----
46		Patigadda	Rasoolpura	11KV	V	19.10	21.03	01.53	EL,OL	No Visible Fault (Due to rain)	-----
47		Patigadda	Zeera	11KV	V	19.12	23.22	04.10	EL,OL-Rph	Pin Insulator flash over at Rani Gunj Bus Depot	-----
48		Patigadda	Budha Bhavan	11KV	V	19.12	20.30	01.18	EL	LT Pole broken at Budha Youth Hospital	-----
49		Lalaguda	Chenna Reddy	11KV	V	19.10	05.00	09.50	EL	No Visible Fault (Due to rain)	Arranged B/F on 11KV Vijaypuri fdr
50		Lalaguda	Nagarjuna Nagar	11KV	V	19.09	05.15	10.06	EL	Tree branches fallen on lines at Various locations	-----
51		Lalaguda	Vijaypuri	11KV	V	19.11	23.52	04.41	EL	Tree branches fallen on Lines at Vijaypuri	-----
52		Lalaguda	Shanthi Nagar	11KV	V	19.05	22.28	03.23	EL	No Visible Fault (Due to rain)	-----
53		Lalaguda	A.P.Dairy	11KV	V	19.05	20.33	01.28	EL	No Visible Fault (Due to rain)	-----
54		Gunrock	Bowenpally	11KV	V	19.10	22.50	03.40	All Indication	Tree branches fallen on lines at Various locations	-----
55		I.I.C.T.	Deccan	11KV	V	19.10	05.10	10.00	EL	Tree branches fallen on lines at Various locations	-----
56		Osm. Univesity	Mettuguda	11KV	V	19.14	21.28	02.14	EL,OL-Rph	No Visible Fault (Due to rain)	-----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
57		Osm. Univesity	Keshav Nagar	11KV	V	19.14	00.25	05.11	EL,OL-Rph	Tree branches fallen on lines at Various locations	-----
58		Osm. Univesity	Ravindra Nagar	11KV	V	19.12	00.40	05.28	EL,OL-Rph	Tree branches fallen on lines at Various locations	-----
59		Chilkalguda	Pragatools	11KV	V	19.12	20.50	01.38	EL	No Visible Fault (Due to rain)	-----
60		Chilkalguda	New Boiguda	11KV	V	09.13	21.13	12.00	EL	No Visible Fault (Due to rain)	-----
61		Chilkalguda	Dandu Pentaiah	11KV	V	19.15	21.20	02.05	EL	No Visible Fault (Due to rain)	-----
62		Chilkalguda	P.R.Nagar	11KV	V	19.17	20.59	01.42	EL	No Visible Fault (Due to rain)	-----
63		Osm. Univesity	RTC Hospital	11KV	V	19.12	01.20	06.08	EL,OL-Rph	Tree branches fallen on lines at Various locations	-----
64		Osm. Univesity	Ladies Hostel	11KV	V	19.08	22.04	02.56	EL,OL-Rph	No Visible Fault (Due to rain)	Partial fdr charged
65		Osm. Univesity	Osm. University	11KV	V	19.14	22.40	03.26	EL,OL-Rph	No Visible Fault (Due to rain)	Partial fdr charged
66		Bhudevi Nagar	Ramraj Nagar	11KV	VI	18.59	23.10	04.11	EL	Cable fault	Arranged B/F on 11KV Satya Sai fdr
67		I.D.P.L.	Bala Nagar	11KV	VI	19.10	20.20	01.10	All Indication	Tree branches fallen on DTR at L.B.S.Nagar	-----
68		Bowenpally	Pension Line	11KV	VI	19.00	20.45	01.45	EL	No Visible Fault (Due to rain)	-----
69		Bowenpally	Plassy Line	11KV	VI	19.05	20.15	01.10	EL	No Visible Fault (Due to rain)	-----
70		Bowenpally	Ferozguda	11KV	VI	19.10	20.40	01.30	EL,OL-Bph	No Visible Fault (Due to rain)	-----
71		Bowenpally	Gowtham Nagar	11KV	VI	19.10	20.35	01.25	EL,OL-Bph	No Visible Fault (Due to rain)	-----
72		Bowenpally	Kalinga Enclave	11KV	VI	19.50	21.15	01.25	EL	No Visible Fault (Due to rain)	-----
73		Bowenpally	Jaya Nagar	11KV	VI	19.15	20.25	01.10	EL	No Visible Fault (Due to rain)	-----
74		Bowenpally	Sancharpuri	11KV	VI	20.05	21.15	01.10	EL,OL-Bph	Faulty DTR at Old Airport Road	-----
75		Chinna Thokatta	Panchavati Colony	11KV	VI	19.05	21.30	02.25	EL,OL-Bph	No Visible Fault (Due to rain)	-----
76		Chinna Thokatta	Old Bowenpally	11KV	VI	19.07	21.58	02.51	EL	Tree branches fallen on lines at Old Bowenpally	-----
77		Chinna Thokatta	Hasmathpet	11KV	VI	19.10	22.00	02.50	All Indication	Tree branches fallen on lines at Hasmathpet	-----
78		Chinna Thokatta	Parkview Enclave	11KV	VI	19.10	22.25	03.15	All Indication	Tree branches fallen on lines at Parkview Enclave	-----
79		Chinna Thokatta	Khanajiguda	11KV	VI	19.15	22.15	03.00	EL,OL	No Visible Fault (Due to rain)	-----
80		Chinna Thokatta	Dubai Gate	11KV	VI	19.10	20.50	01.40	EL	No Visible Fault (Due to rain)	-----
81		Chinna Thokatta	Mahatma Nagar	11KV	VI	19.10	20.40	01.30	EL	No Visible Fault (Due to rain)	-----
82		Tirumalagiri	Satya Sai Enclave	11KV	VI	17.15	21.45	04.30	EL,OL	No Visible Fault (Due to rain)	-----
83		Gunrock	Anjaiah Bhavan	11KV	VI	19.10	23.20	04.10	All Indication	Tree branches fallen on lines at Various locations	-----
84		Gunrock	M.D.F.	11KV	VI	19.10	23.25	04.15	All Indication	Foreign material fallen on lines at M.D.F.	-----
85		Bhudevi Nagar	Gollaguda	11KV	C-VI	18.58	23.00	04.02	EL	Tree branches fallen on lines at Gollaguda	-----
86		Bhudevi Nagar	Adarsh Nagar	11KV	C-VI	18.59	21.00	02.01	EL	No Visible Fault (Due to rain)	-----
87		Bhudevi Nagar	Shastry Nagar	11KV	C-VI	19.00	23.00	04.00	EL	HT Jumper cut Pump House	-----
88		Bhudevi Nagar	Yadamma Nagar	11KV	C-VI	19.03	20.20	01.17	EL	No Visible Fault (Due to rain)	-----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
89		Bhudevi Nagar	Maruthi Nagar	11KV	C-VI	19.04	23.30	04.26	EL	Tree branches fallen on lines at Maruthi Nagar	-----
90		Bhudevi Nagar	L.N.Colony	11KV	C-VI	18.59	21.00	02.01	EL	No Visible Fault (Due to rain)	-----
91		Gunrock	Surya Enclave	11KV	C-VI	19.05	23.15	04.10	EL	Tree branches fallen on lines at Various locations	-----
92		Gunrock	Tirumalagiri	11KV	C-VI	19.10	00.46	05.36	EL	Tree branches fallen on lines at Various locations	-----
93		R.P.Nilayam	Rythu Bazar	11KV	C-VI	18.56	22.16	03.20	EL	No Visible Fault (Due to rain)	-----
94		R.P.Nilayam	Vaishnavi Matha	11KV	C-VI	18.57	23.00	04.03	OL-Rph	Tree branches fallen on lines at Various locations	-----
95		R.P.Nilayam	Saraswathi Nagar	11KV	C-VI	18.58	21.25	02.27	EL,OL-Rph	Tree branches fallen on lines at Darga	-----
96		R.P.Nilayam	Venkatapuram	11KV	C-VI	19.02	23.00	03.58	EL,OL-Bph	No Visible Fault (Due to rain)	-----
97		R.P.Nilayam	Alwal	11KV	C-VI	19.04	23.04	04.00	EL,OL-Rph	Tree branches fallen on lines at Alwal	-----
98		Tirumalagiri	Srinagar Colony	11KV	C-VI	19.16	22.55	03.39	EL,OL	Flexi fallen on lines at Srinagar Colony & faulty 1No. DTR	-----
99		R.P.Nilayam	Naga Devatha	11KV	C-VI	18.58	05.35	10.37	EL	Tree branches fallen on lines at Various locations & Jumper cut at Naga Devatha Temple	-----
100		Gunrock	A.W.H.O.	11KV	C-VI	19.10	22.15	03.05	EL,OL-Bph	Tree branches fallen on lines at A.W.H.O. Colony	-----
101		Marredpally	Miliatary Hospital	11KV	C-VI	19.05	00.00	04.55	EL,OL	Still	-----
102		Marredpally	A.O.C.	11KV	C-VI	19.05	00.00	04.55	EL,OL	Still	-----
103		Marredpally	R.K.Puram	11KV	C-VI	19.10	00.00	04.50	EL,OL-Y&Bph	Still	-----
104		Road No.2	E-Seva	11KV	X	19.20	20.32	01.12	OL-R&Yph	Tree branches fallen on lines at Road No.7	-----
105		MLA Colony	Lotus Pond	11KV	X	19.12	21.55	02.43	EL,OL	Tree branches fallen on lines at K.R.Venket Reddy's House	-----
106		MLA Colony	Cine Ghar	11KV	X	19.14	21.43	02.29	EL,OL	Banner fallen on lines at Road No.12	-----
107		Yellareddyguda	Maruthi Nagar	11KV	X	19.10	20.14	01.04	EL	Tree branches fallen on lines at Maruthi Nagar	-----
108		Muffakamja College	Meridian	11KV	X	19.15	20.45	01.30	EL	Tree branches fallen on lines at Road No.7	-----
1		Aliyabad	Sharadha College	11KV	III	19.19	20.48	01.29	EL	No Visible Fault (Due to rain)	-----
2		Panjasha	Panch Mohallah	11KV	III	19.19	20.26	01.07	EL,OL-Rph	No Visible Fault (Due to rain)	-----
3		Panjasha	Bibi Bazar	11KV	III	19.19	20.25	01.06	All Indication	No Visible Fault (Due to rain)	-----
4		C.R.P.F.	Jamal Banda	11KV	III	19.20	20.40	01.20	EL	No Visible Fault (Due to rain)	-----
5		Devi Bagh	Shivalayam	11KV	III	19.35	21.20	01.45	EL	No Visible Fault (Due to rain)	-----
6		Devi Bagh	Shalimar	11KV	III	19.38	22.15	02.37	EL,OL-Bph	Tree branches fallen on lines at MLA Pasha Khadri's House	-----
7		Devi Bagh	Edgah	11KV	III	19.40	21.15	01.35	EL	No Visible Fault (Due to rain)	-----
8		Khilwath	Khilwath	11KV	III	19.19	21.11	01.52	EL	No Visible Fault (Due to rain)	-----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
9	HYD S	Petlaburz	Hussaini Alam	11KV	III	19.20	20.21	01.01	EL	No Visible Fault (Due to rain)	-----
10		Petlaburz	Murali Nagar	11KV	III	19.20	20.21	01.01	EL	No Visible Fault (Due to rain)	-----
11		Ch' Baradari	ITI Colony	11KV	III	19.20	21.00	01.40	EL	Twisted Lines at Noor Masjid & Faulty loads of 11KV Ramnaspura fdr	-----
12		Ch' Baradari	Govt. Polytechnic	11KV	III	19.20	20.35	01.15	EL	Tree branches fallen on line & HT Jumper cut at Govt. Polytechnic	-----
13		Miralam	Kalapather	11KV	III	19.15	20.36	01.21	EL,OL-Bph	No Visible Fault (Due to rain)	-----
14		Miralam	Madina Masjid	11KV	III	19.21	20.33	01.12	EL,OL-Bph	No Visible Fault (Due to rain)	-----
15		Miralam	Zoo Park	11KV	III	19.24	20.30	01.06	EL,OL-Bph	No Visible Fault (Due to rain)	-----
16		Miralam	Ansari Road	11KV	III	19.25	21.05	01.40	EL	HT Line snapped at Iddle Hotel	-----
17		Miralam	Shaik-E-Masjid	11KV	III	19.27	20.30	01.03	EL	No Visible Fault (Due to rain)	-----
18		Kandikal Gate	Kandikal Gate	11KV	III	19.25	20.35	01.10	EL	No Visible Fault (Due to rain)	-----
19		Kandikal Gate	Phool Bagh	11KV	III	19.25	21.07	01.42	EL	No Visible Fault (Due to rain)	-----
20		Kandikal Gate	Naseeb Nagar	11KV	III	19.25	20.35	01.10	EL	No Visible Fault (Due to rain)	-----
21		Kandikal Gate	Gazimillath Colony	11KV	III	19.25	20.35	01.10	EL	No Visible Fault (Due to rain)	-----
22		Kandikal Gate	Saibaba Nagar	11KV	III	19.25	20.40	01.15	EL	No Visible Fault (Due to rain)	-----
23		Kandikal Gate	Indira Nagar	11KV	III	19.25	20.40	01.15	EL	No Visible Fault (Due to rain)	-----
24		Kandikal Gate	Rakshapuram	11KV	III	19.25	20.40	01.15	EL	No Visible Fault (Due to rain)	-----
25		Kandikal Gate	Ashamabad	11KV	III	19.25	20.40	01.15	EL	No Visible Fault (Due to rain)	-----
26		Ch' Baradari	ITI Colony	11KV	III	19.25	20.40	01.15	EL	No Visible Fault (Due to rain)	-----
27		Falaknuma	Fathima Nagar	11KV	III	19.18	21.02	01.44	EL,OL-Rph	No Visible Fault (Due to rain)	-----
28		Falaknuma	Aliyabad	11KV	III	19.19	20.40	01.21	EL,OL-Rph	HT Line snapped at Aliyabad	-----
29		Falaknuma	Ravindra Naik Nagar	11KV	III	19.20	21.07	01.47	EL,OL-Rph	Jumper cut at MCH Building	-----
30		Falaknuma	Falaknuma Palace	11KV	III	19.23	21.32	02.09	EL,OL-Rph	Tree branches fallen on lines at Opp. Seven Temple	-----
31		Kanchanbagh	Riyasath Nagar	11KV	III	19.16	21.48	02.32	OL-Bph	No Visible Fault (Due to rain)	-----
32		Asmangadh	Asmangadh	11KV	VIII	19.15	20.30	01.15	EL	No Visible Fault (Due to rain)	-----
33		Laxmi Nagar	Shankeshwar Bazar	11KV	VIII	19.19	22.45	03.26	EL	DTR fell down at Bhulaxmi Nagar	-----
34		Laxmi Nagar	Dhobi Ghat	11KV	VIII	19.21	22.47	03.26	OL-Bph	Pin Insulator flash over & Jumper cut at Mathru Sri Eng. College	-----
35		Laxmi Nagar	Laxmi Nagar	11KV	VIII	19.15	22.55	03.40	EL	HT Line snapped at Laxmi Nagar	-----
36		Malakpet B-Block	Anand Biscuit Factory	11KV	VIII	19.20	22.27	03.07	OL-Rph	Tree branches fallen on lines at Anand Biscuit Factory	-----
37		Malakpet	Komatiwadi	11KV	VIII	19.20	21.10	01.50	OL-R&Bph	No Visible Fault (Due to rain)	-----
38		Malakpet	MCH Colony	11KV	VIII	19.16	22.40	03.24	EL,OL-Bph	No Visible Fault (Due to rain)	-----
39		Chanchalguda	Chanchalguda	11KV	VIII	19.12	21.25	02.13	EL,OL-Rph	No Visible Fault (Due to rain)	-----
40		Moosarambagh	SBI Colony	11KV	VIII	19.10	23.00	03.50	EL,OL-Rph	No Visible Fault (Due to rain)	-----
41		Moosarambagh	Moosarambagh	11KV	VIII	19.12	21.07	01.55	OL-Rph	No Visible Fault (Due to rain)	-----
42		Moosarambagh	Shalivahana Nagar	11KV	VIII	19.15	23.30	04.15	OL-Bph	Tree branches fallen on lines at P.G.College	-----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
43		Moosarambagh	A.B.Colony	11KV	VIII	19.15	00.45	05.30	OL-Bph	Tree branches fallen on lines at A.B.Colony	-----
44		Moosarambagh	Dilsukh Nagar	11KV	VIII	19.15	22.40	03.25	EL	No Visible Fault (Due to rain)	-----
45		Moosarambagh	Dwarakapuram	11KV	VIII	19.15	21.25	02.10	OL-Rph	No Visible Fault (Due to rain)	-----
46		Teegalaguda	Shanker Nagar	11KV	VIII	19.19	23.00	03.41	EL	No Visible Fault (Due to rain)	-----
47		Asmangadh	Gadiannaram	11KV	VIII	19.10	23.33	04.23	EL	Faulty RMU at Gadiannaram	-----
48		Asmangadh	Shiva Ganga	11KV	VIII	19.11	00.10	04.59	EL	-----	Arranged B/F on 11KV P&T Colony fdr
49		Asmangadh	Tirumala Hills	11KV	VIII	19.12	21.30	02.18	EL	No Visible Fault (Due to rain)	-----
50		Asmangadh	Jaya Nagar	11KV	VIII	19.13	20.35	01.22	EL	No Visible Fault (Due to rain)	-----
51		Asmangadh	G.A.Bank Colony	11KV	VIII	19.15	22.22	03.07	EL	HT Jumper cut at Tiffin Centre	-----
52		Asmangadh	P&T Colony	11KV	VIII	19.16	21.27	02.11	EL	No Visible Fault (Due to rain)	-----
53		Asmangadh	Gowtham Nagar	11KV	VIII	19.17	22.35	03.18	EL	No Visible Fault (Due to rain)	-----
54		Asmangadh	Saidabad Colony	11KV	VIII	19.15	22.58	03.43	EL	No Visible Fault (Due to rain)	-----
55		Malakpet B-Block	Akber Bagh	11KV	VIII	19.17	01.20	06.03	OL-Rph	Tree branches fallen on lines at Various Locations	-----
56		Asmangadh	T.V.Station	11KV	VIII	19.15	20.30	01.15	EL	No Visible Fault (Due to rain)	-----
57		Teegalaguda	RTA Saleem Nagar	11KV	VIII	19.18	03.03	07.45	EL	Tree branches fallen on lines at RTA Office	-----
58		Laxmi Nagar	Singareni Colony	11KV	VIII	19.18	23.00	03.42	EL	-----	Arranged B/F on 11KV Shankeshwar Bazar fdr
59		Laxmi Nagar	Shankeshwar Bazar	11KV	VIII	23.51	02.30	02.39	All Indication	Cable Jumper cut at Shankeshwar Bazar	Arranged B/F on 11KV Saidabad Colony fdr
60		Gunj	Race Course	11KV	VIII	19.22	23.10	03.48	All Indication	Brass Patti burntout at Race Course	-----
61		Gunj	Judges Colony	11KV	VIII	19.25	01.08	05.43	All Indication	HT Line snapped at Indo-US Hospital	-----
62		Gunj	Palton	11KV	VIII	19.20	21.28	02.08	All Indication	Tree branches fallen on lines at Palton X Road	-----
63		Gunj	Hari Hara Skhetra	11KV	VIII	19.25	23.15	03.50	All Indication	-----	Arranged B/F on 11KV Race Course fdr
64		Gunj	Super Bazar	11KV	VIII	22.50	00.05	01.15	EL	LT Line snapped at Gunj Gate No.2	-----
65		Kanchanbagh	Owasi Hospital	11KV	VIII	20.40	00.19	03.39	EL,OL-Bph	No Visible Fault (Due to rain)	-----
66		Kanchanbagh	Kanchanbagh	11KV	VIII	19.15	21.12	01.57	OL-Bph	No Visible Fault (Due to rain)	-----
67		Kanchanbagh	Darga	11KV	VIII	19.17	21.11	01.54	OL-Bph	No Visible Fault (Due to rain)	-----
68		Womens College	Esamiya Bazar	11KV	IX	19.21	20.35	01.14	EL,OL	No Visible Fault (Due to rain)	-----
69		Osm. Hospital	Gowliguda	11KV	IX	19.15	21.20	02.05	All Indication	Tree branches fallen on lines at Osm.Hospital	-----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
70		Osm. Hospital	Osmangunj	11KV	IX	19.15	21.20	02.05	All Indication	Tree branches fallen on lines at Osm.Hospital	-----
71		Womens College	Quthbiguda	11KV	IX	19.09	20.31	01.22	EL	No Visible Fault (Due to rain)	-----
72		Vittalwadi	Ramkoti	11KV	IX	19.12	21.22	02.10	All Indication	Tree branches fallen on lines at Ganesh Temple	-----
1		Narayanguda	City Central Library	11KV	I	19.10	23.00	03.50	EL	Tree branches fallen on lines at Various Locations	-----
2		Jawahar Nagar	Balaji Indra Prastha	11KV	I	19.15	20.20	01.05	EL	No Visible Fault (Due to rain)	-----
3		Jawahar Nagar	Ashok Nagar	11KV	I	19.15	20.45	01.30	EL	No Visible Fault (Due to rain)	-----
4		Jawahar Nagar	Jawahar Nagar	11KV	I	19.16	22.05	02.49	EL	No Visible Fault (Due to rain)	-----
5		Jawahar Nagar	Bank of Baroda	11KV	I	19.16	22.50	03.34	EL	HT Pole damaged at S.B.I.	-----
6		Jawahar Nagar	Anjaiah Bhavan	11KV	I	19.16	20.25	01.09	EL	No Visible Fault (Due to rain)	-----
7		Jawahar Nagar	J.N.Home	11KV	I	19.17	23.50	04.33	EL	Tree branches fallen on lines at J.N.Home	-----
8		Jawahar Nagar	Post Office	11KV	I	19.23	22.18	02.55	EL	No Visible Fault (Due to rain)	-----
9		Nizam College	Brand Factory	11KV	I	19.15	23.24	04.09	OL	No Visible Fault (Due to rain)	-----
10		Nizam College	Galaxy Hotel	11KV	I	19.21	22.50	03.29	EL,OL-Rph	Banner fallen on lines at Galaxy Hotel	-----
11		Nizam College	Rosary Convent	11KV	I	19.22	21.28	02.06	EL,OL-Rph	No Visible Fault (Due to rain)	-----
12		Indira Park	Talla Basthi	11KV	I	19.30	22.00	02.30	EL	Tree branches fallen on lines at Talla Basthi	-----
13		Indira Park	Domalguda	11KV	I	19.30	22.30	03.00	EL,OL-Rph	Tree branches fallen on lines at Domalguda	-----
14		Indira Park	Gulshan Nagar	11KV	I	19.25	21.30	02.05	EL	Tree branches fallen on lines at Gulshan Nagar	-----
15		Indira Park	Kuchipudi	11KV	I	19.30	23.55	04.25	EL	HT Line snapped at Kuchipudi	-----
16		Vittalwadi	Commissioner Office	11KV	I	19.12	21.56	02.44	EL	Tree branches fallen on lines at Commissioner Office	-----
17		Chilkalguda	Musheerabad	11KV	I	19.19	22.10	02.51	EL	No Visible Fault (Due to rain)	-----
18		Industrial Area	Vidya Nagar	11KV	II	19.05	22.30	03.25	All Indication	Pole fell down at Blood Bank	-----
19		Bathkammakunta	D.D.Colony	11KV	II	19.15	22.45	03.30	EL,OL-Yph	Tree branches fallen on lines at Andhra Bank	-----
20		Bathkammakunta	Shivam	11KV	II	19.10	23.55	04.45	EL	Tree branches fallen on lines at Ratnadeep Super Market	-----
21		Bathkammakunta	Ahobimutt	11KV	II	19.10	22.20	03.10	OL-Rph	Tree branches fallen on lines at Hotel Management	-----
22		Bathkammakunta	Ramalayam	11KV	II	19.10	20.50	01.40	EL,OL-Rph	Tree branches fallen on lines at Ramalayam	-----
23		Bathkammakunta	Ayyappa Temple	11KV	II	19.15	20.30	01.15	EL	No Visible Fault (Due to rain)	-----
24		Bathkammakunta	Saibaba Temple	11KV	II	19.15	20.25	01.10	EL,OL	No Visible Fault (Due to rain)	-----
25		Bathkammakunta	C.E.Colony	11KV	II	19.15	20.52	01.37	EL,OL	No Visible Fault (Due to rain)	-----
26		Narayanguda	Chikkadpally	11KV	II	19.05	21.00	01.55	EL	No Visible Fault (Due to rain)	-----
27		Narayanguda	Preventive Medicine	11KV	II	19.10	22.00	02.50	EL	Tree branches fallen on lines at Reddy College	-----

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
28	HYD C	Narayanguda	Narayanguda	11KV	II	19.10	22.30	03.20	EL	Tree branches fallen on lines at Kallu Compound	-----
29		Zamistanpur	Jamia Osmania	11KV	II	19.10	21.20	02.10	EL	Tree branches fallen on lines at Jamia Osmania	-----
30		Zamistanpur	L.N.Nagar	11KV	II	19.14	23.02	03.48	OL	Twisted lines at Pullaiah Bavi	-----
31		Zamistanpur	Balaji Nagar	11KV	II	19.14	23.45	04.31	EL	Cloth fallen on lines at Amber Nagar	-----
32		Fever Hospital	Nalla Kunta	11KV	II	19.05	00.00	04.55	EL	Tree branches fallen on lines at Various Locations	-----
33		Fever Hospital	Tourist Hotel	11KV	II	19.10	21.30	02.20	EL	Tree branches fallen on lines at Various Locations	-----
34		Fever Hospital	Fever Hospital	11KV	II	19.10	22.45	03.35	EL	Tree branches fallen on lines at Various Locations	-----
35		Fever Hospital	C.C.S.Hospital	11KV	II	19.12	21.35	02.23	EL	Tree branches fallen on lines at Various Locations	-----
36		Fever Hospital	Sri Ram Nagar	11KV	II	19.13	23.30	04.17	EL	Tree branches fallen on lines at Various Locations	-----
37		Fever Hospital	BKP Bus Depot	11KV	II	19.14	22.35	03.21	EL	Tree branches fallen on lines at Various Locations	-----
38		Industrial Area	Barkathpura	11KV	II	19.13	23.20	04.07	EL	Tree branches fallen on lines at Various Locations	-----
39		Industrial Area	R.O.M.	11KV	II	19.10	20.40	01.30	EL	Tree branches fallen on lines at R.O.M.	-----
40		Industrial Area	RTC X Road	11KV	II	19.10	21.40	02.30	EL	LT Line snapped at VST	-----
41		Industrial Area	Azamabad I.E.	11KV	II	19.13	22.15	03.02	EL	No Visible Fault (Due to rain)	-----
42		Industrial Area	D.D.H.	11KV	II	19.20	21.55	02.35	EL	No Visible Fault (Due to rain)	-----
43		Golnaka	Kamala Nagar	11KV	II	19.16	20.19	01.03	EL	No Visible Fault (Due to rain)	-----
44		Golnaka	Brahman Hostel	11KV	II	19.14	20.28	01.14	OL	No Visible Fault (Due to rain)	-----
45		Golnaka	Shivalayam	11KV	II	19.16	21.02	01.46	EL,OL-Rph	No Visible Fault (Due to rain)	-----
46		Golnaka	Sai Madhura Nagar	11KV	II	19.16	21.03	01.47	OL	No Visible Fault (Due to rain)	-----
47		Golnaka	Nehru Nagar	11KV	II	19.08	21.07	01.59	EL,OL	Banner fallen on lines at Nehru Nagar	-----
48		Vittalwadi	APCO	11KV	II	19.10	22.50	03.40	EL,OL-Y&Bph	Tree branches fallen on lines at Narayanguda Water Works	-----
49		Vittalwadi	Gandhi Kutter	11KV	II	19.10	22.58	03.48	EL,OL-Y&Bph	Tree branches fallen on lines at Narayanguda PS	-----
50	Vittalwadi	Y.M.C.A.	11KV	II	19.12	21.36	02.24	EL,OL-Y&Bph	Tree branches fallen on lines at Blood Bank	-----	
51	Vittalwadi	Basanth Colony	11KV	II	19.14	20.50	01.36	EL,OL-Y&Bph	Flexi fallen on lines at Basanth Colony	-----	
52	Osm. University	Boudha Nagar	11KV	II	19.14	22.00	02.46	OL-Rph	Tree branches fallen on lines at Various Locations	-----	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
53		Amberpet	Amberpet	11KV	II	19.18	21.45	02.27	EL,OL-Y&Bph	No Visible Fault (Due to rain)	-----
54		Amberpet	Play Ground	11KV	II	19.19	21.30	02.11	EL	No Visible Fault (Due to rain)	-----
55		Amberpet	6 No.	11KV	II	19.22	21.40	02.18	EL,OL-Rph	No Visible Fault (Due to rain)	-----
56		Amberpet	Patel Nagar	11KV	II	19.22	21.45	02.23	EL	No Visible Fault (Due to rain)	-----
57		Amberpet	Golnaka	11KV	II	19.22	21.05	01.43	EL	No Visible Fault (Due to rain)	-----
58		Amberpet	Sanjeevaiah Nagar	11KV	II	19.25	21.20	01.55	EL,OL-Bph	No Visible Fault (Due to rain)	-----
59		Amberpet	Patel Nagar	11KV	II	23.18	00.50	01.32	EL	No Visible Fault (Due to rain)	-----
60		Chilkalguda	Parsigutta	11KV	II	19.10	21.50	02.40	EL	No Visible Fault (Due to rain)	-----
61		Chilkalguda	44 Bus Stop	11KV	II	19.16	21.13	01.57	EL	No Visible Fault (Due to rain)	-----
62		Chilkalguda	Golconda X Road	11KV	II	19.18	20.48	01.30	EL	No Visible Fault (Due to rain)	-----
63		Langerhouse	Prashanth Nagar	11KV	VII	19.25	20.30	01.05	EL	LT Pole damaged at Prashanth Nagar	-----
64		ITI Mallepally	V.B.R.I.	11KV	VII	20.15	22.10	01.55	EL,OL	Cable fault & tree branches fallen on lines at ITI College	-----
65		Asif Nagar	NSF Colony	11KV	VII	19.15	21.40	02.25	EL,OL-Rph	Faulty DTR at NSF Colony	-----
66		Asif Nagar	Military	11KV	VII	19.15	20.50	01.35	EL,OL-Rph	Tree branches fallen on lines at Military Area	-----
67		Asif Nagar	Jyothi Nagar	11KV	VII	19.25	21.28	02.03	EL,OL-Rph	Tree branches fallen on lines at Jyothi Nagar	-----
68		Asif Nagar	Kakatiya Hills	11KV	VII	19.32	20.54	01.22	EL,OL-Rph	No Visible Fault (Due to rain)	-----