

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		11		11		11			
	Total	606	3055	0	15	0	15	0	15	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		16		16		16			
2	NLG	144	988	2	8	2	8	2	8			
3	MDK	107	933		10		10		10			
4	SDPT			2	3	2	3	2	3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	37	4	37	4	37	0	0	
	Grand Total	1082	6468	4	52	4	52	4	52	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.04.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Yerrabelli	Kannekal	33KV	Miryalaguda	18.10	19.10	01.00		Conductor melt	Kannekal	-
2		Shantinagar	Akupamula	33KV	Huzurnagar	06.00	11.00	05.00		Due to 33Kv Jumper cutted	Akupamula	-
1	SDP	Husnabad	Thotapally	33KV	Husnabad	17.45	19.25	01.40		BD Jumper cut	Thotapally	-
2		Thukkapur	Lingapur	33KV	Gajwel	00.35	05.15	04.40		BD Conductor snapped	Lingapur	-

TSSPDCL - LMRC / Corporate office

Date: 23.04.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Hanwada	Peddadarpally	11KV	Mahabubnagar	03.30	11.42	08.12		11KV pole damage at peddadarally (Vi) 1	-
2		Narva	Lankal	11KV	Mahabubnagar	16.20	19.00	02.40		11KV Tree fallen on conductor at Kumarlingam pally (Vi)	-
3		Waddeman	Nellikondi	11KV	Mahabubnagar	15.10	21.54	06.44		11KV Tree fallen on conductor Near Nellikondi (Vi)	-
4		Serivenkatapur	Suraram	11KV	Mahabubnagar	05.45	11.00	05.15		11KV Tree fallen on conductor Near Suraram&pole damage (Vi) 1	-
5		Abhangapatnam	Abhangapatnam	11KV	Mahabubnagar	16.00	18.30	02.30		11KV pole damage at Abhangapatnam (Vi) 2	-
6		Kodur	Kodur	11KV	Mahabubnagar	15.45	20.00	04.15		11KV Tree fallen on conductor Near Kodur (Vi)	-
7		Kodur	Kodur	11KV	Mahabubnagar	06.00	09.45	03.45		11KV Jumper cut at kodur (vi)	-
8		Kodur	Zamistapur	11KV	Mahabubnagar	15.45	22.40	06.55		11KV Jumper cut at Zamistapur (vi)	-
9		Kodur	Boklonipally	11KV	Mahabubnagar	15.45	20.00	04.15		11KV Jumper cut at Zamistapur& pole damage2 at Boklonipally (vi)	-
10		Kodur	Dharmapur	11KV	Mahabubnagar	15.45	20.30	04.45		11KV Jumper cut at Zamistapur& pole damage4 at Dharmapur (vi)	-
11		S V S	Bhootpur(TG)	11KV	Mahabubnagar	00.00	06.00	06.00		11KV Tree fallen on conductor at Pole damage3 at(Vi)	-
12		S V S	Yenugonda	11KV	Mahabubnagar	19.00	20.00	01.00		11KV Tree fallen on conductor at Pole damage4 at Yenugonda(Vi)	-
13		Yedira	Divitipally	11KV	Mahabubnagar	04.00	11.30	07.30		11KV Tree fallen on conductor at Pole damage3 at Divitipally(Vi)	-
14		K C R Road	Chinnadarpally	11KV	Mahabubnagar	13.05	14.48	01.43		11KV Tree fallen on conductor at Pole damage1 Venkatapur(Vi)	-
15		Janampet	Polkampally	11KV	Mahabubnagar	08.45	11.35	02.50		BD due to 11 KV wire cut near Polkampally (v)	-
16		Janampet	Annasagar	11KV	Mahabubnagar	06.05	10.17	04.12		BD due to 11 KV insulater fail near Polkampally (v)	-
1	NLG	Edulagudem	Yadgarpally	11KV	Miryalaguda	09.30	12.50	03.20	EL	11KV jumper cut	-
2		Haliya	Thirumalagiri	11KV	Miryalaguda	12.00	13.52	01.52	EL	Jumper cut	-
3		Shettipalem	Shettipalem-2	11KV	Miryalaguda	06.40	07.55	01.15	EL	11KV jumper cut	-
4		Guntipally	Guntipally	11KV	Miryalaguda	04.00	08.20	04.20	EL	Insulater failed	-
5		Ravulapally	Ravulapally	11KV	Suryapet	07.00	09.20	02.20	EL	Conductor snapped	-
6		Akupamula	Akupamula Agl	11KV	Huzurnagar	18.00	20.20	02.20	EL	Jumper cutted	-
7		Dirsincherla	Chillepally	11KV	Huzurnagar	01.00	03.00	02.00	EL	Jumper cutted	-
8		Varkatpally	Gokaram	11KV	Choutuppal	10.00	12.01	02.01	EL	11kv Line Snapped Near Gokaram Village	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MDK	Bonthapally	Swamy	11KV	Patancheru	09.12	10.32	01.20		B/D Due to Conductor Snapped and 2 Nos Pole Damaged	-
2		Bonthapally	Veerabadra	11KV	Patancheru	09.12	10.32	01.20		B/D Due to Conductor Snapped and 2 Nos Pole Damaged	-
3		Bonthapally	Newland	11KV	Patancheru	06.20	09.50	03.30		B/D Due to Conductor Snapped and 1 Nos Pole Damaged	-
4		Gummadidala	Agrobell	11KV	Patancheru	01.00	12.30	11.30		B/D Due to 2Nos Insulator Failure Due to Heavy wind and Rain	-
5		Gummadidala	Bell Remedies	11KV	Patancheru	01.00	12.30	11.30		B/D Due to 1Nos Insulator Failure Due to Heavy wind and Rain	-
6		Gundla Machnoor	Industrial	11KV	Jogipet	18.00	23.00	05.00		B/D Due to tree Branches fallen on the line	-
7		Athmakur	Athmakur	11KV	Sangareddy	09.00	10.15	01.15		B/D Due to Conductor Snapped	-
8		Sadasivapet	TSM	11KV	Sangareddy	12.05	13.55	01.50		B/D Due to Phase to phase near Peddapur	-
9		Cheryal	Kalivemula	11KV	Sangareddy	06.45	12.25	05.40		B/D Due to EL & OL no falt found	-
10		Cheryal	Julkal	11KV	Sangareddy	07.00	09.30	02.30		B/D Due to pin insulator burst at Rajastan Dhaba Opp	-
1	SDP	Thotapally	Thotapally	11KV	Husnabad	15.00	18.00	03.00		BD Conductor snapped	
2		Dharmaram	Dharmaram(R.)	11KV	Husnabad	21.05	21.25	00.20		BD Jumper cut	
3		Pandilla	Potlapally	11KV	Husnabad	05.35	08.10	02.35		BD Jumper cut	
1	RR N	Nizampet	Bandri lay out	11KV	Kukatpally	09.40	10.40	01.00	OL	11kv Jumper Cu t & 11kv Line Phase To Phase Road No -9 Bandrilay Out	-
2		Somashila	Ramalayam	11KV	Kukatpally	15.45	18.15	02.30	EL	11kv Endy Kit Failure At Chaitany collage	-
1	RR E	Sai Nagar	RNS Colony	11KV	Habsiguda	09.45	11.05	01.20		Line patrolling but no visible fault	-
2		Moulali	Malkaigiri	11KV	Sainikpuri	23.00	23.40	00.40		11KV Polymer Disc Failed at RTC Colony Near Second Bus Stop	-
1	HYD N	Gunrock	Anjaiah Nagar	11KV	VI	02.20	06.00	03.40	All Indication	Tree branches fallen on lines at Anjaiah Nagar	-
2		Osm. University	Keshava Nagar	11KV	V	04.30	07.35	03.05	OL-Rph	Jumper cut and fallen on Clamp	-
3		Hakimpet	Allenby Lines	11KV	C-VI	07.15	10.00	02.45	EL	Tree branches fallen on lines at BSNL Office	-
4		Bowenpally	Jaya Nagar	11KV	VI	09.40	10.45	01.05	EL	Tree branches fallen on lines at Picket	-
5		Gunrock	Anjaiah Nagar	11KV	VI	13.35	16.00	02.25	OL-R&Yph	Coconut tree branches fallen on lines at RTC Colony	-
6		Gunrock	Medchal	11KV	C-VI	14.00	15.10	01.10	EL	No Visible Fault	-
1	HYD S	Panjasha	Asra Hospital	11KV	III	03.14	05.11	01.57	EL,OL-Rph	Jumper cut at Asra Hospital	-
2		Khilwath	Charminar	11KV	III	07.22	08.31	01.09	EL,OL-Rph	Cat fallen on DTR & Jumpers cut at Gowtham School	-
1	HYD C	Amberpet	Patel Nagar	11KV	II	02.00	03.02	01.02	EL,OL-Yph	Jumper cut at Ali Café	-
2		Amberpet	C.P.L	11KV	II	20.20	22.15	01.55	EL	Tree branches fallen on lines & Jumper cut at C.P.L X-Roads	-
3		Bathkammakunta	Ayyappa Temple	11KV	II	22.23	23.30	01.07	EL,OL-Rph	Tree branches fallen on lines at Satya Sai School	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
------	--------	-----------------------	-------------------------	-----	-------------------------	------	----	----------	---------------------	--------------------	------------------------------