

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No. of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | 2 | | 2 | | 2 | | | | |
| 7 | RR(E) | 168 | 403 | | | | | | | | | |
| 8 | Hyd | 194 | 1044 | | 2 | | 2 | | 2 | | | |
| | Total | 606 | 3055 | 2 | 2 | 2 | 2 | 2 | 2 | 0 | 0 | |

Rural

| S.No | Circle | No. of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|--------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | | | | | | | | | |
| 2 | NLG | 144 | 988 | | 3 | | 3 | | 3 | | | |
| 3 | MDK | 107 | 933 | 2 | 2 | 2 | 2 | 2 | 2 | | | |
| 4 | SDPT | | | | 2 | | 2 | | 2 | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 2 | 7 | 2 | 7 | 2 | 7 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 4 | 9 | 4 | 9 | 4 | 9 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 27.04.2019

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|-----------------------|-----------------------|---------------------------|
| 1 | MDK | Kandi | SKOL | 33KV | Sangareddy | 11.50 | 18.00 | 06.10 | | B/D Due to Jumper Cut | SKOL | - |
| 2 | | Kandi | Aradhana | 33KV | Sangareddy | 11.50 | 18.00 | 06.10 | | B/D Due to Jumper Cut | Aradhana | - |
| 1 | RR N | 132KV Malkaram | 33KV Rathnalayam | 33KV | Medchal | 05.45 | 08.05 | 02.20 | BD | No Visible Fault | 33KV Rathnalayam | - |
| 2 | | 132KV Malkaram | 33KV Shameerpet | 33KV | Medchal | 05.45 | 08.05 | 02.20 | BD | No Visible Fault | 33KV Shameerpet | - |

TSSPDCL - LMRC / Corporate office

Date: 27.04.2019

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|--|
| 1 | NLG | Koppole (K) | Koppole (K) | 11KV | Nalgonda | 13.10 | 15.30 | 02.20 | E/L | Moment fault | - |
| 2 | | Penpahad | Annaram | 11KV | Suryapet | 06.50 | 08.30 | 01.40 | E/L | Insulator failed | - |
| 3 | | Raghunadapalem | Gundlapally | 11KV | Huzurnagar | 07.00 | 10.00 | 03.00 | EL | Due to 11Kv line cutted | - |
| 1 | MDK | EPIP-I | kirby | 11KV | Sangareddy | 11.55 | 12.40 | 00.45 | | B/D Due to tree branch fallen on the line | - |
| 2 | | EPIP-I | Newland(old) | 11KV | Sangareddy | 00.00 | 04.00 | 04.00 | | B/D Due to Conductor Snapped | - |
| 1 | SDP | Regulapally | Regulapally | 11KV | Siddipet | 00.00 | 09.19 | 09.19 | | Insulator failed same rectified | - |
| 2 | | Mustyal | Mustyal | 11KV | Siddipet | 08.40 | 10.35 | 01.55 | | Line snapped same rectified | - |
| 1 | HYD S | Hyderguda | Janapriya AB Cable | 11KV | III | 17.30 | 21.20 | 03.50 | OL | Cable Fault | Arranged B/F on 11KV Weeker Section Colony & Janapriya OH fdrs |
| 1 | HYD C | Amberpet | Play Ground | 11KV | II | 14.30 | 15.50 | 01.20 | EL | Tree branches fallen on lines at 6th Apartment | - |