

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044	1		1		1				
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	9		5		5		4		4 Nos 33KV Feeder stil
2	NLG	144	988	2	6	2	6	2	6			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>11</b>	<b>6</b>	<b>7</b>	<b>6</b>	<b>7</b>	<b>6</b>	<b>4</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>12</b>	<b>7</b>	<b>8</b>	<b>7</b>	<b>8</b>	<b>7</b>	<b>4</b>	<b>0</b>	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Dudyal	33KV	Vikarabad	19.05	22.30	03.25	E/L	Due to Heavy Rain & Gale, Wind		Alternate supply arranged form 33KV Kosgi
2		Kodangal	Kodangal	33KV	Vikarabad	21.15	21.30	00.15	E/L	Due to Heavy Rain & Gale, Wind ,Poles Damaged		Alternate Supply Arranged form 33KV Peddanadigama
3		Gadwal	RWS	33KV	Gadwal	17.58	19.55	01.57	E/L	Due to Heavy Rain & Gale, Wind		Alternate Supplay Arranged form 33KV Nandinne
4		Gadwal	Bijwaram	33KV	Gadwal	22.50		01.10	E/L	Due to Heavy Rain & Gale, Wind		No
5		Nagarkurnool	Nagarkurnool	33KV	Nagarkurnool	18.05	18.10	00.05	E/L	Due to Heavy Rain & Gale, Wind ,Poles Damaged		Alternate supply arranged from 33KV Ithole
6		Nagarkurnool	Bijinapally	33KV	Nagarkurnool	19.04		04.56	E/L	Due to Heavy Rain & Gale, Wind ,Poles Damaged		NO
7		Nagarkurnool	Manthathi	33KV	Nagarkurnool	15.45		08.15	E/L	Due to Heavy Rain & Gale, Wind ,Poles Damaged		NO
8		Nagarkurnool	Rakonda	33KV	Nagarkurnool	18.50	20.00	01.10	E/L & O/L	Due to Heavy Rain & Gale, Wind ,Poles Damaged		Breakdown Alternate supply arranged from 33KV Uppunuthala
9		Nagarkurnool	Tadoor	33KV	Nagarkurnool	18.20		05.40	E/L & O/L	Due to Heavy Rain & Gale, Wind ,Poles Damaged		NO
1	NLG	Bibinagar	Bollepally	33KV	Bhongir	16.48	18.45	01.57	OL	33 kv Discs Failed at BNR Stone Crushers Near Gurraladandi Sub Station		-
2		Choutuppal	Narayanapur	33KV	Choutuppal	11.30	12.25	00.55	OL	33 kv Lightining Arrester Failed at 33 KV Sarvel Sub Station		-
1	HYD C	132KV Asif Nagar	Seetharambagh	33KV	Asif Ngr	09.45	09.50	00.05	OL-Bph	UG Cable fault	132KV Asif Nagar	Loads tranferred onto 132KV Imlibun SS via 33KV Gosha Mahal SS

## TSSPDCL - LMRC / Corporate office

Date: 30.04.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Durajapally	Vallabhapuram	11KV	Suryapet	09.45	12.20	02.35	E/L	Conductor snapped	-
2		BNL Thanda	Pathanda	11KV	Huzurnagar	07.00	09.00	02.00	E/L	11 KV Jumper cut	-
3		Kodad indoor	Komarabanda indl	11KV	Huzurnagar	06.45	08.15	01.30	E/L	11 KV LINE SNAPPED	-
4		Ananthagiri	V R Puram	11KV	Huzurnagar	07.00	08.20	01.20	E/L	11 KV LINE SNAPPED	-
5		Peddapadishala	Bandakothapally	11KV	Bhongir	06.30	10.00	03.30	E/L	11 KV Line Snapped & Bird Fallen at Line Near Bandakothapally Village.	-
6		Sangem	Sangem	11KV	Choutuppal	03.34	08.23	04.49	E/L	11 kv Jumper Cut Near Sangem Village.	-
1	RR N	DP Pally	IDA	11KV	Jeedimetla	16.25	17.25	01.00	BD	11KV Line Cut near HP Petrol Pump Outer Ring Road	-