

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	



## TSSPDCL - LMRC / Corporate office

Date: 01.02.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Velugupally	Velugupally	11KV	Suryapet	08.00	10.50	02.50	E/L	11KV Line melt(HT/LT)	-
2		Gaddipally	Gaddipally	11KV	Huzurnagar	06.40	09.25	02.45	E/L	Due to Tree branch	-
1	SDPT	Pandilla	Kuchanpally	11KV	Husnabad	11.50	12.20	00.30		Line Cutting	
2		Shanigaram	Shanigaram Rural	11KV	Husnabad	04.40	09.00	04.20		Jumper cutting	
1	RR N	UMCC	Sriram Nagar	11KV	Medchal	16.35	17.55	01.20	BD	11KV Cable End kit failed at Sriram Nagar	-
1	RR E	Moula-Ali	Moula-Ali	11KV	Sainikpuri	04.02	05.20	01.18		Car Dashed on 11Kv Pole Broken at Moula-Ali JTC Main Road (AE/OP)	-
2		Moula-Ali	FBP	11KV	Sainikpuri	06.00	13.40	07.40		Car Dashed on 11Kv Pole Broken at Moula-Ali JTC Main Road (AE/OP)	-
1	HYD C	Zamistanpur	Jamai Osmania	11KV	Azamabad	07.44	09.03	01.19	EL,OL-R&Bph	HT Line snapped at Jamai Osmania	-