

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		4		4		4			
3	MDK	107	933	1		1		1				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	4	1	4	1	4	0	0	
	Grand Total	1082	6468	1	5	1	5	1	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 03.02.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Bollaram	Bollaram - II	33KV	Patancheru	19.05	20.35	01.30		BD due to Jumper cut near 132KV SS	Bollaram - II	-

TSSPDCL - LMRC / Corporate office

Date: 03.02.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Koppole(K)	Bheemaram	11KV	Nalgonda	11.30	14.45	03.15	E/L	11KV Jumper cut	-
2		Gaddipaly	Gaddipally agl	11KV	Huzurnagar	05.30	08.37	03.07	E/L	11Kv line snapped	-
3		Rjavaram	Juvvichettu Thanda	11KV	Miryalguda	07.45	10.20	02.35	E/L	11Kv Line snapped at Nadigadda,	-
4		Athmakur(S)	Gottimukkalagudem	11KV	Suryapet	09.30	12.00	02.30	E/L	Insulator failed	-
1	RR N	Subhash Nagar	Bank colony	11KV	Medchal	07.45	08.26	00.41	BD	11KV Cable Failed (Backfeeding to 11KV Sai Baba Nagar feeder)	-