

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>0</b>	



TSSPDCL - LMRC / Corporate office

Date: 06.02.19

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	G.T Giri	Bakthalapuram	11KV	Suryapet	7:30	10:50	3:20	E/L	Insulator flashover	No
2		Garideppaly	L B Nagar	11KV	Huzurnagar	23.30	01.30	02.00	EL	11 KV Jumper cut	No
3		Mattapally	Mattapally town	11KV	Huzurnagar	12.10	15.10	03.00	EL	11 KV Jumper cut	No
4		Aroor	Lingarajupally	11KV	Choutuppal	09.05	10.45	01.40	EL	HT/LT Near Muddapuram Village	No
1	RR N	Petbasheerabad	Satyam Enclave	11KV	Medchal	17:55	19:35	1:40		Stay wire fallen on the 11KV line near SS	No
1	HYD C	A.S.R.Raju Nagar	Ushodaya Colony	11KV	Mehdipatnam	14.40	16.10	01.30	EL,OL	Cable fault & removed loads of 11KV Padmanabha Nagar feeder	No