

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044	1		1		1				
	Total	606	3055	1	2	1	2	1	2	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	4	0	4	0	4	0	0	
	Grand Total	1082	6468	1	6	1	6	1	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 10.02.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	HYD N	132KV Madhapur	Deva Bhoomi Phase-3	33KV	Kalyan Ngr	00.35	07.54	07.19	EL,OL	Cable damaged by GHMC (HMWS) while digging at Madhapur	Deva Bhoomi Phase-3	-

TSSPDCL - LMRC / Corporate office

Date: 10.02.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Bhoothpur	Rural	11KV	Jadcherla	08.40	11.30	02.50		B.D. 11 Kv Wire Cut Near Goplapur(Vi).	-
1	NLG	Velugupally	Keshavapuram	11KV	Suryapeta	10.30	11.40	01.10	E/L	Bird fallen on the line	-
2		Pamanagundla	Pittampally	11KV	Nalgonda	07.30	10.30	03.00	E/L	Insulator failure	-
3		Gaddipally	Khudabakshapuram	11KV	Huzurnagar	12.15	15.00	02.45	E/L	11KV Line Snapped	-
1	RR N	Petbasheerabad	Balaji Hospital	11KV	Medchal	01.00	03.00	02.00		11KV Cable failed Agatpet Govt School	-
2		Subhash Nagar	Jayaram nagar	11KV	Medchal	02.10	05.10	03.00		11KV Breakar Problem in SS	-