

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		7		7		7			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	7	0	7	0	7	0	0	
	Grand Total	1082	6468	0	10	0	10	0	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 11.02.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Dirsincherla	Dirsincherla	11KV	Huzurnagar	04.30	08.00	03.30	EL	Due to 11Kv jumper cutted	-
2		Huzurnagar	Town-1	11KV	Huzurnagar	22.35	23.47	01.12	EL	Due to 01 No pole damged	-
3		Turkapally	Turkapally	11KV	Nalgonda	10.54	12.20	01.26	E/L	11KV Insulator failed	-
4		Pamanagundla	A.P.Lingotam	11KV	Nalgonda	08.21	10.36	02.15	E/L	11Kv line cut at near by village	-
5		Eduloor	Parada	11KV	Nalgonda	06.36	11.20	04.44	E/L	11KV Insulator failed	-
6		Kothapally	Peruvala	11KV	Devarakonda	11.45	13.00	01.15	E/L	Jumper Cutt	-
7		Rajapeta	Namela	11KV	Bhongiri	04.00	09.15	05.15	E/L	Tree Branchess Fallen at line & 11kv Jumper Cut Near Pittalagudem Village 3 Phase B/d Single Phase Ok	-
1	RR E	Keesara	Cheeryala	11KV	Keesara	11.35	13.30	01.55		15KVA T/F failed at Vikalangula Colony	-
1	HYD S	Panjasha	Metharwadi	11KV	Charminar	09.00	10.30	01.30	All Indication	Line snapped at Metharwadi Temple	-
2		Kandikalgate	Patel Nagar	11KV	Charminar	12.10	14.15	02.05	EL,OL	Cable fault at Patel Nagar	-