

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044	1		1		1				
	Total	606	3055	1	0	1	0	1	0	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988	1	5	1	5	1	5			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	7	2	7	2	7	0	0	
	Grand Total	1082	6468	3	7	3	7	3	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 13.02.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Nawabpet	33KV	Mahabubnagar	11.38	12.23	00.45	EL	Pin insulator failed and isolator opens from 33KV Kotha Chervu road SS to 33KV Avangapatnam SS	Nawabpet	No
1	NLG	Dilchinchera	Mukundapuram	33KV	Huzurnagar	12:00	15:40	3:40	E/L	33KV Conductor snapped	Dilchinchera	No
1	HYD N	132KV Gunrock	Bhudevi Nagar	33KV	Nehru Nagar	13.05	13.13	00.08	EL,OL-Yph	Cable fault	Bhudevi Nagar	Loads transferred on to 33KV Gunrock-HMT

TSSPDCL - LMRC / Corporate office

Date: 13.02.19

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Tirumalapur	Dondlapally	11KV	Jadcherla	05.50	11.08	05.18		11KV Pin insulator failed near Chokkampeta (V)	No
1	NLG	Kudakuda	Ilapuram	11KV	Suryapeta	15:45	17:30	1:45	E/L	Insulator flashover	No
2		Palakeedu	Palakeedu	11KV	Huzurnagar	06.50	09.50	03.00	E/L	11KV Jumper cut	No
3		Nadigudem	Nadigudem(T)	11KV	Huzurnagar	06.30	07.50	01.20	E/L	11KV Disc Failure	No
4		Garidepally	Kalmalacheruvu	11KV	Huzurnagar	04.15	07.30	03.15	E/L	11KV Jumper cut	No
5		Narsingbatla	Gadibaigudem	11KV	Nalgonda	11:40	13:00	1:20	E/L	11KV Insulator failed	No
1	SDPT	Guruvannapet	Guruvannapet	11KV	Husnabad	4:50	7:55	3:05		Jumper cut	No