

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	1	1	1	1	1			
7	RR(E)	168	403									
8	Hyd	194	1044									
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		5		5		5			
3	MDK	107	933		2		2		2			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 14.02.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV LGM Pet	33KV BE Pharma	33KV	Medchal	7:38	11:55	4:17		2 Nos. Pin Insulators failed at Nektar Company	33KV BE Pharma	No

TSSPDCL - LMRC / Corporate office

Date: 14.02.19

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Reddygudem	Maddirala	11KV	Suryapet	9:42	11:50	2:08	E/L	HT/LT line melt	No
2		Ananthagiri	Mogalaikota	11KV	Huzurnagar	3:40	5:40	2:00	E/L	AB Switch open	No
3		Mattapally	Mattapally Town	11KV	Huzurnagar	12.30	15.10	2:40	E/L	11KV Conductor snapped	No
4		Pamkunta	Jala	11KV	Bhongir	8:15	11:00	2:45	E/L	11kv Pin binding failed in Jala (V)	No
5		Champur	Chandaypally	11KV	Bhongir	9:15	11:40	2:25	E/L	Insulator failed	No
1	MDK	Pati	Pati	11KV	Patancheru	14:20	15:55	1:35		Insulator failed	No
2		SOL	SOL	11KV	Patancheru	08.45	11.25	02.40		Jumper cut	No
1	SDPT	Guruvannapet	Tapaspally	11KV	Husnabad	4:15	9:00	4:45		Insulator failed	No
1	RR N	Aliabad	Majeedpur	11KV	Medchal	13:40	14:20	0:40		11KV Pole damaged by DCM at Bawarchi Opposite	No