

TSSPDCL - LMRC / Corporate office

Date: 16.02.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV Medchal	33KV Aliabad	33KV	Medchal	0:19	3:09	2:50		Line patrolling done No visuable fault	33KV Aliabad	
2		132KV Medchal	33KV Keshavaram	33KV	Medchal	17.22	18.20	00.58		33KV Cable End Kit failed at ORR	33KV Keshavaram	Backfeed Arranged to 33KV Aliabad feeder
1	HYD N	132KV Madhapur	Rajeha	33KV	Kalyannagar	10.30	10.40	00.10	OL-R&Bph	Cable end kit fault	Rajeha	Loads transfered onto 132KV Madhapur KRIT

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Penpahad	Penpahad Town	11KV	Suryapet	4:00	6:10	2:10	E/L	Conductor snapped	No
2		Urlugonda	K.K.Gudem	11KV	Huzurnagar	09.00	12.00	03.00	EL	11 KV Jumper cut	No
3		Dirincherla	Dirincherla	11KV	Huzurnagar	08.00	10.00	02.00	EL	11 KV Line snapped	No
4		Maryala	Wadaparthi	11KV	Bhongir	08.00	10.20	02.20	EL	11kv Line Snapped In Maryala Villge	No
5		Solipet	Solipet Ind	11KV	Bhongir	3:15	6:30	3:15	EL	PT Failed near Nagireddy Villge	No
1	RR N	Somashila	Balakrishananagar	11KV	Kukatpally	0:15	1:30	1:15	EL/OL	11kv Jumper cut at Bala Krishananagar	No
2		Jeedimetla-I	Apiic	11KV	Jeedimetla	00.35	01.35	01.00	EL/OL	11kv Jumper cut at Hanuman Temple Shapuraganar	No
3		Jeedimetla-I	Netco	11KV	Jeedimetla	00.35	03.15	02.40	EL/OL	11kv AB Cable failure at Global Foods Company	No
4		Jeedimetla-I	Phase-II	11KV	Jeedimetla	00.35	02.10	01.35	EL/OL	Due To Heavy Rain	No
5		Jeedimetla-III	USP Organic	11KV	Jeedimetla	00.55	03.55	03.00	OL	11KV AB cable failure At Vinayaka Company	No
6		Subhash Nagar	Bank colony	11KV	Medchal	0:42	2:05	1:23	OL	No visible fault	No
1	RR E	Vinayak Nagar	Devi Nagar	11KV	Sainikpuri	1:02	1:35	0:33		100KVA DTR jumper cut at Rambramha Nagar due to Heavy Rain	No
2		Chakripuram	Ayyappa	11KV	Keesara	17.15	18.05	00.50		11KV Jumper cut near Andhra Bank	No
1	HYD S	Goshamahal	M.J Market	11KV	Begumbazar	01.30	02.32	01.02		Cable end kit failed	Arranged B/F on 11KV Osmangunj feeder
2		Kulsumpura	Gandi Hanuman	11KV	Begumbazar	11:03	12:30	1:27		Cable fault at Bilal Masjid	No