

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		8		8		8			
3	MDK	107	933		2		2		2			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	11	0	11	0	11	0	0	
	Grand Total	1082	6468	0	11	0	11	0	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 18.02.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
NIL												

TSSPDCL - LMRC / Corporate office

Date: 18.02.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Thatipamula	Nandapuram	11KV	Suryapet	08.10	09.40	01.30	E/L	11Kv Insulator flashover	-
2		Alingapuram	Gundlapahad	11KV	Huzurnagar	07.00	09.00	02.00	E/L	11Kv Disk failure	-
3		Dirsincherla	Yellapuram	11KV	Huzurnagar	06.45	10.00	03.15	E/L	11Kv line snapped	-
4		Chilukur	Kondapuram	11KV	Huzurnagar	08.50	11.45	02.55	E/L	11Kv Jumper cut	-
5		Chityala	Yelikatte 1	11KV	Nalgonda	08.10	09.50	01.40	E/L	11Kv Jumper cut	-
6		Narkatpally	Mandra	11KV	Nalgonda	12.00	13.20	01.20	E/L	11Kv Jumper cut	-
7		B.Ramaram	Sai Teja Indl.	11KV	Bhongir	05.00	05.20	00.20	E/L	11Kv Insulator flashover	-
8		Iskilla	Kakkireni	11KV	Choutuppal	08.40	14.00	05.10	E/L	11Kv Jumper cut	-
1	MDK	Cheryal	Kandi	11KV	Sangareddy	13.00	13.40	00.40		B/D Due to Conductor Snapped	-
2		Ch.Hyd	Ch.Hyd	11KV	Zaheerabad	04.00	08.00	04.00		B/D Due to Jumper Cut	-
1	SDP	Thotapally	Gandinagar	11KV	Husnabad	12.00	15.00	03.00		BD,due to 11KV conductor snapped	-