

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		7		7		7			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	8	0	8	0	8	0	0	
	Grand Total	1082	6468	0	10	0	10	0	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 20.02.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Karkonda	Khanapur	11KV	Jadcherla	09.11	11.54	02.43		LT Line Cut At Bondala Gadda at Khanapur(Vi).	-
1	NLG	Phanigiri	Phanigiri Agl	11KV	Suryapet	14.30	17.00	02.30	E/L	11Kv Conductor snapped	-
2		Gaddipally	Medaram	11KV	Huzurnagar	08.30	12.00	03.30	E/L	11Kv Jumper Cut	-
3		Garidepally	Appannapet	11KV	Huzurnagar	11.35	12.45	01.10	E/L	11Kv Conductor snapped	-
4		Urlugonda	Karakkayalagudem	11KV	Huzurnagar	03.20	07.00	03.40	E/L	11Kv Conductor snapped	-
5		Pamanagundla	Pittampally	11KV	Nalgonda	05.30	10.05	04.35	E/L	11Kv Line Insulator Failed	-
6		Pullemla	Pullemla	11KV	Nalgonda	09.30	10.40	01.10	E/L	11 KV Line Jumper Cut	-
7		K.M.Pally	C.A.Pally	11KV	Devarakonda	21.10	06.10	09.00	E/L	11Kv Broken Pole	-
1	RR East	Kushaiguda	Rukminipuri	11KV	Sainikpuri	06.20	06.50	00.30		Lezard fallen on 11Kv line at Sri Manu Apt. (AE/SKP)	
1	HYD N	Bowenpally	Gowtham Nagar	11KV	Bowenpally	16.45	17.50	01.05	EL,OL-Bph	Big Tree fallen on lines & One pole damaged at Gowtham Nagar	19:15 Hrs 3No DTR's loads added on 11KV Akshay Enclave fdr