

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	2	1	2	1	2			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	1	2	1	2	1	2	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		6		6		6			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	7	0	7	0	7	0	0	
	Grand Total	1082	6468	1	9	1	9	1	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 24.02.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV Chintal	33KV UMCC	33KV	Medchal	09.27	12.05	02.38	BD	Bird fallen on 33kv Line(Backfeeding arranged in 15:00 Minutes)	33KV UMCC	-

TSSPDCL - LMRC / Corporate office

Date: 24.02.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Bopparam	Maktha kotha gudem	11KV	Suryapeta	14.00	15.30	01.30	E/L	Conductor snapped	-
2		Koppole	Bheemaram	11KV	Nalgonda	12.10	14.05	02.05	E/L	11KV Line Cutting	-
3		Pazzur	Khaziramaram	11KV	Nalgonda	06.00	08.00	02.00	E/L	11KV Line Disk Failure	-
4		Akkenepally	Chinnathummalagudem	11KV	Nalgonda	11.00	13.30	02.30	E/L	11KV Insulator failure	-
5		Bollepally	Jampally	11KV	Bhongiri	07.40	10.25	02.45	E/L	11KV Jumper cut	-
6		Raigiri	Raigiri AGL	11KV	Bhongiri	11.30	14.50	03.20	E/L	11KV Insulator failure	-
1	SDP	Komuravelly	Peddarajupeta	11KV	Siddipet	12.50	15.50	03.00		BD due to Gail & Wind	-
1	RR N	Medchal	IDA Kandlakoya	11KV	Medchal	05.13	06.43	01.30	BD	11KV Line Cut & Replaced at Posh Chemical Company	-
2		Shameerpet	Alankrita	11KV	Medchal	09.15	12.05	02.50	BD	11KV Jumper Cut & Replaced near Janaki Seeds Opposite	-