

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988	1	5	1	5	1	5			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	6	2	6	2	6	0	0	
	Grand Total	1082	6468	2	7	2	7	2	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 25.02.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Polepally	Madaram	33KV	Jadcherla	08.50	15.30	06.40		Bus Shud Down and Break Down Conductor Snapped near Midjil	Madaram	-
1	NLG	Nalgonda	SLBC	33KV	Nalgonda	07.20	12.20	05.00	E/L	33KVPTR Jumper cut		-

TSSPDCL - LMRC / Corporate office

Date: 25.02.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	CH.Laxmapur	Madhapur	11KV	Bhongiri	14.10	15.15	00.55	E/L	11KV Jumper cut in Madhapur(v)	-
2		Mariyala	Mailaram	11KV	Bhongiri	14.15	16.45	02.30	E/L	11KV Line Snapped	-
3		Aravapally	Parsaipally	11KV	Suryapeta	05.30	07.50	02.20	E/L	Conductor Snapped	-
4		Dilchincerla	Dilchincerla	11KV	Huzurnagar	03.00	06.00	03.00	E/L	11KV Line Snapped	-
5		Mukundapuram	Somaram	11KV	Huzurnagar	10.47	13.40	02.53	E/L	11KV Jumper cut	-
1	MDK	Patancheru	MIA-II	11KV	Patancheru	00.05	02.05	02.00		B/D due to Conductor snapped	-
1	RR N	Madinaguda	J P N nagar	11KV	Kukatpally	14.43	15.45	01.02	EL/OL	Tree Branches fallen On The 11kv Line At H D F C Bank Miyapur	-