

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		7		7		7			
3	MDK	107	933		2		2		2			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	11	1	11	1	11	0	0	
	Grand Total	1082	6468	1	12	1	12	1	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 05.01.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothamolgara	Kothamolgara	11kv	Jadcherla	09.00	11.15	02.15		11 KV Phase To Phase Near Bhoothpur Road.	-
1	NLG	Akkenapally	Chinna Thumalagudam	11kv	Nalgonda	08.00	10.40	02.40	E/L	11 KV Insulator failed	-
2		Munugode	Kompally	11kv	Nalgonda	09.00	10.45	01.45	E/L	11 KV line jumper cut	-
3		Dirincherla	Somaram	11kv	Huzurnagar	03.00	06.30	03.30	E/L	3 PHASE DTR FAILURE	-
4		Palakeedu	Bothalapalem	11kv	Huzurnagar	06.15	08.30	02.15	E/L	100 KVA DTR FAILURE	-
5		Raghunadapalem	Gundlapally	11kv	Huzurnagar	08.10	09.45	01.35	E/L	11 KV Jumper cut	-
6		Pamkunta	Pamkunta	11kv	Bhongir	07.30	11.00	03.30	E/L	Bird Fallen at Line near Rajapet Villge	-
7		Sangem	Sangem	11kv	Bhongir	13.35	14.56	01.16	E/L	11kv Disc Fail near Sangem Villge	-
1	MDK	Bollaram - I	Aurobindo	11kv	Patancheru	09.10	10.20	01.10		B/D Due to Jumper Cut	-
2		SOL	IDA-II	11kv	Sangareddy	06.05	07.45	01.40		B/D Due to Conductor Snapped	-
3	SDPT	Mustyal	Cherial Agl	11kv	Husnabad	11.50	12.40	00.50		Break down	-
1	RR N	Shameerpet	Thumkunta	11kv	Medchal	16.35	17.55	01.20		11KV UG Cable failed at ORR	-

TSSPDCL - LMRC / Corporate office

Date: 05.01.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	220/33KV SS Singotam	Narsaipally	33kv	Nagarkurnool	13.24	15.07	01.43	EL	33KV Jumper Cut at 220/33KV SS	Narsaipally	-