

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	2	2	2	2	2	2			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	2	2	2	2	2	0	0	
	Grand Total	1082	6468	2	4	2	4	2	4	0	0	

TSSPDCL - LMRC / Corporate office

Date: 06.01.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Hanmapur	Thukkapur	33KV	Bhongir	01.20	02.05	00.45	EL	Alternate Supply Taken 33/11 KV SS Nandanam	Thukkapur	-
2		Choutuppal	Srini IND	33KV	Choutuppal	06.57	09.50	02.53	EL	33KV Line Snapped Near Suryodaya company	Srini IND	-

TSSPDCL - LMRC / Corporate office

Date: 06.01.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Thogarrai	Kapugallu	11KV	Huzurnagar	04.55	06.35	01.40	EL	Due to 11Kv line Snapped	-
2		Janpahad	Sunyapahad	11KV	Huzurnagar	08.00	09.40	01.40	EL/OL	Due to 11Kv line Snapped	-
1	RR E	Aushapur	Aushapur	11KV	Keesara	04.50	10.20	05.30		11KV Pole damaged due to Lorry dashed at Jameelpeta	-
1	HYD C	Golconda	Darga Cable	11KV	VII	14.40	16.30	01.50	EL,OL-Yph	Cable fault at Shaikpet Nala	Arranged B/F on 11KV O.U. Colony & 11KV Aditya Nagar Cable feeders