

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		7		7		7			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	7	0	7	0	7	0	0	
	Grand Total	1082	6468	0	11	0	11	0	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 07.01.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kandibanda	Gandinagar thanda	11KV	Huzurnagar	06.00	09.15	03.15	E/L	11KV Line Snapped	-
2		Akupamula	K K Gudem	11KV	Huzurnagar	12.40	15.00	02.20	E/L	11KV Line Snapped	-
3		Penpahad	Dubbathanda	11KV	Suryapet	13.09	15.45	02.36	E/L	11kv Conductor snapped	-
4		Datharpally	Mallapur	11KV	Bhongir	03.20	09.56	06.36	E/L	11kv Jumper Cut In Mallapur (V)	-
5		Gudapoor	Singaram	11KV	Nalgonda	08.20	10.10	01.50	E/L	11 KV Line Insulator Failed	-
6		Mamidala	Godavarigudem	11KV	Nalgonda	11.36	13.10	01.34	E/L	11 KV Jumper Cut	-
7		Narketpally IE	Vattimarthy	11KV	Nalgonda	06.00	08.00	02.00	E/L	11 KV Jumper Cut	-
1	RR S	Gachibowli	Gopanpally	11KV	Gachibowli	07.20	08.22	01.02	BD	High Tension Earth Wire Fallen on the 11kv Line Near 220kv Gachibowli Sub-Station	-
1	HYD S	Karwan	Jiyaguda OH	11KV	IX	09.20	10.55	01.35	EL,OL	Cable fault at Pillar No. 108 (1No. DTR kept off)	-
2		Kandikal Gate	Phool Bagh	11KV	III	15.10	16.50	01.40	EL,OL	HT Line snapped at Door Dhana Hotel, Phool Bagh	-
3		Panjasha	Panjasha	11KV	III	21.55	23.10	01.15	All Indication	2No. Jumpers cut due to Cat fallen on DTR near Macca Masjid	-