

## Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle       | No. of Feeders Existing Urban |             | Breakdowns occurred during the day |          | Attended during the day |          | Time taken for restoring the supply |          |                                |          | Remarks (Pending)     |
|------|--------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-----------------------|
|      |              | 33KV                          | 11KV        | 33KV                               | 11KV     | 33KV                    | 11KV     | Rectified (Within 24 Hours)         |          | Not Rectified (Above 24 Hours) |          |                       |
|      |              |                               |             |                                    |          |                         |          | 33KV                                | 11KV     | 33KV                           | 11KV     |                       |
| 1    | MBN          | 18                            | 107         |                                    |          |                         |          |                                     |          |                                |          |                       |
| 2    | NLG          | 22                            | 358         |                                    |          |                         |          |                                     |          |                                |          |                       |
| 3    | MDK          | 97                            | 359         |                                    |          |                         |          |                                     |          |                                |          |                       |
| 4    | SDPT         |                               |             |                                    |          |                         |          |                                     |          |                                |          |                       |
| 5    | RR(S)        | 53                            | 234         | 1                                  |          |                         |          |                                     |          |                                |          | 1No 33KV feeder Still |
| 6    | RR(N)        | 54                            | 550         |                                    |          |                         |          |                                     |          |                                |          |                       |
| 7    | RR(E)        | 168                           | 403         |                                    |          |                         |          |                                     |          |                                |          |                       |
| 8    | Hyd          | 194                           | 1044        |                                    | 2        |                         | 2        |                                     | 2        |                                |          |                       |
|      | <b>Total</b> | <b>606</b>                    | <b>3055</b> | <b>1</b>                           | <b>2</b> | <b>0</b>                | <b>2</b> | <b>0</b>                            | <b>2</b> | <b>0</b>                       | <b>0</b> |                       |

Rural

| S.No | Circle             | No. of Feeders Existing Rurals |             | Breakdowns occurred during the day |          | Attended during the day |          | Time taken for restoring the supply |          |                                |          | Remarks (Pending) |
|------|--------------------|--------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
|      |                    | 33KV                           | 11KV        | 33KV                               | 11KV     | 33KV                    | 11KV     | Rectified (Within 24 Hours)         |          | Not Rectified (Above 24 Hours) |          |                   |
|      |                    |                                |             |                                    |          |                         |          | 33KV                                | 11KV     | 33KV                           | 11KV     |                   |
| 1    | MBN                | 107                            | 849         | 1                                  | 1        | 1                       | 1        | 1                                   | 1        |                                |          |                   |
| 2    | NLG                | 144                            | 988         |                                    | 5        |                         | 5        |                                     | 5        |                                |          |                   |
| 3    | MDK                | 107                            | 933         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 4    | SDPT               |                                |             |                                    |          |                         |          |                                     |          |                                |          |                   |
| 5    | RR(S)              | 58                             | 396         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 6    | RR(N)              | 38                             | 114         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 7    | RR(E)              | 22                             | 133         |                                    |          |                         |          |                                     |          |                                |          |                   |
|      | <b>Total</b>       | <b>476</b>                     | <b>3413</b> | <b>1</b>                           | <b>6</b> | <b>1</b>                | <b>6</b> | <b>1</b>                            | <b>6</b> | <b>0</b>                       | <b>0</b> |                   |
|      | <b>Grand Total</b> | <b>1082</b>                    | <b>6468</b> | <b>2</b>                           | <b>8</b> | <b>1</b>                | <b>8</b> | <b>1</b>                            | <b>8</b> | <b>0</b>                       | <b>0</b> |                   |

TSSPDCL - LMRC / Corporate office

Date: 10.01.2019

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown  | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---------------------------|
| 1    | MBNR   | Singotam            | Narsaiaply           | 33KV | Wanaparth            | 11.29 | 14.25 | 02.56    | O/L              | Tree Fallen on the Line and Tree Branches removed               | Singotam              | No                        |
| 1    | RR S   | Pargi               | Savitri              | 33KV | VKB                  | 22.40 |       |          |                  | 2 Nos Insulator failed near 132 KV pargi SS (taken LC 00:30 am) |                       | -                         |

## TSSPDCL - LMRC / Corporate office

Date: 10.01.2019

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown  | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---------------------------|
| 1    | MBNR   | Balanagar          | Gouthapur            | 11KV | Jadcherla            | 00.00 | 08.18 | 08.18    |                  | 11KV Jumper cut near Thirumalai kunta thanda  | -                         |
| 1    | NLG    | Ramachandra puram  | Ramachandra puram    | 11KV | Suryapet             | 12.10 | 14.20 | 02.10    | E/L              | Conductor snapped   | -                         |
| 2    |        | Akupamula          | Lift                 | 11KV | Huzurnagar           | 09.50 | 10.50 | 01.00    | EL/OL            | Due to 11Kv Jumper cutted   | -                         |
| 3    |        | Dirsincherla       | Narasayagudem        | 11KV | Huzurnagar           | 06.30 | 09.30 | 03.00    | EL               | Due to 11Kv line cutted   | -                         |
| 4    |        | Ch.Laxmapur        | Madhapur TOWN        | 11KV | Bhongiri             | 09.10 | 11.00 | 01.50    | EL               | Monkey Fallen in DTR near Rice Mill Main Road Madhapur Town   | -                         |
| 5    |        | Sangem             | Dubbala              | 11KV | Choutuppal           | 12.40 | 14.15 | 01.35    | EL               | 11kv Insulator Fail in Kondam Well near Sangem Villge   | -                         |
| 1    | HYD S  | Yakuthpura         | Dharmavanth          | 11KV | Asmangadh            | 18.20 | 21.00 | 02.40    | EL,OL-Bph        | Sparking AB Switch at Classic Ice Cream (At 19:49 Hrs opened RMU at Classic Ice Cream (Only 30Amps charged /60Amps) | -                         |
| 1    | HYD C  | Ibrahimbagh        | New Military         | 11KV | Mehdipatanam         | 00.45 | 03.10 | 02.25    | EL,OL            | Cable faut at Gurudwara   | -                         |