

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		3		3		3			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		4		4		4			
3	MDK	107	933		3		3		3			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>12</b>	<b>1</b>	<b>12</b>	<b>1</b>	<b>12</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 13.01.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kodangal	Kodangal	33KV	Vikarabad	23.18	23.28	00.10	OL	33KV Conductor snapped	Kodangal	Alternate Supply Arranged from 33KV Peddanadigama SS

TSSPDCL - LMRC / Corporate office

Date: 13.01.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Nidmanoor	Shakapuram	11KV	Miryalaguda	03.10	07.15	04.05	EL	Tree fall	-
2		Raghunadapalem	Nakkagudem	11KV	Huzurnagar	10.00	12.10	02.10	EL	11 KV JUMPER CUT	-
3		Motakondur	Choller	11KV	Bhongir	06.00	09.00	03.00	EL	11kv Line Snapped at Giribothna Gudem Villge	-
4		Motakondur	Motakondur	11KV	Bhongir	07.00	08.00	01.00	EL	25kv DTR Fail in Durgamma temple in Motkondur Villge	-
1	MDK	Nasthipur	Industrial	11KV	Jogipet	18.40	19.20	00.40		B/D Due to Insulator Failure	-
2		Bollaram - I	Soubhagya	11KV	Patancheru	03.50	04.25	00.35		B/D Due to Jumper Cut	-
3		Gummadidala	Gummadidala (Vg)	11KV	Patancheru	06.30	07.30	01.00		B/D Due to Conductor Snapped	-
1	RR N	Shameerpet	Alankrita	11KV	Medchal	14.05	15.30	01.25	BD	11KV Pole fallen on 11KV Thumkunta Feeder(Backfeeding arranged from 11KV Thumkunta Feeder)	-
1	RR E	Vinayak Nagar	Devi Nagar	11KV	Sainikpuri	17.51	18.20	00.29		11/7LP line Kite touching at Sri Krishna Nagar Road No.1 (AE/VK Nagar) due to Phase to Phase	-
1	HYD S	Falaknuma	Falaknuma OH	11KV	III	01.30	03.10	01.40	EL,OL	UG Cable fault at Famous Supply Company (Partial fdr charged at 02:24 Hrs)	-
2		Falaknuma	Falaknuma OH	11KV	III	09.35	10.45	01.10	EL,OL	HT Lines snapped at Bibi Ka Chesma	-
3		Falaknuma	Falaknuma OH	11KV	III	22.25	00.53	02.28	EL,OL-Rph	Suspected RMU Cable Fault	partial loads arranged B/F on 11KV Falaknuma UG & Jangam Mett AB Cbl fdrs