

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		5		5		5			
8	Hyd	194	1044		5		5		5			
	Total	606	3055	0	10	0	10	0	10	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	1	0	1	0	1	0	0	
	Grand Total	1082	6468	0	11	0	11	0	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.01.19

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Choutuppal	Town 2	11KV	Bhongir	6:30	9:50	3:20	EL	11kv 2 no's Disc Failed in Choutuppal Town	No
1	RR E	Uppal	Uppal	11KV	Habsiguda	16:50	18:10	1:20		11KV line cut at Surya Nagar Colony	No
2		Mallapur	IDA	11KV	Habsiguda	10.45	11.25	00.40		11KV IDA feeder breaker fault at SS Yard	No
3		Vasanthapuri	Ganesh Temple	11KV	Sainikpuri	13.14	14.38	01.24		Kite fallen on 11Kv line at Ganesh Temple	No
4		Chengicherla	My Villas	11KV	Keesara	13.10	14.40	01.30		11KV Insulator failed near Peddamma Temple	No
5		Narapally	Prathap Singaram	11KV	Keesara	17:30	18:40	1:10		HT/LT lines touched at Choudariguda	No
1	HYD N	Gymkhana	Balamrai	11KV	Sec'bad	12.38	14.38	02.00	EL	Bird fault on lines at Balamrai Khaman	No
2		H.A.L	H.A.L Town Ship	11KV	Bowenpally	16:15	17:35	1:20	All Indication	DC Control pannel Burnt out at SS	No
1	HYD S	Petlaburz	Hussaini Alam	11KV	Charminar	17.27	19.12	01.45	EL,OL-Rph	Cable fault	Arranged B/F on 11KV Sha Gunj feeder
2		Salarjung	Q.Q Stadium	11KV	Charminar	19:30	21:00	1:30	All Indication	HT Line snapped at Maternity Hospital	No
1	HYD C	Golnaka	Kamala Nagar	11KV	Azamabad	09.45	10.46	01.01	OL	HT/LT Line snapped & HT Jumper cut at Kamala Nagar	No