

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	4	1	4	1	4			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>1</b>	<b>4</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>1</b>	<b>5</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 22.01.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Kolanpaka	Kolanpaka	33KV	Bhongir	11:00	13:15	2:15		33KV Jumper Open In Patelgudem Villge	Kolanpaka	No

TSSPDCL - LMRC / Corporate office

Date: 22.01.19

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Thatipamula	Thatipamula	11KV	Suryapet	8:50	11:30	2:40	EL	Conductor snapped	No
2		Mattapally	Ramachandrapuram	11KV	Huzurnagar	13.45	15.45	02.00	EL/OL	11KV line cutted	No
3		Karivirala	Ramchandrapuram	11KV	Huzurnagar	09.30	10.30	01.00	EL	11KV Insulator failed	No
4		Pamanagundla	Pittampally	11KV	Nalgonda	00.40	09.26	08.46	EL	11KV Jumper cut	No
1	HYD S	Falaknuma	Jangammett AB Cable	11KV	Charminar	15.28	17.43	02.15	EL,OL-Rph	Conductor snapped at Shamseer Gunj & VCB Limb failed at SS	Arranged B/F on 11KV Police Quarters fdr