

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988	1	8	1	8	1	8			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	9	1	9	1	9	0	0	
	Grand Total	1082	6468	1	12	1	12	1	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 25.01.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Aitipamula	Kethepally	33KV	Nalgonda	07.46	09.05	01.19		Moment fault		-

TSSPDCL - LMRC / Corporate office

Date: 25.01.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Thirumalapur	Dondlapally	11KV	Jadcherla	11.30	16.00	04.30		11KV Jumper cut near Raghavapur	-
1	NLG	P.D.Pally	P.D.Pally	11KV	Nalgonda	13.10	15.30	02.20	EL	11KV Line cut	-
2		Narkatpally	Mandra	11KV	Nalgonda	07.00	10.00	03.00	EL	11KV line Insulator failed	-
3		Athmakur(S)	Athmakur Agl	11KV	Suryapet	06.30	09.00	02.30	EL	Insulator flashover	-
4		Dondapadu	Kakatiya	11KV	Huzurnagar	07.00	10.15	03.15	EL	Due to bird fall on 11Kv line	-
5		Mattapally	Ramachandhrapuram	11KV	Huzurnagar	10.30	12.49	02.19	EL	Due to 11Kv line cutted	-
6		Repala	Kalakova	11KV	Huzurnagar	05.45	08.50	03.05	EL	Due to 11Kv jumper cutted	-
7		Sirikonda	Namavaram	11KV	Huzurnagar	10.00	12.00	02.00	EL	Due to 11Kv Disk failure	-
8		Rajapet	Pamkunta	11KV	Bhongir	00.30	07.00	06.30	EL	11kv Line Snapped	-
1	RR N	Medicity	Pudur	11KV	Medchal	13.40	15.20	01.40	BD	Tree fallen on the 11KV Line at Ghanapur Village	-
2		Kandlakoya	Godrej	11KV	Medchal	15.10	16.15	01.05	BD	11KV Pole damaged at Ammavari Thota, Kandlakoya	-
1	RR E	IDAuppal	Kamakshipuram	11KV	Habsiguda	11.40	12.30	00.50		Tree fallen on 11kv line near DR chary clinic	-