

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		5		5		5			
6	RR(N)	54	550		6		6		6			
7	RR(E)	168	403		6		6		6			
8	Hyd	194	1044		14		14		14			
	Total	606	3055	0	31	0	31	0	31	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	14	3	14	3	14	3			
2	NLG	144	988	4	22	4	22	4	22			
3	MDK	107	933	1	6	1	6	1	6			
4	SDPT				16		16		16			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	19	47	19	47	19	47	0	0	
	Grand Total	1082	6468	19	78	19	78	19	78	0	0	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	G.R Cable	33KV	Jadcherla	10.02	12.50	02.48	E/L	Conductor Snapped at Hari OM Industry	G.R Cable	-
2		Makthal	Narwa	33KV	Narayanapet	12.40	15.55	03.15	E/L	Pin Binding Tighten Pole Number 6,9,10	Narwa	-
3		Maddur	Kankurthy	33KV	Narayanapet	15.35	16.35	01.00	E/L	Due to Rain	Kankurthy	-
4		Maddur	Damargidda	33KV	Narayanapet	16.50	19.25	02.35	E/L&O/L	LA Replaced at Kyatanpally SS	Damargidda	-
5		Gadwal	Bijwar	33KV	Gadwal	11.30	18.02	06.32		Pin binding of Tap Phase and Conductor Fallen on the Cross Aram DickFailed	Bijwar	-
6		Ghanapur	Lattupally	33KV	Wanaparthi	10.54	11.49	00.55	E/L	AB Switch Opened at Manganoor SS	Lattupally	-
7		Achampet	Uppununthala	33KV	Nagarkurnool	13.20	15.55	02.35	E/L	Insulator Replaced Near Poultry Form	Uppununthala	-
8		Achampet	Veltoor	33KV	Nagarkurnool	11.25	18.50	07.25	E/L	Pin Insulators Replacment	Veltoor	-
9		Nagarkurnool	Manthathi	33KV	Nagarkurnool	11.16	14.05	02.49	E/L	Tree Branches removing at the Line	Manthathi	-
10		Nagarkurnool	Peddakothapally	33KV	Nagarkurnool	11.30	15.15	03.45	E/L&O/L	Tree Cutting at Sanjeevapuri(V)	Peddakothapally	-
11		Singotam	Narsaipally	33KV	Nagarkurnool	11.18	13.05	01.47	O/L	Due to Rain AB Switch Opened at Mahasamudram	Narsaipally	-
12		Kalwakurthy	Tarnikal	33KV	Nagarkurnool	15.53	17.10	01.17	O/L	No Visible Fault	Tarnikal	-
13		Shadnagar	Mogiligidda	33KV	Shadnagar	15.20	16.30	01.10	E/L	Alternate Supply Was Arranged From 132KV SS Sri Rangapur at 16:30Hrs.	Mogiligidda	-
14		Alwal	Padkal	33KV	Shadnagar	11.45	16.15	04.30	E/L	Insulator Replaced	Padkal	-
1	NLG	Miryalaguda	Mattor	33KV	Miryalaguda	13.10	15.00	01.50		33KV Insulator failed	Mattor	-
2		Haliya	Yacharam	33KV	Miryalaguda	13.30	14.25	00.55		33KV Disck failed	Yacharam	-
3		KM Pally	Meredgumma	33KV	Deverakonda	11.30	14.30	03.00		33KV Insulator failed	Meredgumma	-
4		BB Nagar	BP Pally	33KV	Bhongiri	03.55	07.55	04.00		33KV Jumper cut	BP Pally	-
1	MDK	Sadashivapet	Koheer	33KV	Sangareddy	18.35	14.45	20.10		BD due to AB switch Problem and Supply Arranged from 132KV Zaheerabad, 33KV Jharasangem feeder	Koheer	-

TSSPDCL - LMRC / Corporate office

Date: 27.01.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Peddarevelly	Hemajipur	11KV	Jadcherla	10.00	15.00	05.00		11KV Insulater fail near koilkunta thanda.	-
2		Marikal	Malkapur	11KV	Jadcherla	09.40	14.00	04.20		11KV Insulater fail near Malkapur.	-
3		Marikal	Chakalpally	11KV	Jadcherla	09.35	15.47	06.12		11 KV wire Cut and disk fail near mesab thanda.	-
1	NLG	Kalmancheruv	Ganganagar	11KV	Huzurnagar	04.00	07.30	03.30		11KV conductor snapped	-
2		Mamillagudem	Nothi	11KV	Huzurnagar	10.35	13.10	02.35		11KV conductor snapped	-
3		Ragunathapalem	Gundapally	11KV	Huzurnagar	15.20	17.30	02.10		11KV Jumper cut	-
4		Thungathurthy	Ganugudbanda	11KV	Suryapeta	16.20	17.40	01.20		11KV Insulator failed	-
5		Bibigudem	Maunyanik Thanda	11KV	Suryapeta	16.30	18.15	01.45		11KV Insulator failed	-
6		Pellipakala	Gajanagar	11KV	Devarakonda	12.10	17.17	05.07		11KV Insulator failed	-
7		Ghanapuram	Polkampally	11KV	Devarakonda	12.45	18.00	05.15		11KV Jumper cut	-
8		Ghanapuram	GB Pally	11KV	Devarakonda	12.45	16.30	03.45		11KV Jumper cut	-
9		Ghanapuram	Ghanapuram	11KV	Devarakonda	16.45	17.45	01.00		11KV conductor snapped	-
10		Pullemala	Bodangiparthi	11KV	Nalgonda	11.15	13.00	01.45		11KV Jumper cut	-
11		Pullemala	Pullemala	11KV	Nalgonda	11.15	13.15	02.00		11KV Jumper cut	-
12		Endulagudem	Malparagudem	11KV	Nalgonda	14.55	15.55	01.00		11KV Insulator failed	-
13		Kantangoor	Bollapally	11KV	Nalgonda	15.10	16.30	01.20		11KV Insulator failed	-
14		Edunnuru	Narlagudem	11KV	Nalgonda	14.04	16.50	02.46		11KV Jumper cut	-
15		B banda	B banda	11KV	Nalgonda	14.15	16.20	02.05		Line conductor snapped	-
16		Agamothkur	Agamothkur	11KV	Miryalaguda	14.00	17.00	03.00		Pin Insulator failed	-
17		MG Banda	Gandamalla	11KV	Bhongiri	05.00	09.00	04.00		Pin Insulator failed	-
18		Venkatapur	Dataipally	11KV	Bhongiri	04.00	07.00	03.00		11KV disck failed	-
19		Venkatapur	Vempally	11KV	Bhongiri	04.30	07.30	03.00		11KV Insulator failed	-
20		Pamakunta	Pamkunta	11KV	Bhongiri	03.00	08.00	05.00		11KV Insulator failed	-
21		Venkirayala	Induatrial	11KV	Bhongiri	12.10	12.58	00.48		11KV Insulator failed	-
22		Choutuppal	Jublapally	11KV	Choutuppal	11.00	13.20	02.20		11KV Insulator failed	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MDK	Ismaikhanpet	Industrial	11KV	Sangareddy	07.40	08.30	00.50		BD due to Tree branches fallen on line	-
2		Ismaikhanpet	Goudicherla	11KV	Sangareddy	07.00	08.00	01.00		BD due to Jumper cut	-
3		Bonthapally	Ayyappa	11KV	Patancheru	01.00	09.30	08.30		BD due to Insulator failed	-
4		Patancheru	MIA-I	11KV	Patancheru	08.50	09.30	00.40		BD due to CTPT failed	-
5		Patancheru	MIA-II	11KV	Patancheru	08.50	10.30	01.40		BD due to Disk failed	-
6		Gundla Machnoor	Gundla Machnoor	11KV	Jogipet	02.30	07.00	04.30		BD due to Tree branches fallen on line	-
1	Siddipet	Husnabad	Husnabad Town-2	11KV	Husnabad	14.05	15.20	01.15		Tree branches touched line same rectified	-
2		Thotapally	Anthakkapet	11KV	Husnabad	00.00	08.40	08.40		Insulator failed same rectified	-
3		Akkannapet	Pakilnayak Thanda	11KV	Husnabad	05.00	12.00	07.00		Tree branches touched line same rectified	-
4		Akkannapet	Akkannapet Rural	11KV	Husnabad	00.00	10.50	10.50		Tree branches touched line same rectified	-
5		Gandipally	Ramavaram	11KV	Husnabad	05.50	08.10	02.20		Insulator failed same rectified	-
6		Gandipally	Nandaram	11KV	Husnabad	02.50	08.30	05.40		Insulator failed same rectified	-
7		Gandipally	Ramavaram Exp	11KV	Husnabad	00.00	08.30	08.30		Insulator failed same rectified	-
8		Bejjanki	Kalllepally	11KV	Husnabad	03.00	06.00	03.00		Tree branches touched line same rectified	-
9		Regulapally	Cheelapur	11KV	Husnabad	00.00	12.00	12.00		Tree branches touched line same rectified	-
10		Akunoor	Rampoor	11KV	Husnabad	02.20	12.10	09.50		Lines touched same rectified	-
11		Gurjakunta	Vechareni	11KV	Husnabad	00.00	15.00	15.00		Tree branches touched line same rectified	-
12		Komuravelly	Komuravelly Agl	11KV	Husnabad	00.00	08.30	08.30		Conductor snapped same rectified	-
13		Komuravelly	Kistampet	11KV	Husnabad	09.10	10.15	01.05		Insulator failed same rectified	-
14		Bekkal	Kutigal	11KV	Husnabad	00.00	09.00	09.00		Insulator failed same rectified	-
15		Rebarthy	Gagillapur Agl	11KV	Husnabad	00.00	08.20	08.20		Insulator failed same rectified	-
16		Rebarthy	Rebarthy	11KV	Husnabad	00.00	10.30	10.30		Insulator failed same rectified	-
1	RR S	Ibrahimbagh	Peddamangalram (IBGH)	11KV	RJNR	02.50	03.55	01.05	B/D	11KV Disc Failed at Bagyanagar	-
2		Chanda Nagar	Shanti Nagar	11KV	Gachibowli	01.15	02.30	01.15	B/D	11kv Cable failed at Shanti Nagar.(Back feeding from 11kv Chanda Nagar Feeder)	-
3		Nallagandla	EPISPOM School	11KV	Gachibowli	02.10	03.15	01.05	B/D	11kv Disk failed at Epispom School	-
4		IIIT	Jayabheri	11KV	Gachibowli	01.02	02.20	01.18	B/D	11kv Disk failed at Navayuga	-
5		Borabanda	Padmavathi Nagar	11KV	Kondapur	16.30	18.00	01.30	0.75	Cloth fallen on the 11kv line at borabanda railway station	-
1	RR N	HMT	Gandhi Nagar	11KV	Medchal	23.37	00.30	00.53		Alternate supply arranged from chinthal feeder from chithal SS	-
2		Subhash Nagar	Padma Nagar	11KV	Medchal	15.30	16.20	00.50		No Fault	-
3		Kompally	Kompally	11KV	Medchal	18.25	18.50	00.25		Line AB Switch Opened at Dulapally Chowrasta(100KV T/F Cable kit failed at AMR Apartment)	-
4		Kolthur	Vishwa	11KV	Medchal	00.00	03.40	03.40		11KV Disc failed at Vishwa Company	-
5		ICICI	ICICI	11KV	Medchal	00.50	04.40	03.50		No Fault	-
6		Jeeditmetla-IV	Auto Stand	11KV	JDML	16.55	18.55	02.00	EL/OL	11kv Disk failure At auto stand	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR E	Nacharam Indore	Gouthami Pipes	11KV	Habsiguda	23.21	01.26	02.05		11KV 2Nos Jumper cut at Road No.01 & Times Of India at IDA Nacharam	-
2		NGRI	Habsiguda	11KV	Habsiguda	04.50	06.40	01.50		11KV Disc failed near Ramalayam St.No.01 at Habsiguda	-
3		IDA Uppal	Metro	11KV	Habsiguda	20.21	21.39	01.18		11KV Disc failed near Organised Company at IDA Uppal & AB Switch opened at LIC Building	
4		Peerzathiguda	Peerzathiguda	11KV	Keesara	22.40	04.00	05.20		Line Patrolling but no visible fault	
5		Peerzathiguda	Chenna Reddy Thota	11KV	Keesara	23.58	01.20	01.22		Stick fallen on 11KV Line near Old Andhra Bank	
6		Keesara	Anki Reddy Pally	11KV	Keesara	21.10	22.20	01.10		Kite stick fallen on 11kv line near Goshala Road at Keesara Rice Mill	
1	HYD S	Teegalaguda	Milk Booth	11KV	VIII	00.13	01.30	01.17	EL,OL-Yph	Cable End Kit failed at Saleem Nagar Milk Booth	-
2		Moosarambagh	Shalivahana Nagar	11KV	VIII	00.20	02.10	01.50	EL	No Visible Fault	-
3		Asmangadh	Gadiannaram	11KV	VIII	00.35	03.17	02.42	EL,OL	Cable fault	Arranged B/F on 11KV Tirumala Hills feeder
4		Patlaburz	Murali Nagar	11KV	III	01.05	02.48	01.43	EL,OL-Rph	No Visible Fault	-
5		Vittalwadi	Ramkoti	11KV	IX	12.45	13.52	01.07	EL	HT Insulator blast at Ramkoti	-
6		Miralam	Madina Masjid	11KV	III	15.40	16.50	01.10	EL,OL	2No. Kite sticks on lines at Hasan Nagar	-
7		Aliyabad	Boys Town	11KV	III	14.54	17.20	02.26	EL	Pin Insulator flash over at Khabrasthan	-
8		Miralam	Tadbun	11KV	III	15.50	18.05	02.15	EL,OL	HT Insulator blast at Kalapather PS	-
9		Kulsumpura	Ambedkar Nagar	11KV	IX	16.50	18.08	01.18	EL,OL	Kite sticks fallen on lines at Tallagadda	-
10		Ch' Baradari	Dood Bowli	11KV	III	20.30	22.40	02.10	EL	AB Cable End Kit failed at Naseema Café	-
1	HYD C	Asif Nagar	Mehdipatnam Cable	11KV	VII	01.02	02.19	01.17	EL,OL	Pin Insulator flash over at Annapurna Residency	-
2		Bathkammakunta	Ramalayam	11KV	II	01.55	05.26	03.31	All Indication	Tree branches fallen on lines near Ramalayam Temple	-
3		Chilalguda	Parsigutta	11KV	II	02.05	06.15	04.10	EL	Polymer Disc Insulator flash over at Hanuman Temple	-
4		Mothi Mahal	Heera Khana	11KV	VII	15.32	16.48	01.16	EL	Kite sticks fallen on lines at Heera Khana	-