

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		6		6		6			
3	MDK	107	933		2		2		2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	8	0	8	0	8	0	0	
	Grand Total	1082	6468	0	12	0	12	0	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 31.01.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Thungathurthy	Vempaty	11KV	Suryapeta	07.28	09.30	02.02	E/L	11KV Jumper cut	-
2		Palakeedu	Sajjapuram	11KV	Huzurnagar	10.00	13.00	03.00	E/L	11KV Insulators failures	-
3		Gaddipally	Medaram	11KV	Huzurnagar	10.30	14.30	04.00	E/L	11KV Insulators failures	-
4		Kethepally	Korlapahad	11KV	Nalgonda	12.00	16.10	04.10	E/L	11KV Jumper cut	-
5		Rajapeta	Narsapur	11KV	Bhongiri	06.30	09.00	02.30	E/L	11KV Insulators failure	-
6		Addagudur	CH.Ramaram	11KV	Bhongiri	07.00	08.30	01.30	E/L	11KV Line Snapped	-
1	MDK	KONDAPUR	MAREPALLY	11KV	Sangareddy	09.15	14.00	04.45		B/D DUE TO 11KV INSULATOR FAIL AT SHAHIDAPUR	-
2		Thornal	Yellogai	11KV	Jogipet	07.12	07.12	02.00		B/D due to Juper Cut near Yellogai(V)	-
1	RR N	Chinthal	Surya nagar	11KV	Medchal	14:20	15:40	1:20		11KV Cable End kit failed at Surya Nagar(Backfeeding to 11KV Padma Nagar feeder)	-
2		Athiwelly	Somaram	11KV	Medchal	16:15	17:15	1:00		Bird Fallen on 11KV Line at SC Colony, Somaram Village	-
1	HYD N	Chilkaiguda	P.R Nagar	11KV	Sec-Bad	16.05	17.10	01.05	EL	Brass Patties phase to phase at Garunda Apts	-
1	HYD S	Panjasha	Bibi Bazar	11KV	Charminar	08.06	09.24	01.18	EL,OL	HG fuse blown at Bibi Bazar	-