

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		14		14		14			
7	RR(E)	168	403		12		12		12			
8	Hyd	194	1044		23		23		23			
	Total	606	3055	0	51	0	51	0	51	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	24	1	15	1	15	1			9 Nos. 33KV Still
2	NLG	144	988	12	5	7	5	7	5			5 Nos. 33KV Still
3	MDK	107	933		3		3		3			
4	SDPT			1	2	1	2	1	2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	37	11	23	11	23	11	0	0	
	Grand Total	1082	6468	37	62	23	62	23	62	0	0	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Jadcherla	33KV	Mahabubnagar	18.32	18.48	00.16	EL	Heavy rain and Wind	Jadcherla	-
2		Mahabubnagar	Machanpally	33KV	Mahabubnagar	19.10	21.15	02.05	OL	AB Switch closed	Machanpally	-
3		Kodangal	Hamsanpally	33KV	Vikarabad	19.05	21.35	02.30	EL	Insulator failed	Hamsanpally	-
4		Kodangal	Peddanandigama	33KV	Vikarabad	19.20	22.45	03.25	EL	Heavy rain and Wind	Peddanandigama	-
5		Kodangal	Kothur	33KV	Vikarabad	22.45	00.00	01.15	EL	Not Rectified	Kothur	-
6		Balanagar	Kollur	33KV	Jadcherla	20.05	22.05	02.00	EL	Line touching to Pole rectified purpose	Kollur	-
7		Balanagar	Chinchode	33KV	Jadcherla	16.40	20.35	03.55		Tree follen on the 33KV line	Chinchode	-
8		Polepally	Jadcherla	33KV	Jadcherla	19.38	21.32	01.54	EL	Pin insulator replacement near Sezdj	Jadcherla	-
9		Maddur	Damargidda	33KV	Narayanapet	20.40	03.05	06.25	EL	Pin baining failed and replaced	Damargidda	-
10		Marikal	Koilkonda Water Grid	33KV	Narayanapet	18.49	21.30	02.41		Heavy rain and Wind	Koilkonda Water Grid	-
11		Marikal	Devarkadra	33KV	Narayanapet	21.40	22.15	00.35		No visible fault	Devarkadra	-
12		Makthal	Gudeballore	33KV	Narayanapet	23.40	00.00	00.20		Not Rectified	Gudeballore	-
13		Wanaparthy	Kodair	33KV	Wanaparthy	21.25	00.00	02.35	EL	Not Rectified	Kodair	-
14		Chinnamaroor	Kalwarala	33KV	Wanaparthy	22.05	22.10	00.05	EL	Heavy rain and Wind	Kalwarala	-
15		Gadwal	Bijwara	33KV	Gadwal	20.55	00.00	03.05	EL	Not Rectified	Bijwara	-
16		leeza	T T Doddi	33KV	Gadwal	23.52	00.00	00.08	EL	Not Rectified	T T Doddi	-
17		leeza	Madelabanda	33KV	Gadwal	23.56	00.00	00.04	EL	Not Rectified	Madelabanda	-
18		Nagarkurnool	Ithole	33KV	Nagarkurnool	20.36	00.00	03.24	EL	opening of jumpers at Ithole SS	Ithole	-
19		Nagarkurnool	Bijinepally	33KV	Nagarkurnool	03.10	10.30	07.20	EL	Pine Biending work at Bijinapally	Bijinepally	-
20		Nagarkurnool	Bijinepally	33KV	Nagarkurnool	22.06	23.20	01.14	EL	AB Switch open at Bijinepally SS	Bijinepally	-
21		Achampet	Lingal	33KV	Nagarkurnool	19.05	00.00	04.55	EL	Not Rectified	Lingal	-
22		Shadnagar	Salasar	33KV	Shadnagar	19.11	22.05	02.54	EL	B Phase Pin insulator failure naer Yeligadda Vijjage	Salasar	-
23		Amangal	Kadthal	33KV	Shadnagar	19.00	00.00	05.00		Not Rectified	Kadthal	-
24		Kothur	PNG	33KV	Shadnagar	23.05	00.00	00.55		Not Rectified	PNG	-
1	NLG	Wadapally	A.D.Pally	11KV	Miryalaguda	15.55	18.20	03.05		Heavy rain and Wind	A.D.Pally	-
2		220 KV Miryalaguda	Miryalaguda	11KV	Miryalaguda	15.15	18.20	03.05		Pin Binding Loosen,Line fallen on ground on ground	Miryalaguda	-
3		Madgulapally	Laxmidevigudem	11KV	Miryalaguda	15.15	20.30	05.15		Heavy rain and Wind	Laxmidevigudem	-
4		Madgulapally	Thipparthy	11KV	Nalgonda	15.10	00.00	08.50		Not Rectified	Thipparthy	Alternate supply to Agamothkur 18:20 Hrs
5		Aitipamula	Nakrekal	11KV	Nalgonda	15.40	18.50	03.10		Heavy rain and Wind	Nakrekal	-
6		Nalgonda	Rayanguda	11KV	Nalgonda	15.58	00.00	08.02		Not Rectified	Rayanguda	Alternate supply to Agamothkur 18:20 Hrs
7		Nalgonda	Mamillagudem	11KV	Nalgonda	16.00	21.00	05.00		Tree fallen on near Mamillagudem	Mamillagudem	-
8		K.M.Pally	Neredugomma	11KV	Devarakonda	18.10	00.00	05.50		Not Rectified	Neredugomma	Alternate Supply Arranged
9		K.M.Pally	Pendlipakala	11KV	Devarakonda	18.10	00.00	05.50		Not Rectified	Pendlipakala	Alternate Supply Arranged
10		Suryapeta	Nemmikal	11KV	Suryapeta	18.00	00.00	06.00		Not Rectified	Nemmikal	Alternate Supply Arranged
11		Suryapeta	Chivemla	11KV	Suryapeta	18.00	19.30	01.30		pin Binding Loosen	Chivemla	-
12		Suryapeta	MJR	11KV	Suryapeta	18.00	19.00	01.00		Heavy rain and Wind	MJR	-
1	SDP	Chandlapur	Kamarlapally	33KV	SIDDIPET	11.30	12.25	00.55		LOOSE COLLECTION	Kamarlapally	-

TSSPDCL - LMRC / Corporate office

Date: 06.06.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Pedda revelly	Pedda revelly	11KV	Jadcherla	08.53	11.20	02.27		11 KV disk fail near Raghuma reddy DTR at peddarevelly (v)	-
1	NLG	Aipoor	Kotapahad	11KV	Suryapet	10.00	11.40	01.40		Insulator Failed	-
2		Polecenter	Telephone exchange	11KV	Nalgonda	18.50	21.05	02.15		33 KV Line fallen on 11 Kv Line	-
3		Polecenter	Railway	11KV	Nalgonda	18.50	21.05	02.15		33 KV Line fallen on 11 Kv Line	-
4		Narketpally	Narketpally	11KV	Nalgonda	04.00	09.00	05.00		4 Nos 11 KV pole damaged	-
5		Akkenapally	Reliance	11KV	Nalgonda	18.30	21.45	03.15		Heavy rain and Wind	-
1	MDK	Patancheru	MIA-II	11KV	Patancheru	18.20	20.50	02.30		B/D due to Conductor snapped	-
2		Patancheru	Allwyn	11KV	Patancheru	18.30	19.50	01.20		B/D due to Disk failure	-
3		SOL	Markwel	11KV	Patancheru	21.20	22.50	01.30		B/D due to Tree branches fallen on the line	-
1	SDP	Chityal	Chityal	11KV	Husnabad	16.10	18.20	02.10		Line Snapped	-
2		Chityal	Thadoor	11KV	Husnabad	17.05	18.25	01.20		Line Snapped	-
1	RR S	ESCI	Nanakramguda	11KV	GCB	09.36	11.03	01.27		HT Service UG-Cable damaged near NCB bhavan	-
2		Nallagandla	EPISPOM School	11KV	GCB	19.00	20.05	01.05		Tree branches fallen on the 11kv line at EPISPOM School	-
1	RR N	Mayurinagar	Lezand	11KV	Kukatpally	18.30	22.20	03.50	EL	Tree brachesh fallon the 11kv line Near Ladies Hostel at Mayurinagar	-
2		Mayurinagar	G R R R	11KV	Kukatpally	19.02	21.43	02.41	EL	Construction Stick Fallon the 11kv line at RLCT apt at G R R R	-
3		Guntur Vikas	Volvo	11KV	Kukatpally	18.17	19.36	01.19	EL	Tree brachesh fallon the 11kv line at Janachaithanya Colony	-
4		Jeedimetla-II	Phase-IV	11KV	Jeedimetla	18.12	19.20	01.08	EL	Tree branchesh fallon the 11kv line at phase-IV	-
5		HMT	Venkanna Hills	11KV	Medchal	18.10	19.40	01.30	EL	Tree fallon on the 11KV Line at Quthbullapur	-
6		HMT	Ganesh Nagar	11KV	Medchal	18.30	19.20	00.50	EL	Tree fallon on the 11KV Line at NTR Nagar	-
7		Petbasheerabad	Balaji Hospital	11KV	Medchal	19.37	20.33	00.56	BD	Tree fallon on the 11KV Line at Panchashila colony	-
8		Subhash Nagar	Padma Nagar	11KV	Medchal	19.30	19.35	00.05	BD	11KV Line AB Switch opened at Chaise company (Tree fallon on the 11KV Line)	-
9		Dppaly-II	Indo Fab	11KV	Jeedimetla	18.05	19.15	01.10	BD	Tree branchesh fallon the 11kv line at Doctor basthi	-
10		Aliabad	Jaganguda	11KV	Medchal	08.30	08.40	00.10	BD	11KV Line AB Switch opened at LGM Pet	-
11		Medchal	IDA Kandlakoya	11KV	Medchal	17.15	20.10	02.55	EL	Tree fallon on the 11KV Line at ORR	-
12		Medchal	Check Post	11KV	Medchal	18.35	19.50	01.15	EL	Tree fallon on the 11KV Line at Maruthi shoroom	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
13		Medchal	CMR	11KV	Medchal	18.50	19.45	00.55	EL	Tree fallon on the 11KV Line at Ganga kaveri	-
14		Yellampet	IDA Yellampet	11KV	Medchal	20.20	22.00	01.40	BD	Tree fallon on the 11KV Line at Yellampet x Road	-
1	RR E	Kushaiguda	Rukminipuri	11KV	Sainikpuri	18.50	19.40	00.50		Flex fallen on 11Kv line at Ram Raju Cotton Brundavan Colony (AE/SKP)	-
2		VP Nagar	Madhura Nagar	11KV	Sainikpuri	10.30	11.00	00.30		Tree branches fallen on 11Kv line at Sri Colony (L Insp Koteswar Rao)	-
3		Vasanthapuri	Venkateshwar Nagar	11KV	Sainikpuri	15.36	16.49	01.13		Tree branches fallen on 11Kv line on Remooved at Shawales Compony (L Insp Narsing Rao)	-
4		Vasanthapuri	Ragavendra	11KV	Sainikpuri	17.00	18.02	01.02		Tree branches fallen on 11Kv line at Railway Colony (L Insp Narsing Rao)	-
5		VP Nagar	VV Puram	11KV	Sainikpuri	21.08	21.54	00.46		Tree fallen on 11Kv line at VV Puram (LM Chandra Shekar)	-
6		St.No.08	Eggwood	11KV	Habsiguda	18.18	19.54	01.36		Due to heavy rain & gale & Line patrolling but no visible fault	-
7		Uppal	Uppal	11KV	Habsiguda	19.05	20.10	01.05		Tree branches fallen on 11KV line at Vijayapuri Colony	-
8		IICT	Nacharam	11KV	Habsiguda	18.40	19.45	01.05		Line patrolling but no visible fault & B/F supply taken from 11KV Vyjayanthi feeder	-
9		IDA Uppal	Metro	11KV	Habsiguda	18.06	21.25	03.19		11KV Jumper cut at SS Yard & Tree branches fallen on 11KV line near Videocon Company	-
10		Ramanthapur	Gokhale Nagar	11KV	Habsiguda	18.43	20.00	01.17		Flexi Banner fallen on 11KV line at Ramanthapur Main Road Tower	-
11		Chengicherla	My Villas	11KV	Keesara	13.20	14.30	01.10		11KV Brass patti cut at Plasma India Company	-
12		Yadgarpally	Cheeryal	11KV	Keesara	08.35	09.30	00.55		Snake fallen on 11kv line at Cheeryala	-
1	HYD N	Lodha	Crown Casting	11KV	IV	18.20	19.35	01.15	EL,OL	Tree branches fallen on lines at Lodha	-
2		Clock Tower	R.P.Road	11KV	V	18.40	20.25	01.45	EL,OL-Rph	Cable fault	Arranged B/F on 11KV Anjali feeder
3		I.D.P.L	Tipcon	11KV	VI	18.15	19.20	01.05	EL,OL-Bph	Tree branches fallen on lines at Ashwini Gally	-
4		Bowenpally	Ferozguda	11KV	VI	18.15	20.35	02.20	OL-R&Yph	HT Line snapped at Ferozguda	-
5		H.A.L	Sowbagya Nagar	11KV	VI	18.20	19.50	01.30	EL,OL-Bph	Tree branches fallen on lines at Sowbagya Nagar	-
6		Prashanth Nagar	Andhra Jyothi	11KV	VI	18.30	19.35	01.05	EL	No Visible Fault (due to heavy wind)	-
7		Marredpally	A.O.C	11KV	C-VI	17.05	18.30	01.25	EL	No Visible Fault (due to heavy wind)	-
8		Maitrivanam	Saradhi Studio	11KV	X	18.05	19.05	01.00	All Indication	Tree branches fallen on lines at Althaf Hotel	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
9		Kalyan Nagar	Vengalrao Nagar	11KV	X	18.11	20.20	02.09	EL	Tree branches fallen on lines at Heritage Fresh	-
10		Jubilee Hills	I.O.A.	11KV	X	18.50	19.55	01.05	EL,OL-R&Bph	Tree branches fallen on lines at Road No.44	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD S	Miralam	Hasan Nagar	11KV	III	18.35	19.45	01.10	EL,OL	No Visible Fault (due to heavy wind)	-
2		Salarjung	Darulshifa	11KV	III	18.51	20.30	01.39	EL	No Visible Fault (due to heavy wind)	-
3		Moosarambagh	SBI Colony	11KV	VIII	18.15	20.40	02.25	OL-R&Bph	Cable Jumpers cut at SS & Hanuman Temple	-
4		Durga Nagar	Saleem Nagar	11KV	VIII	18.25	20.30	02.05	EL	RMU Jumper cut at RTO Office	-
5		Asmangadh	Saidabad Colony	11KV	VIII	19.18	20.20	01.02	OL-Rph	HT Jumper cut at Subramanya Park	-
1	HYD C	Public Garden	Nampally Railway Station	11KV	I	18.08	20.50	02.42	OL-Y&Bph	3No. Jumpers cut at Huz House	-
2		Exhibition	Collector Office	11KV	I	19.30	20.35	01.05	EL,OL-Rph	Tree branches fallen on lines at Rama Krishna Theatre	-
3		Fever Hospital	Sri Ram Nagar	11KV	II	17.45	19.04	01.19	OL-R&Bph	Tree branches fallen on lines at Sri Ram Nagar	-
4		Golnaka	Shivalayam	11KV	II	17.48	19.50	02.02	EL,OL	Tree branches fallen on lines at Shivalayam	-
5		Durga Nagar	Sunder Nagar	11KV	II	18.25	19.30	01.05	EL,OL-Rph	No Visible Fault (due to heavy wind)	-
6		Asif Nagar	Military	11KV	VII	18.00	20.25	02.25	EL	Faulty CT PT at Military Area	-
7		Asif Nagar	Kakatiya Nagar	11KV	VII	18.23	19.32	01.09	EL,OL-R&Bph	No Visible Fault (due to heavy wind)	-
8		A.S.R.Raju Nagar	LIC Office	11KV	VII	18.25	19.37	01.12	EL	Faulty DTR at More Super Market	-