

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		16		16		16			
6	RR(N)	54	550	2	58	2	58	2	58			
7	RR(E)	168	403		31		31		31			
8	Hyd	194	1044		112		112		112			
	Total	606	3055	2	217	2	217	2	217	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	10	11	10	11	10	11			
2	NLG	144	988	15	58	15	58	15	58			
3	MDK	107	933	6	13	6	13	6	13			
4	SDPT			11		11		11				
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	42	82	42	82	42	82	0	0	
	Grand Total	1082	6468	44	299	44	299	44	299	0	0	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Mahabubnagar	33KV	Jadcherla	02.55	03.05	00.10	E/L&O/L	Due to Heavy Rain	Mahabubnagar	Back Feeding Supply Arranged from 132KV Polepally SS at 3:05Hrs.
2		Vikarabad	Kodangal	33KV	Kodangal	03.02	09.10	06.08	O/L	Break Down No Visible Fault Due to Heavy Rain	Kodangal	No
3		Vikarabad	Kodangal	33KV	Hamsanpally	03.05	09.50	06.45	E/L	Pin Insulator Damaged at Hamsanpally SS	Kodangal	No
4		Jadcherla	Balanagar	33KV	Rajapur	5:35	6:55	1:20	E/L & O/L	No Visible Fault Due to Heavy Rain	Balanagar	No
5		Narayanapet	Makthal	33KV	Narayanapet	2:40	6:30	3:50	E/L	Break Down No Visible Fault Due to Heavy Rain	Makthal	No
6		Narayanapet	Marikal	33KV	Koukuntla	3:50	8:04	4:14	E/L	for Pin Binding Failed Koukuntla	Marikal	Alternate Supply Arranged from 33KV Koukuntla SS at 8:04Hrs
7		Narayanapet	Marikal	33KV	Koilkonda Water	3:45	9:10	5:25	E/L	No Visible Fault Due to Heavy Rain	Marikal	No
8		Wanaparthy	Ghanapur	33KV	Lattupally	4:27	8:36	4:09	E/L	Tree Fallen on the Line near at Manganoor (V)	Ghanapur	No
9		Gadwal	Gadwal	33KV	Bijwaram	5:58	13:05	7:07	E/L	Pin Insulator Damaged	Gadwal	No
10		Shadnagar	Sri Rangapur	33KV	Utharaspally	02.41	06.28	03.47	O/L	Tree fallen on the line Utharasapally	Sri Rangapur	No
1	NLG	Aitipamula	Aitipamula	33KV	Nalgonda	5:05	8:18	3:13		Tree fallen on line	Aitipamula	No
2		Nalgonda	Anneparthi	33KV	Nalgonda	03.30	08.45	05.15		Jumper cut	Anneparthi	No
3		Marriguda	Gattupal	33KV	Devarakonda	10.25	11.55	01.30		Insulator and Pinbinding failure	Gattupal	No
4		Miryalaguda	Huzurnagar	33KV	Miryalaguda	04.30	10.00	05.30		Pole damaged	Huzurnagar	No
5		Shaligouraram	Arvapally	33KV	Suryapet	06.25	10.15	03.50		Yard clamp damaged	Arvapally	No
6		Thungathurthi	Ravulapally	33KV	Suryapet	05.25	10.05	04.40		Disc Failure	Ravulapally	No
7		Thungathurthi	Annaram	33KV	Suryapet	05.25	13.00	07.35		Jumper cut	Annaram	No
8		Thungathurthi	Phanigiri	33KV	Suryapet	05.25	07.44	02.19		Disc Failure	Phanigiri	No
9		Thungathurthi	Thungathurthi	33KV	Suryapet	03.45	05.25	01.40		Moment fault	Thungathurthi	No
10		Dilshancherla	Watergrid	33KV	Suryapet	04.00	12.00	08.00		Insulator Failed	Watergrid	No
11		B.B.Nagar	Bhongir	33KV	Bhongir	06.25	08.25	02.00		Jumper cut	Bhongir	No
12		B.B.Nagar	B.P.Pally	33KV	Bhongir	02.20	06.20	04.00		B/D/Heavy Moment fault	B.P.Pally	No
13		B.B.Nagar	M.L.R	33KV	Bhongir	02.25	07.10	04.45		B/D/Moment fault	M.L.R	No
14		Ramannapet	Aroor	33KV	Choutuppal	02.45	10.15	07.30		Tree fallen on line	Aroor	No
15		Ramannapet	Yelanki	33KV	Choutuppal	2:30	10:20	7:50		Line Felt the Stay Wire	Yelanki	No
1	MDK	Zaheerabad	Mannapur	33KV	Sangareddy	0:30	11:17	10:47		Insulator Flashover	Mannapur	No
2		Borapatla	Waddepally	33KV	Jogipet	01.27	09.36	08.09		Insulator Failure near Borapatla Water Plant	Waddepally	No
3		R.C.Puram	AP Files	33KV	Patancheru	01.30	09.28	07.58		Insulator Failure	AP Files	No
4		Sadasivpet	Koheer	33KV	Sangareddy	01.35	08.05	06.30		Isolator opened at Koheer ss	Koheer	No
5		Sadasivpet	Jogipet	33KV	Sangareddy	03.25	06.45	03.20		Isolator opened at Jogipet ss	Jogipet	No
6		Kandi	HFC-1	33KV	Sangareddy	1:50	9:20	7:30		R B Phase Jumper cut	HFC-1	No

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	SDPT	Habsipur	Thimmapur	33KV	Siddipet	0:00	1:40	1:40		Breakdown	Thimmapur	No
2		Palamakula	Gonnepally	33KV	Siddipet	23.25	1.25	02.00		Breakdown	Gonnepally	No
3		Palamakula	Nangnoor	33KV	Siddipet	00.24	01.23	00.59		Breakdown	Nangnoor	No
4		Thunkibollaram	Wantimamidi	33KV	Gajwel	0.01	1.44	01.43		Breakdown	Wantimamidi	No
5		Thunkibollaram	Seethrampally	33KV	Gajwel	2.55	6.55	04.00		Breakdown	Seethrampally	No
6		Thunkibollaram	khesarasagara	33KV	Gajwel	1.46	5.30	03.44		Breakdown	khesarasagara	No
7		Angadikistapu	Wardarajapur	33KV	Gajwel	9.50	13.00	03.10		Breakdown	Wardarajapur	No
8		Husnabad	Ganeshpally	33KV	Husnabad	11.00	12.20	01.20		Breakdown	Ganeshpally	No
9		Musthyal	Cheriyal	33KV	Husnabad	12.20	13.00	00.40		Breakdown	Cheriyal	No
10		Musthayl	Dhoolmitta	33KV	Husnabad	1.05	2.25	01.20		Breakdown	Dhoolmitta	No
11		Musthayl	Tharigopula	33KV	Husnabad	4.10	4.30	0:20		Breakdown	Tharigopula	No
1	RR N	132KV Malkaram	Ratnalayam	33KV	Medchal	1:22	2:30	1:08		33KV Pin Insulator Replaced at Thimaipally X Road	Ratnalayam	No
2		132KV DP Pally	Gowdavelly	33KV	Medchal	01.00	03.22	02.22		Tree fallen on 33KV Line at Police station , DP Pally	Gowdavelly	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Balanagar	Mothiganpur	11KV	Jadcherla	08.38	14.19	05.41		Due to tree fallen on 11 KV line	No
2		Rajapur	Mudireddy pally	11KV	Jadcherla	03.00	10.50	07.50		11 KV wire cut near Mudireddy pally	No
3		Janampet	Musapet	11KV	Jadcherla	06.50	08.45	01.55		Due to 11 KV insulater fail near chakrapur	No
4		Kothapally	Velgomla	11KV	Jadcherla	8:28	11:58	3:30		Due to 11 KV Disk fail near Chilver (V)	No
5		Kothapally	Kanchanpally	11KV	Jadcherla	8:35	10:05	1:30		Due to 11 kv insulater fail near chegunta	No
6		Marikal	Chakalapally	11KV	Jadcherla	6:15	11:00	4:45		Due to 11 KV wire cut near chakalapally	No
7		Kothamolgara	Kothamolgara	11KV	Jadcherla	6:45	9:25	2:40		Due to tree fallen on 11 KV line	No
8		Mothiganpur	Gangadar pally	11KV	Jadcherla	9:10	13:50	4:40		Due to 11 KV wire cut near ganga dar pally	No
9		Addakal	Gudibanda	11KV	Jadcherla	2:34	8:12	5:38		Due to 11 KV jumper cut near gudi banda	No
10		Addakal	Chinna mungal chedu	11KV	Jadcherla	2:36	9:30	6:54		Due to 11 KV insulateer fail near pedda mangul chedu	No
11		Peddarevelly	Chinnarevelly	11KV	Jadcherla	01.50	12.20	10.30		Due to 11 KV wirecut near poshamma gadda thanda	No
1	NLG	Eduloor	Naragudem	11KV	Nalgonda	4:00	6:30	2:30	E/L	11KV jumper cut	No
2		Mushampally	Mushampally AGL	11KV	Nalgonda	00.00	06.00	06.00	E/L	11KV jumper cut	No
3		Eduloor	Kurumarthy	11KV	Nalgonda	05.00	09.30	04.30	E/L	11 KV Jumper Cut Under SS-5	No
4		Aitipamula	Gangadevigudem	11KV	Nalgonda	08.30	10.10	01.40	E/L	Tree Fallen on 11 KV Line	No
5		Aitipamula	R.C.Puram	11KV	Nalgonda	08.30	10.10	01.40	E/L	Tree Fallen on 11 KV Line	No
6		Aitipamula	Rasoolgudem	11KV	Nalgonda	08.30	09.40	01.10	E/L	11 KV Jumper Cut	No
7		Gundrampally	Tolgate	11KV	Nalgonda	05.00	09.00	04.00	E/L	Tree Branches Fallen on the 11 KV Line	No
8		Veliminedu	Parepally	11KV	Nalgonda	04.30	09.15	04.45	E/L	11 KV Insulator Failed	No
9		Urumadla	Tallavellemia	11KV	Nalgonda	05.40	10.15	04.35	E/L	11 KV Jumper Cut at Vembai	No
10		Narsingbatla	Chennugudem	11KV	Nalgonda	04.40	07.45	03.05	E/L	11 KV Pole Damage at Kodandapuram (V)	No
11		Akkenapally	Ammanabole	11KV	Nalgonda	07.00	09.00	02.00	E/L	11 KV Pin Insulator Failed at Bendalpahad	No
12		Nemmani	Merlakunta	11KV	Nalgonda	02.30	10.00	07.30	E/L	11 KV Line Melt	No
13		Nemmani	Pothinenipally	11KV	Nalgonda	02.30	10.00	07.30	E/L	11 KV Line Melt	No
14		Thipparthy	Thipparthy town	11KV	Nalgonda	06.40	10.40	04.00	E/L	Tree Branches Fallen on the 11 KV Line	No
15		Thipparthy	Gangannapalem	11KV	Nalgonda	02.40	14.05	11.25	E/L	Tree Branches fallen on the 11 KV line and LT Line Melt	No
16		Thipparthy	Marrigudem	11KV	Nalgonda	02.40	10.35	07.55	E/L	Due to Heavy Gale and Wind	No
17		Thipparthy	Indloor	11KV	Nalgonda	02.40	10.40	08.00	E/L	11 KV Insulator Failed	No
18		Thipparthy	Sarvaram	11KV	Nalgonda	02.40	14.40	12.00	E/L	11 KV Jumper Cut	No
19		Thipparthy	Silarmiyagudem	11KV	Nalgonda	02.40	14.45	12.05	E/L	T4ree Falln on the 11 KV Line	No
20		Rayaniguda	Jangareddygudem	11KV	Nalgonda	02.40	09.30	06.50	E/L	AB Switch Open at Mallepally Gudem (Partial Line Charged) 3-Ph Supply Ok	No
21		Thimmannagudem	Chennaram	11KV	Nalgonda	07.30	09.30	02.00	E/L	Tree Branches Fallen on the 11 KV Line at Bobbakligudem Village	No
22		Akaram	Shanthinagar	11KV	Nalgonda	07.00	11.09	04.09	E/L	Tree Branches Fallen on the 11 KV Line at Adloor Village	No
23		Eduloor	Parada	11KV	Nalgonda	04.00	10.30	06.30	E/L	11 KV Jumper Cut Under SS-3	No
24		Mupparam	yerrabelly	11KV	Miryalaguda	03.10	14.10	11.00		insulator failed	No
25		Mupparam	Mupparam	11KV	Miryalaguda	03.10	06.25	03.15		line snapped	No
26		pottichelma	Navodaya	11KV	Miryalaguda	03.00	09.15	06.15		insulator failed	No
27		pottichelma	Parvedula	11KV	Miryalaguda	03.30	07.45	04.15		line snapped	No
28		Devarakonda	K.B.Pally	11KV	Devarakonda	07.15	07.50	00.35	E/L	Moviment Fault	No
29		Devarakonda	Mynampally	11KV	Devarakonda	07.20	07.40	00.20	E/L	Moviment Fault	No
30		Devarakonda	Devarakonda town -II	11KV	Devarakonda	01.30	02.45	01.15	E/L	1 No 11KV Disc Failed	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
31		Pdamatpally	Iddampally	11KV	Devarakonda	02.35	09.20	06.45	E/L	11 KV Pin Insulator Failed	No
32		Pdamatpally	Erraguntlapally	11KV	Devarakonda	02.35	09.50	07.15	E/L	11 KV Jumper Cutt	No
33		Neredugomma	Neredugomma	11KV	Devarakonda	02.40	13.00	10.20	E/L	25 KVDTR Failed	No
34		Neredugomma	Kethepally	11KV	Devarakonda	03.00	11.00	08.00	E/L	11 KV Disc Failed	No
35		Angaipeta	Akkampally	11KV	Devarakonda	06.00	08.30	02.30	E/L	Tree Follen	No
36		Ghanapuram	G.B.pally	11KV	Devarakonda	02.30	09.20	06.50	E/L	11 kv Insulator Failed	No
37		Dugayala	Dugayala	11KV	Devarakonda	03.20	09.00	05.40	E/L	LT Line Cutt	No
38		Pochampally	Pochampally	11KV	Devarakonda	03.00	07.30	04.30	E/L	11 KV Jumper cutt	No
39		K.M.Pally	Palvai	11KV	Devarakonda	09.10	11.20	02.10	E/L	11 KV Jumper Cutt	No
40		Aipoor	Kotapahad	11KV	Suryapet	06.30	09.10	02.40	E/L	Insulator Failed	No
41		Yerkaram	Dasthanda	11KV	Suryapet	13.00	14.30	01.30	E/L	HT /LT Line melt	No
42		Gundepuri	Gundepuri	11KV	Suryapet	11.00	13.10	02.10	E/L	INSULATOR FAILED	No
43		Palakeedu	Palakeedu	11KV	Huzurnagar	05.00	08.30	03.30	EL	11 KV INSLATER FAILED	No
44		Repala	V R Puram	11KV	Huzurnagar	05.30	08.30	03.00	EL	11 KV LINE SNAPPED	No
45		Nadigudem	Krishnanagar	11KV	Huzurnagar	04.30	07.00	02.30	EL	11 KV JUMPER CUT	No
46		Karvirala	Keshavapuram	11KV	Huzurnagar	05.00	08.30	03.30	EL	11 KV LINE SNAPPED	No
47		Ch.Laxmapur	Ch.Laxmapur	11KV	Bhongir	05.00	09.00	04.00	EL	11kv Disc Failed near Gopalapuram village	No
48		B.Ramaram	Jalal pur	11KV	Bhongir	06.00	08.30	02.30	OL	11kv Line snapped near Ranghapuram Village near	No
49		Y.Gutta	Wangapally	11KV	Bhongir	10.00	12.00	02.00	EL/OL	11kv Insulator Failed near Wangapally Vilage	No
50		Motakondur	Motakondur	11KV	Bhongir	01.00	07.00	06.00	EL	phase to phase near Motakondur Village	No
51		Motakondur	Vattoor	11KV	Bhongir	01.00	09.30	08.30	EL/OL	HT/LT near Vattor village	No
52		Addagudur	Addagudur	11KV	Bhongir	05.00	10.20	05.20	EL/OL	SS-3 Insulator Failed Addagudur Village	No
53		Paladugu	Duppally	11KV	Bhongir	08.00	12.30	04.30	EL/OL	HT/LT near Vattor village	No
54		Athmakur	Thukkapur	11KV	Bhongir	04.00	14.15	10.15	EL/OL	11kv Insulator Failed near Thukkapuram Village	No
55		Narayanpur	Maillacharu	11KV	Choutuppal	07.00	09.20	02.20	EL/OL	single Phase DTR Failed	No
56		D.Nagaram	D.Nagaram Indl	11KV	Choutuppal	08.05	09.50	01.45	EL/OL	11kv line phase to phase near sub_station near	No
57		Voligonda	Town	11KV	Choutuppal	05.40	08.15	02.35	EL/OL	11kv Line snapped near Sub_station near	No
58		Puligilla	Kanchanpally	11KV	Choutuppal	8:30	9:30	1:00	EL/OL	HT/LT near Kanchanpally Village	No
1	MDK	SOL	Markwell	11KV	Patancheru	10:25	13:05	2:45		Disc failed	No
2		Pati	Pati	11KV	Patancheru	00.35	08.45	08.10		Jumper cut	No
3		Patancheru Town	Shanthinagar	11KV	Patancheru	05.30	06.30	01.00		AB Switch failed	No
4		Bollaram - II	Vipla	11KV	Patancheru	00.35	18.00	17.25		Connductor Replaced	No
5		Bollaram - II	Vasavidatta	11KV	Patancheru	01.45	08.50	07.05		Disc Failed	No
6		Anrich Bollaram	Town-II	11KV	Patancheru	10.03	11.05	01.02		Jumper cut	No
7		Gaddapotharam -II	Khajipally Indl.	11KV	Patancheru	02.30	07.20	04.50		Tree Fallen on the line	No
8		Gummadidaia	Agrobell	11KV	Patancheru	00.55	12.35	11.40		Jumper Cut & line Problam	No
9		Gummadidala	Bell Remedies	11KV	Patancheru	00.48	10.30	09.42		Jumper Cut & line Problam	No
10		Bonthapally	Newland	11KV	Patancheru	00.45	09.10	08.25		Tree Fallen on the line	No
11		Gundla Machnoor	Industrial	11KV	Patancheru	04.00	09.30	05.30		Tree Fallen on the line	No
12		Almaipet 1x5	Andole 24 Hrs.	11KV	Jogipet	06.15	11.30	05.15		Tree Fallen on the line	No
13		Hathnoora	Town Ind	11KV	Jogipet	0:00	7:40	7:40		Tree Fallen on the line	No
1		MD Pally	Bandlaguda	11KV	RJNR	2:00	3:50	1:50		Tree branches fallen on 11KV Line at Bandlaguda	No
2		Kattedan-I	Feeder-II	11KV	RJNR	02.41	03.51	01.10		11kv Insulator Failed at Kailas Battery	No
3		Gaganpahad	Pelicon rubber	11KV	RJNR	02.41	05.45	03.04		11kv Insulator Failed at Goshala	No
4		Kismathpur	Vidyapeetam	11KV	RJNR	03.35	06.30	02.55		Tree branches Fallen on 11KV Line at Krishnanagar colony	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
5	RR S	Gachibowli	Sudharshan Nagar	11KV	Gachibowli	04.05	06.05	02.00		Due ot heavy wind and rain 1)11kv Pin-insalator failed at Dohen's , 2)11kv Disc failed at church 3)Tree branches fallen on the 11kv line at Navayuga	No	
6		Nanakramguda	Church	11KV	Gachibowli	00.58	03.22	02.24		Due ot heavy wind and rain , 11kv LABS Opened near Outerring road, Nanakramguda	No	
7		Nanakramguda	TNGO's Colony	11KV	Gachibowli	01.43	05.50	04.07		Due to heavy wind and rain , 11kv Pin-insulator failed at TNGO'S Colony	No	
8		IIIT	Jayabheri	11KV	Gachibowli	02.08	03.30	01.22		Due to heavy wind and rain	No	
9		IIIT	Jayabheri	11KV	Gachibowli	04.01	05.09	01.08		Due to heavy wind and rain	No	
10		Papireddy colony	Prem Nagar	11KV	Gachibowli	05.40	06.50	01.10		Due to heavy wind and rain	No	
11		Chandanagar	Madinaguda	11KV	Gachibowli	13.25	14.25	01.00		11KV Pin Insulator Failure near Sai Krupa Apartments at Madinaguda.	No	
12		Balaji Nagar	Balaji Nagar	11KV	Kondapur	01.09	02.52	01.43		Due to heavy wind and rain, 11kv LABS insulator failed at Ramdav Hospital	No	
13		Balaji Nagar	Dhanalaxmi	11KV	Kondapur	01.09	02.34	01.25		Due to heavy wind and rain,No visible fault found	No	
14		Balaji Nagar	4th Phase	11KV	Kondapur	01.09	05.27	04.18		Due to heavy wind and rain,No visible fault found	No	
15		Balaji Nagar	Moosapet	11KV	Kondapur	02.32	04.46	02.14		Tree branches fallen on the 11kv line at LIG-116	No	
16		SEZ	Rolling Hills	11KV	Kondapur	2:00	3:05	1:05		Due to heavy wind and rain,No visible fault found	No	
1			HMT	Gandhi Nagar	11KV	Medchal	1:50	4:40	2:50		Tree fallen on the 11KV Line at Gandhi Nagar	No
2			Jagathgirigutta	Maqdoom Nagar	11KV	Medchal	03.20	04.00	00.40		Tree Fallen on 11KV Line at Mee Seva	No
3			Kompally	Dholari Dhani	11KV	Medchal	16.35	17.25	00.50		11KV Pole Damaged by Lorry at Bollaram Road	No
4			Kompally	Garden Society	11KV	Medchal	01.07	03.30	02.23		No Fault	No
5	Kompally		Jaibheri	11KV	Medchal	07.29	08.38	01.09		315KVA DTR HG Fuse Insulator Failed at Dulapally Road	No	
6	Kompally		Kompally	11KV	Medchal	01.47	03.05	01.18		No Fault	No	
7	Kompally		NCL	11KV	Medchal	01.18	02.23	01.05		Tree fallen on the 11KV at Saibaba Temple (11KV Jumper opened at Saisadan Apartement)	No	
8	Petbasheerabad		Satyam Enclave	11KV	Medchal	01.35	04.05	02.30		Tree fallen on the 11KV Line at Bloom Hospital	No	
9	Subhash Nagar		Ramaraj Nagar	11KV	Medchal	01.39	04.55	03.16		Tree fallen on the 11KV Line at Ramaraj Nagar	No	
10	Subhash Nagar		Bank Colony	11KV	Medchal	03.44	04.43	00.59		No Fault	No	
11	Subhash Nagar		Bank Colony	11KV	Medchal	03.44	04.43	00.59		No Fault	No	
12	Subhash Nagar		Saibaba Nagar	11KV	Medchal	01.20	04.25	03.05		11KV Pin Insulator failed at Saibaba Nagar	No	
13	Kolthur		Anantharam	11KV	Medchal	02.40	06.40	04.00		5 No 11KV Pin Insulators failed at Darga,Antharam	No	
14	GP Pally		GP Pally	11KV	Medchal	02.10	05.50	03.40		2 Nos. 11KV Pin Insulator failed at Mallanna Temple Opposite & Venkat Godom Opposite	No	
15	Athiwelly		Ravalkole Thanda	11KV	Medchal	02.40	06.10	03.30		11KV Pin Insulator Failed at near by SS	No	
16	Devarayamjal		Pothaipally	11KV	Medchal	02.15	06.30	04.15		11KV Disc failed near SS	No	
17	Pudur		Munirabad	11KV	Medchal	07.30	09.30	02.00		2 Nos, 11KV Pin Insulator failed at Old Crusher	No	
18	Uddamarry		Snehafarm	11KV	Medchal	05.00	08.15	03.15		11KV Pin Insulator Failed at Adraspally Poultry farm	No	
19	Athiwelly		SPIC	11KV	Medchal	02.50	05.45	02.55		11KV Pin Insutlator failed at Yellampet Village	No	
20	Kandalkoya		Kandlakoya	11KV	Medchal	00.50	02.50	02.00		Tree fallen on the 11KV Line at Kandlakoya Chowrasta	No	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
21	RR N	Pudur	Mallanna Temple	11KV	Medchal	02.00	04.00	02.00		100KVA T/F failed at Pudur Village	No
22		Athiwelly	Dabeerpur	11KV	Medchal	02.45	04.00	01.15		Tree fallen on the 11KV Line at Lingapur Chowrasta	No
23		Vikas	Reddy Colony	11KV	Kukatpally	04.55	06.41	01.46		Tree Branchesh Fallen the 111kv line at Reddy Colony Duplex House	No
24		Nizampet	Srinivasa Colony	11KV	Kukatpally	05.05	06.50	01.45		11kv line Cut at Road:02, KTR Colony	No
25		Vijyanagar	AS RajuNagar	11KV	Kukatpally	05.05	07.15	02.10		Tree Branchesh Fallen the 11kv line at Socity Office Back side, V V Nagar	No
26		Vijyanagar	Jayanagar	11KV	Kukatpally	05.25	06.15	00.50		Line AB Switch Open Fridze Collage	No
27		Vijayanagar	AS Rajunagar	11KV	Kukatpally	01.20	03.00	01.40		Tripped On EL/OL Indication {Due to Rain }	No
28		Vijayanagar	Jayanagar	11KV	Kukatpally	01.50	03.10	01.20		Tripped On EL/OL Indication {Due to Rain }	No
29		Somashila	Sheshadrinagar	11KV	Kukatpally	05.48	07.44	01.56		11kv line Jumper Cut at Sai baba Nagar Colony	No
30		Mayurinagar	Mayurinagar	11KV	Kukatpally	07.40	08.28	00.48		Tree Branchesh Fallen the 11kv line Near SBI Bank at Mayurinagar	No
31		Mayurinagar	Divyashakathi,LV-I Pullout	11KV	Kukatpally	07.20	13.20	06.00		11kv Cable kit failure in Sub Station	No
32		Mayurinagar	K T R Colony	11KV	Kukatpally	12.45	14.20	01.35		D T R AB Swtich Incoming Side Lizhard fallen On the At Naryana reddy Park	No
33		Jeedimetla-II	Phase-III	11KV	Jeedimetla	01.10	02.20	01.10		Tripped On EL Indication {Due to Rain }	No
34		Jeedimetla-II	NRSA	11KV	Jeedimetla	01.20	03.34	02.14		Tree Branchesh Fallen the 11kv line at APIIC Colony Park	No
35		Jeedimetla-II	Phase-IV	11KV	Jeedimetla	04.20	06.55	02.35		11kv line AB Cable Failure at Sanjay Technical , Phase-IV	No
36		Jeedimetla-II	Apuroopa Colony	11KV	Jeedimetla	05.44	07.35	01.51		Tree Branchesh Fallen the 11kv line at opp:Janapriya Apt	No
37		Jeedimetla-IV	Vasudha	11KV	Jeedimetla	01.10	02.25	01.15		Tripped On EL/OL Indication {Due to Rain }	No
38		Jeedimetla-IV	Bhagalaxmi	11KV	Jeedimetla	01.10	02.25	01.15		Tripped On EL/OL Indication {Due to Rain }	No
39		Jeedimetla-IV	Auto stand	11KV	Jeedimetla	01.20	02.25	01.05		Tripped On EL/OL Indication {Due to Rain }	No
40		Jeedimetla-IV	AAIMatha	11KV	Jeedimetla	01.20	02.25	01.05		Tripped On EL/OL Indication {Due to Rain }	No
41		Jeedimetla-IV	Axies	11KV	Jeedimetla	01.25	02.25	01.00		Tripped On EL/OL Indication {Due to Rain }	No
42		Jeedimetla-IV	Bhagalaxmi	11KV	Jeedimetla	05.10	06.40	01.30		A Cat Fallen the T/F at opp:Little Star School, Bhgyalaxmi Colony	No
43		RGK Suraram	Surararm Village	11KV	Jeedimetla	00.30	01.35	01.05		Tripped On EL Indication {Due to Rain }	No
44		Jeedimetla-I	NITCO	11KV	Jeedimetla	01.10	06.10	05.00		11kv line Jumper cut at Obulam Comapany, Pipe line Road	No
45		Jeedimetla-I	CS Wires	11KV	Jeedimetla	01.15	08.15	07.00		Tripped On EL/OL Indication {Due to Rain }	No
46		Jeedimetla-I	Raghava	11KV	Jeedimetla	01.15	06.15	05.00		Tripped On EL/OL, {Due to Rain & Jumper Cut in SS }	No
47		Jeedimetla-I	APIIC Colony	11KV	Jeedimetla	01.10	05.10	04.00		Tripped On EL/OL Indication {Due to Rain }	No
48		Jeedimetla-I	JETL	11KV	Jeedimetla	01.25	07.25	06.00		Tree branchesh Fallen the 11kv line at AV Moters ,pipe line Road	No
49		Jeedimetla-I	Shapurnagar	11KV	Jeedimetla	01.35	07.10	05.35		11kv line Jumper Cut at Thirumala Bekari, Shapurnagar {Due to Rain}	No
50		Jeedimetla-I	Phase-II	11KV	Jeedimetla	02.20	07.20	05.00		11kv line AB Cable Failure at Manasa Pakage, pipe line Road	No
51		Jeedimetla-I	HMT Socity	11KV	Jeedimetla	04.05	07.05	03.00		11kv line Jumper Cut at Thirumala Bekari, Shapurnagar {Due to Rain}	No
52		Jeedimetla-I	JETL	11KV	Jeedimetla	08.40	10.20	01.40		11kv Jumper Cut In Sub station	No
53		Jeedimetla-I	Balaji	11KV	Jeedimetla	10.20	12.20	02.00		11kv Jumper Cut At balaji Cylinder	No
54		Jeedimetla-III	Vinayaka nagar	11KV	Jeedimetla	12.55	14.40	01.45		11kv Cable Failure At Vinayaka Nagar	No
55		Dppally-II	Indian Oil	11KV	Jeedimetla	01.15	02.30	01.15		Tripped On EL Indication {Due to Rain }	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
56		Dppally	IDA	11KV	Jeedimetla	02.20	06.00	03.40		11kv line Cut Near Petrol bunk, at Pochampally	No
57		Dppally	AGL Gagillapur	11KV	Jeedimetla	02.30	08.30	06.00		Tree branchesh Fallen the 11kv line at Gagillapur Road	No
58		Dppally	Bowrampet	11KV	Jeedimetla	5:30	7:30	2:00		Tripped On EL Indication {Due to Rain }	No
1	RR E	NGRI	Habsiguda	11KV	Habsiguda	1:28	3:15	1:47		Tree branches fallen on 11kv line near St.No.01 Habsiguda	No
2		NGRI	Scientist Colony	11KV	Habsiguda	02.42	04.36	01.54		11KV Core cable cut & fallen on 11KV Pin Insulator failed at IICT Gate No.02	No
3		Ramanthapur	Church Colony	11KV	Habsiguda	01.30	03.20	01.50		11KV Outgoing AB switch insulator failed at SS Yard & B/F from 11KV Sri Nagar Colony feeder	No
4		St.No.08	Laxmi Nagar	11KV	Habsiguda	01.41	05.32	03.51		Line patrolling but no fault & 11KV Line AB switch opened near Bhadra's Grand Hotel & 11KV AB switch female Insulator failed at Madhura Bar Backside	No
5		Nacharam	Surana	11KV	Habsiguda	03.50	04.50	01.00		Tree branches fallen on 11kv line near Road No.07 Kumar Industry at IDA Nacharam	No
6		Polytechnic	Vishal	11KV	Habsiguda	01.45	03.02	01.17		Line patrolling but no fault & Due to heavy Rain & gale	No
7		IDA Uppal	Metro	11KV	Habsiguda	01.35	04.35	03.00		Tree branches fallen on 11KV line near Oxo Company	No
8		IICT	Snehapuri	11KV	Habsiguda	06.00	07.45	01.45		Tree branches fallen on 11KV line at VST Colony	No
9		IDA Uppal	Jersey	11KV	Habsiguda	07.05	08.05	01.00		Tree branches fallen on 11KV line near Gubba Cold Storage	No
10		Moula Ali	Gayatri Nagar	11KV	Sainikpuri	05.55	07.48	01.53		Tree fallen on 11Kv line at Sadulla Nagar (Artisian Gangadhar)	No
11		VP Nagar	VV Puram	11KV	Sainikpuri	01.41	03.10	01.29		11KV line AB Switch Vivekanadapuram Park Due to Pin Insulator failed at Sapthagiri Colony (L.Insp Koteswar Rao)	No
12		VP Nagar	Deen Dayal Nagar	11KV	Sainikpuri	04.00	04.36	00.36		11Kv line AB Switch Opened at Canara bank near Sainathpuram Due to Lizard fallen on 1Kv line	No
13		Anand Bagh	NMDC	11KV	Sainikpuri	05.10	07.10	02.00		11Kv Pin Insulator failed at Uday Krishna Apt (AE)	No
14		Vasanthapuri	Raghavendra	11KV	Sainikpuri	02.15	04.39	02.24		Tree branches fallen on 11Kv lin at Railway Corner and Ab Switch Insulator failed at Yadav Nagar (Artisian Jamal)	No
15		Sainikpuri	Ramalyam	11KV	Sainikpuri	03.55	05.10	01.15		Tree branches fallen on 11Kv line at Defence Colony (AE)	No
16		RGK	RGK	11KV	Sainikpuri	04.40	05.40	01.00		11Kv Pin Insulator failed at Bharath Nagar (AE)	No
17		Moula-Ali	Mirzalguda	11KV	Sainikpuri	19.06	20.06	01.00		11Kv Pin Insulator failed at RPF (AE/Moula-Ali)	No
18		Nagaram	P S Rao Nagar	11KV	Keesara	02.55	04.32	01.37		11KV Disc failed near Forest Area Water Tank Backside	No
19		Yadgarpally	Cheeryala	11KV	Keesara	03.00	04.00	01.00		11KV Pin Insulator failed at Cheeryala Laxmi Narsimha Swamy Temple	No
20		Rampally dayara	Rampally dayara	11KV	Keesara	04.10	08.20	04.10		11KV Pin Insulator failed near Ram Reddy Poultry Form	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
21		Rampally dayara	Vanneguda Indl	11KV	Keesara	04.40	08.40	04.00		11KV Pin Insulator failed near R R Poultry Form at Bogaram	No	
22		Ghatkesar	HPCL	11KV	Keesara	05.30	08.00	02.30		11KV Disc failed near HPCL Petrol Bunk	No	
23		Aushapur	Aushapur	11KV	Keesara	03.00	08.00	05.00		11KV Disc failed at Aushapur	No	
24		Aushapur	Sandupatlaguda	11KV	Keesara	03.00	08.00	05.00		11KV Disc failed near Megha College	No	
25		Singapur	RGK	11KV	Keesara	05.30	08.30	03.00		Tree branches fallen on 11kv line at RGK-33 Block	No	
26		P&T Colony	Medipally	11KV	Keesara	05.20	06.50	01.30		160KVA DTR Disc failed at Maruthi Nagar	No	
27		P&T Colony	NIN	11KV	Keesara	07.30	08.35	01.05		Tree branches fallen on 11KV Line at P&T Colony	No	
28		Narapally	Prathap Singaram	11KV	Keesara	03.30	04.40	01.10		Tree branches fallen on 11kv line at Korremula Village	No	
29		Chakripuram	Shilpa Nagar	11KV	Keesara	02.02	05.52	03.50		11KV Disc failed at Rampally Road	No	
30		Singapur	RGK	11KV	Keesara	11.30	12.30	01.00		Tree branches fallen on 11kv line at RGK-88 Block	No	
31		Narapally	Narapally Indl	11KV	Keesara	7:30	8:50	1:20		11KV Disc failed near Delhi Public School	No	
1		HYD N	Tirumalagiri	Srinagar Colony	11KV	C-VI	01.12	04.32	03.20	EL,OL-Y&Bph	HT Jumper cut at Tirumalagiri	No
2			Osm. University	Mettuguda	11KV	V	1:15	2:55	1:40	EL	No Visible Fault	No
3			Zamistanpur	S.P College	11KV	V	1:18	4:28	3:10	EL,OL-Rph	HT Jumper cut at Z.P Garden	No
4			Tirumalagiri	Jupitor Colony	11KV	C-VI	1:30	2:55	1:25	EL,OL-Y&Bph	No Visible Fault	No
5			Osm. University	Ladies Hostel	11KV	V	1:30	2:55	1:25	EL	No Visible Fault	No
6			Road N.12	Kana Durga Temple	11KV	X	1:29	2:40	1:11	EL,OL-Yph	No Visible Fault	No
7			Toli Chowki	Road No.86	11KV	X	2:02	3:48	1:46	EL	Tree branches fallen on lines at Plot No.509	No
8			Chinna Thokatta	Old Bowenpally	11KV	VI	2:00	4:00	2:00	EL,OL-R&Bph	Tree branches fallen on lines at Old Bowenpally	No
9			Bowenpally	Sancharapuri Colony	11KV	VI	1:20	2:27	1:07	EL,OL-Yph	No Visible Fault	No
10			Bowenpally	Pension Line	11KV	VI	1:24	4:24	3:00	EL,OL-Yph	Tree branches fallen on lines at Pension Line	No
11			Prashanth Nagar	Time Tek	11KV	VI	2:20	4:50	2:30	EL	Tree branches fallen on lines at Ice Cream Center	No
12			Prashanth Nagar	Ganesh Kanta	11KV	VI	2:25	3:45	1:20	EL	Tree branches fallen on lines at Ganesh Kanta	No
13			Jubilee Hills	A.O.U	11KV	X	1:40	3:10	1:30	EL,OL-Bph	No Visible Fault	No
14			Gymkhana	Balamrai	11KV	C-VI	1:46	3:26	1:40	EL	DTR fault at Priya Enclave	No
15			Yousufguda	Hylam Colony	11KV	X	1:48	3:30	1:42	EL	Tree branches fallen on lines at Police Line	No
16			Yousufguda	Police Line	11KV	X	2:08	3:30	1:22	EL	Tree branches fallen on lines at Police Line	No
17			Marredpally	Jyothi Colony	11KV	C-VI	1:50	3:10	1:20	EL	No Visible Fault	No
18			Film Nagar	Apollo	11KV	X	1:30	2:40	1:10	EL,OL	No Visible Fault	No
19			Allwyn	I.E	11KV	IV	2:15	3:50	1:35	EL	No Visible Fault	No
20			H.A.L	Samrat	11KV	VI	1:40	3:30	1:50	All Indication	Tree fallen on lines at Jangle Bit	Arranged B/F on 11KV B.B.R Hospital fdr
21	Macha Bollarum		Radha Sath Sang	11KV	C-VI	1:20	2:30	1:10	EL	No Visible Fault	No	
22	Seethaphalmandi		Medibai	11KV	V	4:50	6:50	2:00	EL,OL	Tree branches fallen on lines at Bhu Laxmi Temple	No	
23	Bowenpally		Pipe Line	11KV	VI	1:29	9:12	7:43	EL,OL-Yph	Tree branches fallen on lines at Bhagath Singh Park	No	
24	I.D.P.L		Tipcon	11KV	VI	7:40	9:00	1:20	All Indication	DTR fault at Tipcon Company	No	
25	Chinna Thokatta		C.E Colony	11KV	VI	8:15	10:05	1:50	EL	DTR fault at Vaisnavi Matha Temple	No	
26	Pragatools		TC Bala Nagar	11KV	VI	1:10	9:30	8:20	EL	Pin Insulator flash over & Tree branches fallen on lines at IDA Bala Nagar	No	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
27		Bhudevi Nagar	Maruthi Nagar	11KV	C-VI	1:23	2:40	1:17	EL,OL	No Visible Fault	No	
28		Yellareddyguda	Savera	11KV	X	2:18	3:45	1:27	EL,OL	No Visible Fault	No	
29		Bansilalpet	C.C Nagar	11KV	V	1:50	3:05	1:15	EL,OL-Bph	CT blasted at SS	Arranged B/F on 11KV N.T.P.C fdr	
30		R.P Nilayam	Naga Devatha Temple	11KV	C-VI	4:10	7:00	2:50	EL,OL	No Visible Fault	No	
31		Zamistanpur	S.P College	11KV	V	4:52	5:55	1:03	EL,OL-Rph	No Visible Fault	No	
32		Toli Chowki	Road No.86	11KV	X	5:44	12:45	7:01	EL	Tree branches fallen on lines at Plot No.509	No	
33		I.D.P.L	Shivalayam	11KV	VI	4:25	9:05	4:40	All Indication	UG Cable fault at Bala Nagar	No	
34		I.D.P.L	Vijaya Electrical	11KV	VI	4:25	8:55	4:30	All Indication	Pin Insulator flash over at Bala Nagar Section Office	No	
35		Pragatools	T.C Bala Nagar	11KV	VI	1:30	9:30	8:00	EL,OL	Tree branches fallen on lines at Plot No.4, IDA Bala Nagar	No	
36		Pragatools	L&T	11KV	VI	1:20	8:15	6:55	EL	Tree branches fallen on lines	No	
37		Pragatools	Asbestor Hills	11KV	VI	1:08	2:20	1:12	EL	No Visible Fault	No	
38		Pragatools	Pragathi Pack	11KV	VI	3:25	5:20	1:55	EL	Tree branches fallen on lines at R.R Nagar	No	
39		Pragatools	Raj Foods	11KV	VI	2:10	6:42	4:32	EL,OL	Tree branches fallen on lines at I.D.A Kukatpally	No	
40		Lalaguda	Shanthi Nagar	11KV	V	1:27	2:31	1:04	EL	No Visible Fault	No	
41		Lalaguda	Lalapet	11KV	V	6:04	7:20	1:16	EL	Jumper cut at Lalapet	No	
42		Madhapur	Shilparammam	11KV	X	0:05	1:15	1:10	EL	No Visible Fault	Arranged B/F on 11KV Value Lab fdr	
43		Gunrock	Lalbazar	11KV	C-VI	1:18	3:24	2:06	EL,OL-Bph	Tree branches fallen on lines at P&T Colony, Lalbazar	No	
44		MLA Colony	K.B.R Park	11KV	X	08.50	10.00	01.10	EL,OL-R&Bph	Tree branches fallen on lines at N-TV	No	
1		HYD S	Devi Bagh	Edgah	11KV	III	01.10	03.05	01.55	OL-Rph	No Visible Fault	No
2			Teegalaguda	Shanker Nagar	11KV	VIII	1:27	3:57	2:30	All Indication	HT Jumper cut at Shanker Nagar	No
3			Miralam	Madina Masjid	11KV	III	1:45	4:30	2:45	EL,OL	No Visible Fault	No
4			Miralam	Ranjan Colony	11KV	III	1:50	3:10	1:20	EL,OL	No Visible Fault	No
5			Miralam	N.S Kunta	11KV	III	2:00	3:35	1:35	EL,OL	No Visible Fault	No
6			Miralam	Kalapather	11KV	III	2:05	4:48	2:43	EL,OL	No Visible Fault	No
7	Khilwath		Khazipura	11KV	III	2:37	4:26	1:49	EL,OL-Bph	Cut Point Jumper cut at Kumarwadi DTR	No	
8	Hyderguda		A.G Colony	11KV	III	1:40	3:15	1:35	EL	HT Jumper cut at Seven Hills	No	
9	Yakuthpura		Bada Bazar	11KV	VIII	1:44	2:50	1:06	EL	No Visible Fault	No	
10	Miralam		Ranjan Colony	11KV	III	4:05	9:20	5:15	EL,OL	Brass Patti & Jumpers cut at Shamshi Garden	No	
11	Attapur		HUDA Colony	11KV	III	2:30	10:27	7:57	EL	No Visible Fault	Arranged B/F on 11KV Kishan Bagh OH feeder	
12	Attapur		N.M Guda OH	11KV	III	3:20	4:30	1:10	EL	HT Line snapped at Hasan Nagar	No	
13	Salarjung		Madina	11KV	III	6:05	8:45	2:40	EL	Iron rod fallen on lines at A1 Hotel	No	
14	Falaknuma		Farooq Nagar	11KV	III	16.12	18.26	02.14	EL,OL	Breaker Problem	Arranged B/F on 11KV Fathima Nagar feeder	
1		A.S.R Raju Nagar	Ushodaya Colony	11KV	VII	01.00	03.50	02.50	OL	No Visible Fault	No	
2		Golconda	Darga OH	11KV	VII	01.00	03.25	02.25	EL,OL-Y&Bph	No Visible Fault	No	
3		Industrial Area	Mother Dairy	11KV	II	01.15	03.08	01.53	EL,OL	No Visible Fault	No	
4		Vittalwadi	Gandhi Kuteer	11KV	II	01.28	02.45	01.17	EL,OL-Bph	No Visible Fault	No	
5		Vittalwadi	APCO	11KV	II	01.30	03.10	01.40	All Indication	No Visible Fault	No	
6		Golconda	Darga Cable	11KV	VII	01.35	04.20	02.45	EL	No Visible Fault	No	
7		Golconda	Shaikpet W.W	11KV	VII	01.40	06.10	04.30	EL	Tree branches fallen on lines at Gulshan Colony	No	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
8	HYD C	Toli Chowki	Para Mount Colony	11KV	VII	01.32	05.58	04.26	EL,OL-R&Bph	Cable End Kit failed at Royal Apts	No
9		Narayanaguda	Chikkadapally	11KV	II	01.45	03.45	02.00	EL,OL-Y&Bph	Pin Insulator flash over at Lalitha Apts	No
10		Chilkaiguda	Golconda X-Roads	11KV	II	01.55	06.45	04.50	EL,OL	No Visible Fault	No
11		Zamistanpur	Dayara Market	11KV	II	01.51	07.04	05.13	EL	Kite Sticks fallen on lines at Daryara Market	No
12		Toli Chowki	Kala Banglow	11KV	VII	01.45	07.25	05.40	EL	Tree branches fallen on lines at Para Mount Colony	No
13		Nizam College	Little Flower	11KV	I	01.50	03.02	01.12	EL	No Visible Fault	No
14		Asif Nagar	Military	11KV	VII	01.25	08.55	07.30	EL,OL-Rph	Big tree fallen on lines & HT Lines snapped at Military	No
15		Z.P Office	H.P.Sabha	11KV	I	02.08	03.28	01.20	EL	No Visible Fault	No
16		Golconda	Brindavan Colony	11KV	VII	02.30	03.40	01.10	EL,OL	No Visible Fault	No
17		Nampally	V.N.C	11KV	VII	01.40	02.42	01.02	EL,OL	No Visible Fault	No
18		Amberpet	Play Ground	11KV	II	02.50	03.55	01.05	EL	No Visible Fault	No
19		Amberpet	Amberpet	11KV	II	01.35	04.25	02.50	OL-R&Yph	Tree branches fallen on lines at Masjid	No
20		Indira Park	Talla Basti	11KV	I	01.35	03.20	01.45	EL	Tree branches fallen on lines at Talla Basti	No
21		Indira Park	R.K Mutt	11KV	I	01.40	03.20	01.40	EL	No Visible Fault	No
22		Golconda	Mothi Mahal	11KV	VII	01.45	03.20	01.35	EL	No Visible Fault	No
23		Golconda	Aditya Nagar OH	11KV	VII	01.47	03.20	01.33	EL	No Visible Fault	No
24		I.T.I Mallepally	Anjuman	11KV	VII	01.10	02.41	01.31	EL	No Visible Fault	No
25		I.T.I Mallepally	V.B.R.I	11KV	VII	01.30	02.42	01.12	EL	No Visible Fault	No
26		I.T.I Mallepally	P.S Nagar	11KV	VII	01.31	02.42	01.11	EL	No Visible Fault	No
27		Fever Hospital	C.C Shroff Hospital	11KV	II	01.38	02.50	01.12	EL,OL-Rph	No Visible Fault	No
28		Fever Hospital	Tourist Hotel	11KV	II	01.50	05.25	03.35	EL	No Visible Fault	No
29		Fever Hospital	Nallakunta	11KV	II	01.55	05.50	03.55	EL	Tree branches fallen on lines at Nallakunta	No
30		A.S.R Raju Nagar	Jeevan Kalyan Nagar	11KV	VII	01.35	06.30	04.55	EL	Tree branches fallen on lines at Citizen Apts	No
31		Bathkammakunta	Ahobilmutt	11KV	II	01.30	04.40	03.10	EL	Tree branches fallen on lines at College Hotel Management	No
32		Bathkammakunta	Ayyappa Temple	11KV	II	01.41	08.25	06.44	EL	Disc Insulator flash over at Sidda Apts	No
33		Bathkammakunta	Shivam	11KV	II	01.50	05.24	03.34	EL,OL-Bph	Tree branches fallen on lines at Taruni Super Market	No
34		Bathkammakunta	C.E Colony	11KV	II	02.10	07.15	05.05	EL,OL-Bph	Disc Insulator flash over at Ganga Bowli	No
35		Langer House	Nethaji Nagar	11KV	VII	01.30	05.05	03.35	EL,OL-Yph	Banner fallen on lines at Mogal Ka Nala	No
36		Langer House	Prashanth Nagar	11KV	VII	01.47	05.14	03.27	EL,OL-R&Yph	Tree branches fallen on lines at Lawrence PT	No
37		I.T.I Mallepally	Anwar Uloom College	11KV	VII	01.55	04.00	02.05	EL	No Visible Fault	Arranged B/F on 11KV Amba Hospital fdr
38		S.D Hospital	Crescent Hospital	11KV	VII	02.20	03.55	01.35	EL	Cable End Kit failed at Crescent Hospital	No
39		I.T.I Mallepally	Anjuman	11KV	VII	06.13	09.20	03.07	EL	Pin Insulator flash over at Bondalagadda	No
40		A.S.R Raju Nagar	Ushodaya Colony	11KV	VII	04.10	07.50	03.40	EL	Tree branches fallen on lines at Market Yard	No
41		Bathkammakunta	Saibaba Temple	11KV	II	04.42	08.38	03.56	OL	No Visible Fault	No
42		Erramanzil	Anugraha	11KV	I	01.30	10.30	09.00	EL	Inter linking Cable at Banjara Hills	No
43		Industrial Area	Barkathpura	11KV	II	02.00	04.40	02.40	EL,OL-Rph	Tree branches fallen on lines at Vegitable Market	No
44		Vittalwadi	Y.M.C.A	11KV	II	01.42	07.05	05.23	EL,OL-Rph	Tree branches fallen on lines at Reddy College	No
45		Fever Hospital	C.C Shroff Hospital	11KV	II	03.40	07.42	04.02	EL,OL-Rph	No Visible Fault	No
46		Mothi Mahal	M.D Lines	11KV	VII	01.54	03.52	01.58	EL,OL-R&Yph	No Visible Fault	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
47		Hyderguda	Abids	11KV	I	03.35	05.35	02.00	EL	No Visible Fault	No
48		Durga Nagar	Bapu Nagar	11KV	II	01.40	06.20	04.40	EL	Cable fault	Arranged B/F on 11KV Chenna Reddy Nagar fdr
49		Mothi Mahal	M.D Lines	11KV	VII	05.18	06.22	01.04	EL,OL	No Visible Fault	No
50		Lumbini Park	T.T.D	11KV	I	06.17	08.00	01.43	EL	Insulator falsh over at Himayath Nagar	No
51		A.S.R Raju Nagar	Ushodaya Colony	11KV	I	04.10	07.50	03.40	EL	Tree branches fallen on lines at Market Yard	No
52		Chilkaiguda	Golconda X-Roads	11KV	II	01.20	09.30	08.10	EL,OL-Bph	No Visible Fault	Partial feeder Arranged B/F on 1KV Dayara Market fdr
53		Langer House	Prashanth Nagar	11KV	VII	9:55	10:57	1:02	All Indication	No Visible Fault	Arranged B/F on 11KV Langer House Cable feeder
54		Chilkaiguda	44 Bus Stop	11KV	II	14.50	15.54	01.04	EL	No Visible Fault	No